



RITA BRIGHT COM LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	RITA BRIGHT COMMUNITY CENTER	WS- 005534	9/22/2016	1	Cooler	In hallway adjacent to main entrance	FT-82016-005534-A	< 1	FT-82016-005534-B	< 1
2	RITA BRIGHT COMMUNITY CENTER	WS- 005537	9/22/2016	1	Food Prep Sink	In kitchen	FT-82016-005537-A	< 1	FT-82016-005537-B	< 1