



BALLOU LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location			1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	BALLOU HIGH SCHOOL	WS- 010374	8/15/2016	3	Fountain	In hallway adjacent to auditorium	High	Left	FT-82016-010374-A	< 1	FT-82016-010374-B	< 1
2	BALLOU HIGH SCHOOL	WS- 010375	8/15/2016	3	Fountain	In hallway adjacent to auditorium	Low	Right	FT-82016-010375-A	< 1	FT-82016-010375-B	< 1
3	BALLOU HIGH SCHOOL	WS- 010376	8/15/2016	3	Fountain	In hallway adjacent to room 3622	High	Left	FT-82016-010376-A	< 1	FT-82016-010376-B	< 1
4	BALLOU HIGH SCHOOL	WS- 010377	8/15/2016	3	Fountain	In hallway adjacent to room 3622	Low	Right	FT-82016-010377-A	< 1	FT-82016-010377-B	< 1
5	BALLOU HIGH SCHOOL	WS- 010382	8/15/2016	3	Fountain	In classroom 3002		Mid	FT-82016-010382-A	< 1	FT-82016-010382-B	< 1
6	BALLOU HIGH SCHOOL	WS- 010399	8/15/2016	3	Fountain	In hallway adjacent to room 3012	Low	Right	FT-82016-010399-A	< 1	FT-82016-010399-B	< 1
7	BALLOU HIGH SCHOOL	WS- 010400	8/15/2016	3	Fountain	In hallway adjacent to room 3012	High	Left	FT-82016-010400-A	< 1	FT-82016-010400-B	< 1
8	BALLOU HIGH SCHOOL	WS- 010910	8/15/2016	3	Fountain	In hallway adjacent to room 3026	High	Left	FT-82016-010910-A	< 1	FT-82016-010910-B	< 1
9	BALLOU HIGH SCHOOL	WS- 010911	8/15/2016	3	Fountain	In hallway adjacent to room 3026	Low	Right	FT-82016-010911-A	< 1	FT-82016-010911-B	< 1
10	BALLOU HIGH SCHOOL	WS- 010912	8/15/2016	3	Fountain	In hallway adjacent to gym 3210	High	Left	FT-82016-010912-A	< 1	FT-82016-010912-B	< 1
11	BALLOU HIGH SCHOOL	WS- 010913	8/15/2016	3	Fountain	In hallway adjacent to gym 3210	Low	Right	FT-82016-010913-A	< 1	FT-82016-010913-B	< 1
12	BALLOU HIGH SCHOOL	WS- 010914	8/15/2016	3	Fountain	In hallway adjacent to gym 3210	High	Left	FT-82016-010914-A	< 1	FT-82016-010914-B	< 1
13	BALLOU HIGH SCHOOL	WS- 010915	8/15/2016	3	Fountain	In hallway adjacent to gym 3210	Low	Right	FT-82016-010915-A	< 1	FT-82016-010915-B	< 1
14	BALLOU HIGH SCHOOL	WS- 010916	8/15/2016	3	Fountain	In the gym 3210	Low	Right	FT-82016-010916-A	< 1	FT-82016-010916-B	< 1
15	BALLOU HIGH SCHOOL	WS- 010917	8/15/2016	3	Fountain	In gym 3210	High	Left	FT-82016-010917-A	< 1	FT-82016-010917-B	< 1
16	BALLOU HIGH SCHOOL	WS- 010959	8/15/2016	3	Fountain	In hallway adjacent to room 3200	High	Left	FT-82016-010959-A	< 1	FT-82016-010959-B	< 1
17	BALLOU HIGH SCHOOL	WS- 010960	8/15/2016	3	Fountain	In hallway adjacent to room 3200	Low	Right	FT-82016-010960-A	< 1	FT-82016-010960-B	< 1
18	BALLOU HIGH SCHOOL	WS- 010961	8/15/2016	3	Fountain	In fitness room 3215	High	Left	FT-82016-010961-A	< 1	FT-82016-010961-B	< 1
19	BALLOU HIGH SCHOOL	WS- 010962	8/15/2016	3	Fountain	In fitness room 3215	Low	Right	FT-82016-010962-A	< 1	FT-82016-010962-B	< 1
20	BALLOU HIGH SCHOOL	WS- 010963	8/15/2016	3	Fountain	In fitness room 3215	High	Left	FT-82016-010963-A	< 1	FT-82016-010963-B	< 1
21	BALLOU HIGH SCHOOL	WS- 010964	8/15/2016	3	Fountain	In fitness room 3215	Low	Right	FT-82016-010964-A	< 1	FT-82016-010964-B	< 1
22	BALLOU HIGH SCHOOL	WS- 011299	8/15/2016	1	Fountain	In hallway adjacent to room 1012	High	Left	FT-82016-011299-A	< 1	FT-82016-011299-B	< 1
23	BALLOU HIGH SCHOOL	WS- 011300	8/15/2016	1	Fountain	In hallway adjacent to room 1012	Low	Right	FT-82016-011300-A	< 1	FT-82016-011300-B	< 1
24	BALLOU HIGH SCHOOL	WS- 011309	8/15/2016	1	Fountain	In hallway adjacent to room 1020	High	Left	FT-82016-011309-A	< 1	FT-82016-011309-B	< 1
25	BALLOU HIGH SCHOOL	WS- 011310	8/15/2016	1	Fountain	In hallway adjacent to room 1026	Low	Right	FT-82016-011310-A	< 1	FT-82016-011310-B	< 1
26	BALLOU HIGH SCHOOL	WS- 011327	8/15/2016	1	Fountain	In hallway adjacent to room 1204	High	Left	FT-82016-011327-A	< 1	FT-82016-011327-B	< 1
27	BALLOU HIGH SCHOOL	WS- 011328	8/15/2016	1	Fountain	In hallway adjacent to room 1204	Low	Right	FT-82016-011328-A	< 1	FT-82016-011328-B	< 1
28	BALLOU HIGH SCHOOL	WS- 011329	8/15/2016	1	Fountain	In hallway adjacent to room 1402	High	Left	FT-82016-011329-A	< 1	FT-82016-011329-B	< 1
29	BALLOU HIGH SCHOOL	WS- 011330	8/15/2016	1	Fountain	In hallway adjacent to room 1402	Low	Right	FT-82016-011330-A	< 1	FT-82016-011330-B	< 1
30	BALLOU HIGH SCHOOL	WS- 011338	8/15/2016	1	Fountain	In hallway adjacent to room 1306	High	Left	FT-82016-011338-A	< 1	FT-82016-011338-B	< 1
31	BALLOU HIGH SCHOOL	WS- 011339	8/15/2016	1	Fountain	In hallway adjacent to room 1306	Low	Right	FT-82016-011339-A	< 1	FT-82016-011339-B	< 1
32	BALLOU HIGH SCHOOL	WS- 011340	8/15/2016	1	Fountain	In hallway adjacent to auditorium 1600	Low	Right	FT-82016-011340-A	< 1	FT-82016-011340-B	< 1
33	BALLOU HIGH SCHOOL	WS- 011341	8/15/2016	1	Fountain	In hallway adjacent to auditorium 1600	High	Right	FT-82016-011341-A	< 1	FT-82016-011341-B	< 1
34	BALLOU HIGH SCHOOL	WS- 011342	8/15/2016	1	Fountain	In hallway adjacent to dressing room 1612	High	Left	FT-82016-011342-A	< 1	FT-82016-011342-B	< 1
35	BALLOU HIGH SCHOOL	WS- 011343	8/15/2016	1	Fountain	In hallway adjacent to dressing room 1612	Low	Right	FT-82016-011343-A	< 1	FT-82016-011343-B	< 1
36	BALLOU HIGH SCHOOL	WS- 011344	8/15/2016	1	Fountain	In hallway adjacent to day care room 1630	High	Left	FT-82016-011344-A	< 1	FT-82016-011344-B	< 1
37	BALLOU HIGH SCHOOL	WS- 011345	8/15/2016	1	Fountain	In hallway adjacent to day care room 1630	Low	Right	FT-82016-011345-A	< 1	FT-82016-011345-B	< 1
38	BALLOU HIGH SCHOOL	WS- 011357	8/15/2016	2	Fountain	In hallway adjacent to school store room 2350	High	Left	FT-82016-011357-A	< 1	FT-82016-011357-B	< 1
39	BALLOU HIGH SCHOOL	WS- 011358	8/15/2016	2	Fountain	In hallway adjacent to school store room 2350	Low	Right	FT-82016-011358-A	< 1	FT-82016-011358-B	< 1
40	BALLOU HIGH SCHOOL	WS- 011359	8/15/2016	2	Fountain	In hallway adjacent to room 2411	High	Left	FT-82016-011359-A	< 1	FT-82016-011359-B	< 1

41	BALLOU HIGH SCHOOL	WS- 011360	8/15/2016	2	Fountain	In hallway adjacent to room 2411	Low	Right	FT-82016-011360-A	< 1	FT-82016-011360-B	< 1
42	BALLOU HIGH SCHOOL	WS- 011366	8/15/2016	2	Food Prep Sink	In kitchen room 2503 on east wall			FT-82016-011366-A	< 1	FT-82016-011366-B	< 1
43	BALLOU HIGH SCHOOL	WS- 011368	8/15/2016	2	Ice Maker	In kitchen room 2503 (ice maker)		Left	FT-82016-011368-A	< 1	FT-82016-011368-B	< 1
44	BALLOU HIGH SCHOOL	WS- 011377	8/15/2016	2	Fountain	In hallway adjacent to room 2503	Low	Right	FT-82016-011377-A	< 1	FT-82016-011377-B	< 1
45	BALLOU HIGH SCHOOL	WS- 011378	8/15/2016	2	Fountain	In hallway adjacent to room 2623	Low	Right	FT-82016-011378-A	< 1	FT-82016-011378-B	< 1
46	BALLOU HIGH SCHOOL	WS- 011379	8/15/2016	2	Fountain	In hallway adjacent to room 2623	High	Left	FT-82016-011379-A	< 1	FT-82016-011379-B	< 1
47	BALLOU HIGH SCHOOL	WS- 011384	8/15/2016	2	Fountain	In hallway across from room 2012	High	Left	FT-82016-011384-A	< 1	FT-82016-011384-B	< 1
48	BALLOU HIGH SCHOOL	WS- 011385	8/15/2016	2	Fountain	In hallway across from room 2012	Low	Right	FT-82016-011385-A	< 1	FT-82016-011385-B	< 1
49	BALLOU HIGH SCHOOL	WS- 011386	8/15/2016	2	Fountain	In hallway adjacent to room 2503	High	Left	FT-82016-011386-A	< 1	FT-82016-011386-B	< 1
50	BALLOU HIGH SCHOOL	WS- 011399	8/15/2016	2	Fountain	In hallway adjacent to room 2026	High	Left	FT-82016-011399-A	< 1	FT-82016-011399-B	< 1
51	BALLOU HIGH SCHOOL	WS- 011400	8/15/2016	2	Fountain	In hallway adjacent to room 2026	Low	Right	FT-82016-011400-A	< 1	FT-82016-011400-B	< 1
52	BALLOU HIGH SCHOOL	WS- 011414	8/15/2016	2	Fountain	In hallway adjacent to room 2201	High	Left	FT-82016-011414-A	< 1	FT-82016-011414-B	< 1
53	BALLOU HIGH SCHOOL	WS- 011415	8/15/2016	2	Fountain	In hallway adjacent to room 2201	Low	Right	FT-82016-011415-A	< 1	FT-82016-011415-B	< 1
54	BALLOU HIGH SCHOOL	WS- 011416	8/15/2016	2	Fountain	In pool area left of pool	High	Left	FT-82016-011416-A	< 1	FT-82016-011416-B	< 1
55	BALLOU HIGH SCHOOL	WS- 011417	8/15/2016	2	Fountain	In pool area left of pool	Low	Right	FT-82016-011417-A	< 1	FT-82016-011417-B	< 1
56	BALLOU HIGH SCHOOL	WS- 011418	8/15/2016	2	Fountain	In pool area right of pool	High	Left	FT-82016-011418-A	< 1	FT-82016-011418-B	< 1
57	BALLOU HIGH SCHOOL	WS- 011419	8/15/2016	2	Fountain	In pool area right of pool	Low	Right	FT-82016-011419-A	< 1	FT-82016-011419-B	< 1
58	BALLOU HIGH SCHOOL	WS- 011421	8/15/2016	2	Fountain	In hallway adjacent to room 2205	High	Left	FT-82016-011421-A	< 1	FT-82016-011421-B	< 1
59	BALLOU HIGH SCHOOL	WS- 011422	8/15/2016	2	Fountain	In hallway adjacent to room 2205	Low	Right	FT-82016-011422-A	< 1	FT-82016-011422-B	< 1
60	BALLOU HIGH SCHOOL	WS- 011426	8/15/2016	2	Fountain	In hallway adjacent to stairwell 6	High	Left	FT-82016-011426-A	< 1	FT-82016-011426-B	< 1
61	BALLOU HIGH SCHOOL	WS- 011427	8/15/2016	2	Fountain	In hallway adjacent to stairwell 6	Low	Right	FT-82016-011427-A	< 1	FT-82016-011427-B	< 1
62	BALLOU HIGH SCHOOL	WS- 011432	8/15/2016	2	Fountain	In hallway adjacent to room 2320	High	Left	FT-82016-011432-A	< 1	FT-82016-011432-B	< 1
63	BALLOU HIGH SCHOOL	WS- 011434	8/15/2016	2	Fountain	In hallway adjacent to room 2320	Low	Left	FT-82016-011434-A	< 1	FT-82016-011434-B	< 1
64	BALLOU HIGH SCHOOL	WS- 011435	8/15/2016	2	Fountain	In hallway adjacent to room 2200	High	Right	FT-82016-011435-A	< 1	FT-82016-011435-B	< 1
65	BALLOU HIGH SCHOOL	WS- 011436	8/15/2016	2	Fountain	In hallway adjacent to room 2200	Low	Right	FT-82016-011436-A	< 1	FT-82016-011436-B	< 1
66	BALLOU HIGH SCHOOL	WS- 011437	8/15/2016	2	Fountain	In hallway adjacent to football locker room	High	Left	FT-82016-011437-A	< 1	FT-82016-011437-B	< 1
67	BALLOU HIGH SCHOOL	WS- 011438	8/15/2016	2	Fountain	In hallway adjacent to football locker room	Low	Right	FT-82016-011438-A	< 1	FT-82016-011438-B	< 1
68	BALLOU HIGH SCHOOL	WS- 011439	8/15/2016	2	Health Suite	In break room 2322 in health suite			FT-82016-011439-A	< 1	FT-82016-011439-B	< 1
69	BALLOU HIGH SCHOOL	WS- 011440	8/15/2016	2	Health Suite	In exam room 2317 in health suite			FT-82016-011440-A	< 1	FT-82016-011440-B	< 1
70	BALLOU HIGH SCHOOL	WS- 011441	8/15/2016	2	Health Suite	In exam room 2316 in health suite			FT-82016-011441-A	2.9	FT-82016-011441-B	< 1
			10/10/2016						Re-test A	< 1	Re-test B	< 1
71	BALLOU HIGH SCHOOL	WS- 011442	8/15/2016	2	Health Suite	In exam room 2315 in health suite			FT-82016-011442-A	1.5	FT-82016-011442-B	< 1
			10/10/2016						Re-test A	< 1	Re-test B	< 1
72	BALLOU HIGH SCHOOL	WS- 011443	8/15/2016	2	Health Suite	In exam room 2313 in health suite			FT-82016-011443-A	< 1	FT-82016-011443-B	< 1
73	BALLOU HIGH SCHOOL	WS- 011444	8/15/2016	2	Health Suite	In exam room 2321 in health suite			FT-82016-011444-A	< 1	FT-82016-011444-B	< 1
74	BALLOU HIGH SCHOOL	WS- 011445	8/15/2016	2	Health Suite	In exam room 2309 in health suite			FT-82016-011445-A	< 1	FT-82016-011445-B	< 1