



BRENT ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	BRENT ELEMENTARY SCHOOL	WS- 009315	12/22/2016	1	Classroom Faucet	In classroom 110	FT-122016-009315-A	< 1	FT-122016-009315-B	< 1
2	BRENT ELEMENTARY SCHOOL	WS- 009321	12/22/2016	1	Classroom Faucet	In classroom 102	FT-122016-009321-A	< 1	FT-122016-009321-B	< 1
3	BRENT ELEMENTARY SCHOOL	WS- 009317	12/22/2016	1	Classroom Faucet	In classroom 108	FT-122016-009317-A	< 1	FT-122016-009317-B	< 1
4	BRENT ELEMENTARY SCHOOL	WS- 009313	12/22/2016	1	Classroom Faucet	In classroom 118	FT-122016-009313-A	< 1	FT-122016-009313-B	< 1
5	BRENT ELEMENTARY SCHOOL	WS- 009311	12/22/2016	1	Classroom Faucet	In classroom 116	FT-122016-009311-A	< 1	FT-122016-009311-B	< 1
6	BRENT ELEMENTARY SCHOOL	WS- 009319	12/22/2016	1	Classroom Faucet	In classroom 104	FT-122016-009319-A	< 1	FT-122016-009319-B	< 1
7	BRENT ELEMENTARY SCHOOL	WS- 009327	12/22/2016	2	Break Room	In staff lounge 211	FT-112016-009327-A	< 1	FT-112016-009327-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb