



BRENTWOOD REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	BRENTWOOD RECREATION CENTER	WS- 012677	9/21/2016	1	Cooler	In hallway adjacent to computer lab High Left	FT-82016-012677-A	< 1	FT-82016-012677-B	< 1
2	BRENTWOOD RECREATION CENTER	WS- 012678	9/21/2016	1	Cooler	In hallway adjacent to computer lab Low Right	FT-82016-012678-A	< 1	FT-82016-012678-B	< 1
3	BRENTWOOD RECREATION CENTER	WS- 012680	9/21/2016	1	Food Prep Sink	In kitchen 105	FT-82016-012680-A	< 1	FT-82016-012680-B	< 1