



BURRVILLE ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

| | Building Location: Building Name | RECORD ID | Date Analyzed | Floor | Device Type | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ppb) |
|----|----------------------------------|------------|---------------|-------|--------------|------------------------|----------------------|-------------------------------|----------------------|-------------------------------|
| 1 | BURRVILLE ELEMENTARY SCHOOL | WS- 009236 | 12/14/2016 | 2 | Break Room | In staff lounge | FT-102016-009236-A | < 1 | FT-102016-009236-B | < 1 |
| 2 | BURRVILLE ELEMENTARY SCHOOL | WS- 009248 | 12/14/2016 | 2 | Combo Faucet | In classroom 227 | FT-112016-009248-A | 4.7 | FT-112016-009248-B | < 1 |
| 3 | BURRVILLE ELEMENTARY SCHOOL | WS- 009256 | 12/14/2016 | 2 | Combo Faucet | In classroom 221 | FT-112016-009256-A | 14 | FT-112016-009256-B | < 1 |
| 4 | BURRVILLE ELEMENTARY SCHOOL | WS- 009254 | 12/14/2016 | 2 | Combo Faucet | In classroom 224 | FT-112016-009254-A | 4.7 | FT-112016-009254-B | < 1 |
| 5 | BURRVILLE ELEMENTARY SCHOOL | WS- 009211 | 12/14/2016 | 1 | Combo Faucet | In classroom 108 | FT-112016-009211-A | 2.7 | FT-112016-009211-B | < 1 |
| 6 | BURRVILLE ELEMENTARY SCHOOL | WS- 009221 | 12/14/2016 | 1 | Combo Faucet | In Pre-K classroom 110 | FT-112016-009221-A | 7.9 | FT-112016-009221-B | < 1 |
| 7 | BURRVILLE ELEMENTARY SCHOOL | WS- 009217 | 12/14/2016 | 1 | Combo Faucet | In classroom 113 | FT-112016-009217-A | 6.5 | FT-112016-009217-B | < 1 |
| 8 | BURRVILLE ELEMENTARY SCHOOL | WS- 009219 | 12/14/2016 | 1 | Combo Faucet | In classroom 115 | FT-112016-009219-A | 1.9 | FT-112016-009219-B | < 1 |
| 9 | BURRVILLE ELEMENTARY SCHOOL | WS- 009223 | 12/14/2016 | 1 | Combo Faucet | In Pre-K classroom 111 | FT-112016-009223-A | 8.8 | FT-112016-009223-B | < 1 |
| 10 | BURRVILLE ELEMENTARY SCHOOL | WS- 009213 | 12/14/2016 | 1 | Combo Faucet | In classroom 114 | FT-112016-009213-A | 2 | FT-112016-009213-B | < 1 |
| 11 | BURRVILLE ELEMENTARY SCHOOL | WS- 009244 | 12/14/2016 | 2 | Combo Faucet | In classroom 228 | FT-112016-009244-A | 1.2 | FT-112016-009244-B | < 1 |

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

| | | | | | | | | | | |
|----|-----------------------------|------------|-----------|---|--------------|------------------------|--------------------|-----|--------------------|-----|
| 2 | BURRVILLE ELEMENTARY SCHOOL | WS- 009248 | 1/25/2017 | 2 | Combo Faucet | In classroom 227 | FT-112016-009248-A | 2.1 | FT-112016-009248-B | < 1 |
| 3 | BURRVILLE ELEMENTARY SCHOOL | WS- 009256 | 1/25/2017 | 2 | Combo Faucet | In classroom 221 | FT-112016-009256-A | 2.6 | FT-112016-009256-B | < 1 |
| 4 | BURRVILLE ELEMENTARY SCHOOL | WS- 009254 | 1/25/2017 | 2 | Combo Faucet | In classroom 224 | FT-112016-009254-A | 2.5 | FT-112016-009254-B | < 1 |
| 5 | BURRVILLE ELEMENTARY SCHOOL | WS- 009211 | 1/25/2017 | 1 | Combo Faucet | In classroom 108 | FT-112016-009211-A | 1.1 | FT-112016-009211-B | < 1 |
| 6 | BURRVILLE ELEMENTARY SCHOOL | WS- 009221 | 1/25/2017 | 1 | Combo Faucet | In Pre-K classroom 110 | FT-112016-009221-A | 1.7 | FT-112016-009221-B | < 1 |
| 7 | BURRVILLE ELEMENTARY SCHOOL | WS- 009217 | 1/25/2017 | 1 | Combo Faucet | In classroom 113 | FT-112016-009217-A | 6.5 | FT-112016-009217-B | < 1 |
| 8 | BURRVILLE ELEMENTARY SCHOOL | WS- 009219 | 1/25/2017 | 1 | Combo Faucet | In classroom 115 | FT-112016-009219-A | 1.9 | FT-112016-009219-B | < 1 |
| 9 | BURRVILLE ELEMENTARY SCHOOL | WS- 009223 | 1/25/2017 | 1 | Combo Faucet | In Pre-K classroom 111 | FT-112016-009223-A | 8.8 | FT-112016-009223-B | < 1 |
| 10 | BURRVILLE ELEMENTARY SCHOOL | WS- 009213 | 1/25/2017 | 1 | Combo Faucet | In classroom 114 | FT-112016-009213-A | 1.3 | FT-112016-009213-B | < 1 |
| 11 | BURRVILLE ELEMENTARY SCHOOL | WS- 009244 | 1/25/2017 | 2 | Combo Faucet | In classroom 228 | FT-112016-009244-A | 1.1 | FT-112016-009244-B | < 1 |

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb