



C.H.O.I.C.E ACADEMY @ EMERY LEAD WATER TEST RESULTS May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009565	Kitchen	1	In kitchen north wall	WT-042916-9582- A	< 1	WT-042916-9582- B	< 1				
2 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009566	Kitchen	1	In kitchen south wall Mid	WT-042916-9583- A	2.3	WT-042916-9583- B	< 1				
3 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009567	Cooler	1	In hallway across room 101	WT-042916-9584- A	< 1	WT-042916-9584- B	< 1				
4 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009568	Utility	Basement	In boiler room sink	WT-042916-9585- A	2.1	WT-042916-9585- B	< 1				
5 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009569	Cooler	1	In hallway adjacent to room 110	WT-042916-9586- A	< 1	WT-042916-9586- B	< 1				
6 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009570	Classroom	1	In classroom 112 Right	WT-042916-9587- A	< 1	WT-042916-9587- B	11.4				
7 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009571	Cooler	1	In classroom 112	WT-042916-9588- A	< 1	WT-042916-9588- B	< 1				
8 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009572	Classroom	1	In room 113	WT-042916-9589- A	3.2	WT-042916-9589- B	< 1				
9 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009573	Fountain	1	In room 113	WT-042916-9590- A	< 1	WT-042916-9590- B	< 1				
10 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009574	Cooler	2	In hallway adjacent to room 218	WT-042916-9591- A	< 1	WT-042916-9591- B	< 1				
11 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009575	Cooler	2	In hallway adjacent room 213	WT-042916-9592- A	< 1	WT-042916-9592- B	< 1				
12 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009576	Cooler	2	In hallway adjacent to room 205	WT-042916-9593- A	< 1	WT-042916-9593- B	< 1				
13 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009577	Break Room	2	In staff lounge room 205	WT-042916-9594- A	< 1	WT-042916-9594- B	< 1				
14 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009579	Classroom	3	In room across from stairway 3 Left	WT-042916-9596- A	2.2	WT-042916-9596- B	13.2				
15 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009580	Fountain	3	In classroom 316 Right	WT-042916-9597- A	4	WT-042916-9597- B	2.2				
16 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009581	Cooler	3	In hallway next to stairwell 3	WT-042916-9598- A	< 1	WT-042916-9598- B	< 1				
17 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009582	Classroom	3	In classroom 314	WT-042916-9599- A	90.4	WT-042916-9599- B	3.2	Filter will be installed and then retested			
18 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009583	Fountain	3	In classroom 314	WT-042916-9600- A	10.6	WT-042916-9600- B	8.6				
19 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS-009584	Classroom	3	In room 317 Left	WT-042916-9601- A	< 1	WT-042916-9601- B	< 1				



C.H.O.I.C.E ACADEMY @ EMERY LEAD WATER TEST RESULTS May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
20 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009585	Classroom	3	In room 317 Mid	WT-042916-9602- A	5.1	WT-042916-9602- B	1.3				
21 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009586	Classroom	3	In room 317 Right	WT-042916-9603- A	14.7	WT-042916-9603- B	< 1				
22 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009587	Classroom	3	In classroom 312	WT-042916-9604- A	19.6	WT-042916-9604- B	1.5	Filter will be installed and then retested			
23 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009588	Fountain	3	In classroom 312	WT-042916-9605- A	13.2	WT-042916-9605- B	2.6				
24 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009589	Classroom	3	In classroom 315 Right	WT-042916-9606- A	1.8	WT-042916-9606- B	< 1				
25 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009590	Classroom	3	In classroom 315 Mid	WT-042916-9607- A	1.9	WT-042916-9607- B	< 1				
26 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009591	Classroom	3	In classroom 315 Left	WT-042916-9608- A	< 1	WT-042916-9608- B	< 1				
27 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009592	Cooler	3	In hallway next to room 318	WT-042916-9609- A	< 1	WT-042916-9609- B	< 1				
28 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009593	Classroom	3	In classroom 310	WT-042916-9610- A	3	WT-042916-9610- B	< 1				
29 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009594	Fountain	3	In classroom 310	WT-042916-9611- A	< 1	WT-042916-9611- B	< 1				
30 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009595	Classroom	3	In classroom 308	WT-042916-9612- A	28.2	WT-042916-9612- B	2.3	Filter will be installed and then retested			
31 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009596	Fountain	3	In classroom 308	WT-042916-9613- A	1.9	WT-042916-9613- B	35.1	Filter will be installed and then retested			
32 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009597	Cooler	3	In hallway across room 306	WT-042916-9614- A	< 1	WT-042916-9614- B	< 1				
33 C.H.O.I.C.E. Academy @ Emery ES	5/11/2016	WS- 009598	Cooler	3	In hallway adjacent stairwell 1	WT-042916-9615- A	< 1	WT-042916-9615- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.