



CHEVY CHASE REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	CHEVY CHASE RECREATION CENTER	WS- 012535	9/21/2016	1	Cooler	In hallway adjacent to mechanical room High	FT-82016-012535-A	< 1	FT-82016-012535-B	< 1
2	CHEVY CHASE RECREATION CENTER	WS- 012536	9/21/2016	1	Cooler	In hallway adjacent to mechanical room Low	FT-82016-012536-A	< 1	FT-82016-012536-B	< 1
3	CHEVY CHASE RECREATION CENTER	WS- 012537	9/21/2016	1	Kitchen	In kitchen	FT-82016-012537-A	< 1	FT-82016-012537-B	< 1
4	CHEVY CHASE RECREATION CENTER	WS- 012539	9/21/2016	1	Ice Maker	In kitchen (ice maker)	FT-82016-012539-A	< 1	FT-82016-012539-B	< 1