



COLUMBIA HEIGHTS REC LEAD WATER TEST RESULTS May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 003772	Cooler	4	In hallway adjacent to roof access 413 High	WT-042916-3789- A	< 2	WT-042916-3789- B	< 2				
2	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 003773	Cooler	4	In hallway adjacent to roof access 413 Low	WT-042916-3790- A	< 2	WT-042916-3790- B	< 2				
3	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 003774	Classroom	4	In art room 415	WT-042916-3791- A	< 2	WT-042916-3791- B	< 2				
4	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 003775	Fountain	Ground Floor	In exterior adjacent to basketball court Left	WT-042916-3792- A	< 2	WT-042916-3792- B	< 2				
5	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 003776	Fountain	Ground Floor	In exterior adjacent to basketball court Right	WT-042916-3793- A	< 2	WT-042916-3793- B	< 2				
6	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 003783	Utility	5	(water source)	WT-042916-3800- A	3	WT-042916-3800- B	< 2				
7	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 003784	Kitchen	2	In room 202	WT-042916-3801- A	< 2	WT-042916-3801- B	< 2				
8	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 010070	Cooler	1	In hallway adjacent to room 115 High	WT-042916-10087- A	< 2	WT-042916-10087- B	< 2				
9	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 010071	Cooler	1	In hallway adjacent to room 115 Low	WT-042916-10088- A	< 2	WT-042916-10088- B	< 2				
10	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 010072	Cooler	2	In hallway adjacent to gym High	WT-042916-10089- A	< 2	WT-042916-10089- B	< 2				
11	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 010073	Cooler	2	In hallway adjacent to gym Low	WT-042916-10090- A	< 2	WT-042916-10090- B	< 2				
12	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 010075	Cooler	3	In hallway adjacent to custodian closet 305 High	WT-042916-10092- A	< 2	WT-042916-10092- B	< 2				
13	COLUMBIA HEIGHTS RECREATION CENTER	5/20/2016	WS- 010076	Cooler	3	In hallway adjacent custodian closet 305 Low	WT-042916-10093- A	< 2	WT-042916-10093- B	< 2				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.