



# DC THERAPEUTIC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	DC THERAPEUTIC / TR CENTER	WS- 011546	9/21/2016	1	Cooler	In pool area	FT-82016-011546-A	< 1	FT-82016-011546-B	< 1
2	DC THERAPEUTIC / TR CENTER	WS- 011547	9/21/2016	1	Cooler	In hallway lobby	FT-82016-011547-A	< 1	FT-82016-011547-B	< 1
3	DC THERAPEUTIC / TR CENTER	WS- 011548	9/21/2016	1	Food Prep Sink	In kitchen	FT-82016-011548-A	< 1	FT-82016-011548-B	< 1
4	DC THERAPEUTIC / TR CENTER	WS- 011549	9/21/2016	1	Classroom Faucet	In activity room Left	FT-72016-011549-A	< 1	FT-72016-011549-B	< 1
5	DC THERAPEUTIC / TR CENTER	WS- 011550	9/21/2016	1	Fountain	In activity room Right	FT-82016-011550-A	< 1	FT-82016-011550-B	< 1