



H.D. COOKE LEAD WATER TEST RESULTS

May 12th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd draw
1	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002430	Classroom	2	In classroom 221	WT-042916-2447- A	< 1	WT-042916-2447- B	< 1				
2	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002429	Fountain	2	In classroom 221	WT-042916-2446- A	< 1	WT-042916-2446- B	< 1				
3	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002417	Fountain	3	In classroom 310	WT-042916-2434- A	< 1	WT-042916-2434- B	< 1				
4	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002416	Break Room	3	In staff lounge 319	WT-042916-2433- A	< 1	WT-042916-2433- B	< 1				
5	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002414	Fountain	3	In classroom 305	WT-042916-2431- A	< 1	WT-042916-2431- B	< 1				
6	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002412	Fountain	3	In classroom 304	WT-042916-2429- A	< 1	WT-042916-2429- B	< 1				
7	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002411	Fountain	3	In classroom 302	WT-042916-2428- A	< 1	WT-042916-2428- B	< 1				
8	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002410	Classroom	3	In classroom 302	WT-042916-2427- A	< 1	WT-042916-2427- B	< 1				
9	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002409	Classroom	3	In classroom 303	WT-042916-2426- A	< 1	WT-042916-2426- B	< 1				
10	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002408	Fountain	3	In classroom 303	WT-042916-2425- A	< 1	WT-042916-2425- B	< 1				
11	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002407	Cooler	3	In hallway across from classroom 304	Low WT-042916-2424- A	< 1	WT-042916-2424- B	< 1				
12	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002406	Cooler	3	In hallway across from classroom 304	High WT-042916-2423- A	< 1	WT-042916-2423- B	< 1				
13	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002405	Classroom	2	In classroom 234	WT-042916-2422- A	< 1	WT-042916-2422- B	< 1				
14	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002404	Fountain	2	In classroom 234	WT-042916-2421- A	< 1	WT-042916-2421- B	< 1				
15	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002403	Classroom	2	In classroom 232	WT-042916-2420- A	< 1	WT-042916-2420- B	< 1				
16	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002402	Fountain	2	In classroom 232	WT-042916-2419- A	< 1	WT-042916-2419- B	< 1				
17	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002401	Classroom	2	In classroom 235	WT-042916-2418- A	< 1	WT-042916-2418- B	< 1				
18	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002400	Fountain	2	In classroom 235	WT-042916-2417- A	< 1	WT-042916-2417- B	< 1				
19	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002399	Classroom	2	In classroom 231	WT-042916-2416- A	< 1	WT-042916-2416- B	< 1				
20	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002398	Fountain	2	In classroom 231	WT-042916-2415- A	< 1	WT-042916-2415- B	< 1				
21	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002397	Classroom	2	In resource room 236	WT-042916-2414- A	< 1	WT-042916-2414- B	< 1				
22	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002396	Fountain	2	In resource room 236	WT-042916-2413- A	< 1	WT-042916-2413- B	< 1				
23	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002394	Fountain	2	In resource room 230	WT-042916-2411- A	< 1	WT-042916-2411- B	< 1				
24	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002390	Fountain	2	In classroom 213	WT-042916-2407- A	< 1	WT-042916-2407- B	< 1				
25	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002388	Fountain	2	In classroom 212	WT-042916-2405- A	< 1	WT-042916-2405- B	< 1				
26	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002387	Classroom	2	In classroom 211	WT-042916-2404- A	1	WT-042916-2404- B	< 1				
27	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002386	Fountain	2	In classroom 211	WT-042916-2403- A	< 1	WT-042916-2403- B	< 1				
28	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002385	Classroom	2	In classroom 210	WT-042916-2402- A	< 1	WT-042916-2402- B	< 1				



H.D. COOKE LEAD WATER TEST RESULTS

May 12th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd draw
29	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002384	Fountain	2	In classroom 210	WT-042916-2401- A	< 1	WT-042916-2401- B	< 1				
30	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002382	Fountain	2	In classroom 203	WT-042916-2399- A	< 1	WT-042916-2399- B	< 1				
31	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002380	Fountain	2	In classroom 202	WT-042916-2397- A	< 1	WT-042916-2397- B	< 1				
32	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002378	Fountain	2	In classroom 204	WT-042916-2395- A	< 1	WT-042916-2395- B	< 1				
33	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002377	Classroom	2	In classroom 205	WT-042916-2394- A	< 1	WT-042916-2394- B	< 1				
34	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002376	Fountain	2	In classroom 205	WT-042916-2393- A	< 1	WT-042916-2393- B	< 1				
35	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002375	Cooler	2	In hallway across from classroom 204	Low	WT-042916-2392- A	< 1	WT-042916-2392- B	< 1			
36	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002374	Cooler	2	In hallway across from classroom 204	High	WT-042916-2391- A	< 1	WT-042916-2391- B	< 1			
37	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002373	Classroom	1	In art room 111 across from 111A storage	WT-042916-2390- A	< 1	WT-042916-2390- B	< 1				
38	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002370	Break Room	Ground Floor	In break room 110	WT-042916-2387- A	< 1	WT-042916-2387- B	< 1				
39	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002368	Health Suite	1	In health suite exam room 103E (sink)	WT-042916-2385- A	< 1	WT-042916-2385- B	1				
40	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002367	Cooler	1	In hallway across from room 105 (student services)	Low	WT-042916-2384- A	< 1	WT-042916-2384- B	< 1			
41	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002365	Kitchen	1	In kitchen near dry storage 144E	WT-042916-2382- A	< 1	WT-042916-2382- B	< 1				
42	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002364	Kitchen	1	In kitchen near storage 144C	Right	WT-042916-2381- A	< 1	WT-042916-2381- B	< 1			
43	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002363	Kitchen	1	In kitchen near storage 144C	Left	WT-042916-2380- A	< 1	WT-042916-2380- B	< 1			
44	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002362	Other	1	In kitchen (spray nozzle)	WT-042916-2379- A	< 1	WT-042916-2379- B	< 1				
45	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002361	Classroom	1	In classroom 135	WT-042916-2378- A	< 1	WT-042916-2378- B	< 1				
46	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002360	Fountain	1	In classroom 135	WT-042916-2377- A	< 1	WT-042916-2377- B	< 1				
47	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002359	Classroom	1	In classroom 133	WT-042916-2376- A	< 1	WT-042916-2376- B	< 1				
48	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002358	Fountain	1	In classroom 133	WT-042916-2375- A	< 1	WT-042916-2375- B	< 1				
49	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002357	Classroom	1	In classroom 136	WT-042916-2374- A	< 1	WT-042916-2374- B	< 1				
50	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002356	Fountain	1	In classroom 136	WT-042916-2373- A	< 1	WT-042916-2373- B	< 1				
51	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002355	Classroom	1	In classroom 132	WT-042916-2372- A	1	WT-042916-2372- B	< 1				
52	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002354	Fountain	1	In classroom 132	WT-042916-2371- A	< 1	WT-042916-2371- B	< 1				
53	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002353	Break Room	1	In staff lounge 137	WT-042916-2370- A	< 1	WT-042916-2370- B	< 1				
54	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002351	Cooler	1	In gymnasium 142	Low	WT-042916-2368- A	< 1	WT-042916-2368- B	< 1			
55	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002350	Classroom	1	In gymnasium	High	WT-042916-2367- A	< 1	WT-042916-2367- B	< 1			
56	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002422	Classroom	3	In classroom 312	WT-042916-2439- A	1.1	WT-042916-2439- B	< 1				



H.D. COOKE LEAD WATER TEST RESULTS

May 12th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd draw
57	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002372	Classroom	1	In art room 111 Right	WT-042916-2389- A	1.3	WT-042916-2389- B	< 1				
58	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002415	Classroom	3	In classroom 305	WT-042916-2432- A	1.4	WT-042916-2432- B	< 1				
59	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002366	Cooler	1	In hallway across from room 105 (student services) Left High	WT-042916-2383- A	1.4	WT-042916-2383- B	1.3				
60	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002421	Fountain	3	In classroom 312	WT-042916-2438- A	1.6	WT-042916-2438- B	< 1				
61	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002419	Fountain	3	In classroom 311	WT-042916-2436- A	1.6	WT-042916-2436- B	< 1				
62	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002381	Classroom	2	In room 202	WT-042916-2398- A	1.6	WT-042916-2398- B	< 1				
63	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002371	Classroom	1	In art room 111 Left	WT-042916-2388- A	1.8	WT-042916-2388- B	< 1				
64	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002379	Classroom	2	In classroom 204	WT-042916-2396- A	2.2	WT-042916-2396- B	< 1				
65	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002395	Classroom	2	In resource room 230	WT-042916-2412- A	2.3	WT-042916-2412- B	< 1				
66	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002413	Classroom	3	In classroom 304	WT-042916-2430- A	2.7	WT-042916-2430- B	< 1				
67	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002424	Classroom	3	In classroom 313	WT-042916-2441- A	3.1	WT-042916-2441- B	< 1				
68	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002393	Classroom	2	In resource room 241	WT-042916-2410- A	3.3	WT-042916-2410- B	< 1				
69	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002383	Classroom	2	In classroom 203	WT-042916-2400- A	3.3	WT-042916-2400- B	< 1				
70	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002392	Fountain	2	In resource room 241	WT-042916-2409- A	3.8	WT-042916-2409- B	< 1				
71	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002389	Classroom	2	In classroom 212	WT-042916-2406- A	4	WT-042916-2406- B	< 1				
72	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002425	Fountain	3	In classroom 314	WT-042916-2442- A	5.8	WT-042916-2442- B	308	Filtered	6/14/2016	<1	<1
73	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002391	Classroom	2	In classroom 213	WT-042916-2408- A	7.1	WT-042916-2408- B	< 1				
74	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002420	Classroom	3	In classroom 311	WT-042916-2437- A	7.6	WT-042916-2437- B	< 1				
75	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002352	Break Room	1	In work Room 130	WT-042916-2369- A	9.5	WT-042916-2369- B	30.3	Filtered	6/14/2016	<1	<1
76	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002369	Health Suite	1	In health suite exam room 103C (sink)	WT-042916-2386- A	13.3	WT-042916-2386- B	< 1				
77	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002423	Fountain	3	In classroom 313	WT-042916-2440- A	20.5	WT-042916-2440- B	9.9	Filtered	6/14/2016	<1	<1
78	H.D. COOKE ELEMENTARY SCHOOL	5/4/2016	WS- 002349	Utility	1	In boiler room	WT-042916-2366- A	34.1	WT-042916-2366- B	6.5	Not accessible to children			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.