



# H.D. COOKE LEAD WATER TEST RESULTS

May 12th, 2016



|    | Building Location            | Sample Collected Date | Water Source ID | Device Type | Floor | Device Location                      | 1st Draw - Sample ID      | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date | Retest Results |
|----|------------------------------|-----------------------|-----------------|-------------|-------|--------------------------------------|---------------------------|--------------------------------|----------------------|--------------------------------|-------------|-------------|----------------|
| 1  | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002430      | Classroom   | 2     | In classroom 221                     | WT-042916-2447- A         | < 1                            | WT-042916-2447- B    | < 1                            |             |             |                |
| 2  | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002429      | Fountain    | 2     | In classroom 221                     | WT-042916-2446- A         | < 1                            | WT-042916-2446- B    | < 1                            |             |             |                |
| 3  | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002417      | Fountain    | 3     | In classroom 310                     | WT-042916-2434- A         | < 1                            | WT-042916-2434- B    | < 1                            |             |             |                |
| 4  | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002416      | Break Room  | 3     | In staff lounge 319                  | WT-042916-2433- A         | < 1                            | WT-042916-2433- B    | < 1                            |             |             |                |
| 5  | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002414      | Fountain    | 3     | In classroom 305                     | WT-042916-2431- A         | < 1                            | WT-042916-2431- B    | < 1                            |             |             |                |
| 6  | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002412      | Fountain    | 3     | In classroom 304                     | WT-042916-2429- A         | < 1                            | WT-042916-2429- B    | < 1                            |             |             |                |
| 7  | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002411      | Fountain    | 3     | In classroom 302                     | WT-042916-2428- A         | < 1                            | WT-042916-2428- B    | < 1                            |             |             |                |
| 8  | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002410      | Classroom   | 3     | In classroom 302                     | WT-042916-2427- A         | < 1                            | WT-042916-2427- B    | < 1                            |             |             |                |
| 9  | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002409      | Classroom   | 3     | In classroom 303                     | WT-042916-2426- A         | < 1                            | WT-042916-2426- B    | < 1                            |             |             |                |
| 10 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002408      | Fountain    | 3     | In classroom 303                     | WT-042916-2425- A         | < 1                            | WT-042916-2425- B    | < 1                            |             |             |                |
| 11 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002407      | Cooler      | 3     | In hallway across from classroom 304 | Low<br>WT-042916-2424- A  | < 1                            | WT-042916-2424- B    | < 1                            |             |             |                |
| 12 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002406      | Cooler      | 3     | In hallway across from classroom 304 | High<br>WT-042916-2423- A | < 1                            | WT-042916-2423- B    | < 1                            |             |             |                |
| 13 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002405      | Classroom   | 2     | In classroom 234                     | WT-042916-2422- A         | < 1                            | WT-042916-2422- B    | < 1                            |             |             |                |
| 14 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002404      | Fountain    | 2     | In classroom 234                     | WT-042916-2421- A         | < 1                            | WT-042916-2421- B    | < 1                            |             |             |                |
| 15 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002403      | Classroom   | 2     | In classroom 232                     | WT-042916-2420- A         | < 1                            | WT-042916-2420- B    | < 1                            |             |             |                |
| 16 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002402      | Fountain    | 2     | In classroom 232                     | WT-042916-2419- A         | < 1                            | WT-042916-2419- B    | < 1                            |             |             |                |
| 17 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002401      | Classroom   | 2     | In classroom 235                     | WT-042916-2418- A         | < 1                            | WT-042916-2418- B    | < 1                            |             |             |                |
| 18 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002400      | Fountain    | 2     | In classroom 235                     | WT-042916-2417- A         | < 1                            | WT-042916-2417- B    | < 1                            |             |             |                |
| 19 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002399      | Classroom   | 2     | In classroom 231                     | WT-042916-2416- A         | < 1                            | WT-042916-2416- B    | < 1                            |             |             |                |
| 20 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002398      | Fountain    | 2     | In classroom 231                     | WT-042916-2415- A         | < 1                            | WT-042916-2415- B    | < 1                            |             |             |                |
| 21 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002397      | Classroom   | 2     | In resource room 236                 | WT-042916-2414- A         | < 1                            | WT-042916-2414- B    | < 1                            |             |             |                |
| 22 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002396      | Fountain    | 2     | In resource room 236                 | WT-042916-2413- A         | < 1                            | WT-042916-2413- B    | < 1                            |             |             |                |
| 23 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002394      | Fountain    | 2     | In resource room 230                 | WT-042916-2411- A         | < 1                            | WT-042916-2411- B    | < 1                            |             |             |                |
| 24 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002390      | Fountain    | 2     | In classroom 213                     | WT-042916-2407- A         | < 1                            | WT-042916-2407- B    | < 1                            |             |             |                |
| 25 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002388      | Fountain    | 2     | In classroom 212                     | WT-042916-2405- A         | < 1                            | WT-042916-2405- B    | < 1                            |             |             |                |
| 26 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002387      | Classroom   | 2     | In classroom 211                     | WT-042916-2404- A         | 1                              | WT-042916-2404- B    | < 1                            |             |             |                |
| 27 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002386      | Fountain    | 2     | In classroom 211                     | WT-042916-2403- A         | < 1                            | WT-042916-2403- B    | < 1                            |             |             |                |



# H.D. COOKE LEAD WATER TEST RESULTS

May 12th, 2016



|    | Building Location            | Sample Collected Date | Water Source ID | Device Type  | Floor        | Device Location                                    | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date | Retest Results |
|----|------------------------------|-----------------------|-----------------|--------------|--------------|--|----------------------|--------------------------------|----------------------|--------------------------------|-------------|-------------|----------------|
| 28 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002385      | Classroom    | 2            | In classroom 210                                   | WT-042916-2402- A    | < 1                            | WT-042916-2402- B    | < 1                            |             |             |                |
| 29 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002384      | Fountain     | 2            | In classroom 210                                   | WT-042916-2401- A    | < 1                            | WT-042916-2401- B    | < 1                            |             |             |                |
| 30 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002382      | Fountain     | 2            | In classroom 203                                   | WT-042916-2399- A    | < 1                            | WT-042916-2399- B    | < 1                            |             |             |                |
| 31 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002380      | Fountain     | 2            | In classroom 202                                   | WT-042916-2397- A    | < 1                            | WT-042916-2397- B    | < 1                            |             |             |                |
| 32 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002378      | Fountain     | 2            | In classroom 204                                   | WT-042916-2395- A    | < 1                            | WT-042916-2395- B    | < 1                            |             |             |                |
| 33 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002377      | Classroom    | 2            | In classroom 205                                   | WT-042916-2394- A    | < 1                            | WT-042916-2394- B    | < 1                            |             |             |                |
| 34 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002376      | Fountain     | 2            | In classroom 205                                   | WT-042916-2393- A    | < 1                            | WT-042916-2393- B    | < 1                            |             |             |                |
| 35 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002375      | Cooler       | 2            | In hallway across from classroom 204               | Low                  | WT-042916-2392- A              | < 1                  | WT-042916-2392- B              | < 1         |             |                |
| 36 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002374      | Cooler       | 2            | In hallway across from classroom 204               | High                 | WT-042916-2391- A              | < 1                  | WT-042916-2391- B              | < 1         |             |                |
| 37 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002373      | Classroom    | 1            | In art room 111 across from 111A storage           | WT-042916-2390- A    | < 1                            | WT-042916-2390- B    | < 1                            |             |             |                |
| 38 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002370      | Break Room   | Ground Floor | In break room 110                                  | WT-042916-2387- A    | < 1                            | WT-042916-2387- B    | < 1                            |             |             |                |
| 39 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002368      | Health Suite | 1            | In health suite exam room 103E (sink)              | WT-042916-2385- A    | < 1                            | WT-042916-2385- B    | 1                              |             |             |                |
| 40 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002367      | Cooler       | 1            | In hallway across from room 105 (student services) | Low                  | WT-042916-2384- A              | < 1                  | WT-042916-2384- B              | < 1         |             |                |
| 41 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002365      | Kitchen      | 1            | In kitchen near dry storage 144E                   | WT-042916-2382- A    | < 1                            | WT-042916-2382- B    | < 1                            |             |             |                |
| 42 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002364      | Kitchen      | 1            | In kitchen near storage 144C                       | Right                | WT-042916-2381- A              | < 1                  | WT-042916-2381- B              | < 1         |             |                |
| 43 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002363      | Kitchen      | 1            | In kitchen near storage 144C                       | Left                 | WT-042916-2380- A              | < 1                  | WT-042916-2380- B              | < 1         |             |                |
| 44 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002362      | Other        | 1            | In kitchen (spray nozzle)                          | WT-042916-2379- A    | < 1                            | WT-042916-2379- B    | < 1                            |             |             |                |
| 45 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002361      | Classroom    | 1            | In classroom 135                                   | WT-042916-2378- A    | < 1                            | WT-042916-2378- B    | < 1                            |             |             |                |
| 46 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002360      | Fountain     | 1            | In classroom 135                                   | WT-042916-2377- A    | < 1                            | WT-042916-2377- B    | < 1                            |             |             |                |
| 47 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002359      | Classroom    | 1            | In classroom 133                                   | WT-042916-2376- A    | < 1                            | WT-042916-2376- B    | < 1                            |             |             |                |
| 48 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002358      | Fountain     | 1            | In classroom 133                                   | WT-042916-2375- A    | < 1                            | WT-042916-2375- B    | < 1                            |             |             |                |
| 49 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002357      | Classroom    | 1            | In classroom 136                                   | WT-042916-2374- A    | < 1                            | WT-042916-2374- B    | < 1                            |             |             |                |
| 50 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002356      | Fountain     | 1            | In classroom 136                                   | WT-042916-2373- A    | < 1                            | WT-042916-2373- B    | < 1                            |             |             |                |
| 51 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002355      | Classroom    | 1            | In classroom 132                                   | WT-042916-2372- A    | 1                              | WT-042916-2372- B    | < 1                            |             |             |                |
| 52 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002354      | Fountain     | 1            | In classroom 132                                   | WT-042916-2371- A    | < 1                            | WT-042916-2371- B    | < 1                            |             |             |                |
| 53 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002353      | Break Room   | 1            | In staff lounge 137                                | WT-042916-2370- A    | < 1                            | WT-042916-2370- B    | < 1                            |             |             |                |
| 54 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002351      | Cooler       | 1            | In gymnasium 142                                   | Low                  | WT-042916-2368- A              | < 1                  | WT-042916-2368- B              | < 1         |             |                |



# H.D. COOKE LEAD WATER TEST RESULTS

May 12th, 2016



|    | Building Location            | Sample Collected Date | Water Source ID | Device Type  | Floor | Device Location  | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation  | Retest Date | Retest Results |
|----|------------------------------|-----------------------|-----------------|--------------|-------|--|----------------------|--------------------------------|----------------------|--------------------------------|--|-------------|----------------|
| 55 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002350      | Classroom    | 1     | In gymnasium High  | WT-042916-2367- A    | < 1                            | WT-042916-2367- B    | < 1                            |  |             |                |
| 56 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002422      | Classroom    | 3     | In classroom 312   | WT-042916-2439- A    | 1.1                            | WT-042916-2439- B    | < 1                            |  |             |                |
| 57 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002372      | Classroom    | 1     | In art room 111 Right  | WT-042916-2389- A    | 1.3                            | WT-042916-2389- B    | < 1                            |  |             |                |
| 58 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002415      | Classroom    | 3     | In classroom 305   | WT-042916-2432- A    | 1.4                            | WT-042916-2432- B    | < 1                            |  |             |                |
| 59 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002366      | Cooler       | 1     | In hallway across from room 105 (student services) Left High | WT-042916-2383- A    | 1.4                            | WT-042916-2383- B    | 1.3                            |  |             |                |
| 60 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002421      | Fountain     | 3     | In classroom 312   | WT-042916-2438- A    | 1.6                            | WT-042916-2438- B    | < 1                            |  |             |                |
| 61 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002419      | Fountain     | 3     | In classroom 311   | WT-042916-2436- A    | 1.6                            | WT-042916-2436- B    | < 1                            |  |             |                |
| 62 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002381      | Classroom    | 2     | In room 202  | WT-042916-2398- A    | 1.6                            | WT-042916-2398- B    | < 1                            |  |             |                |
| 63 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002371      | Classroom    | 1     | In art room 111 Left   | WT-042916-2388- A    | 1.8                            | WT-042916-2388- B    | < 1                            |  |             |                |
| 64 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002379      | Classroom    | 2     | In classroom 204   | WT-042916-2396- A    | 2.2                            | WT-042916-2396- B    | < 1                            |  |             |                |
| 65 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002395      | Classroom    | 2     | In resource room 230   | WT-042916-2412- A    | 2.3                            | WT-042916-2412- B    | < 1                            |  |             |                |
| 66 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002413      | Classroom    | 3     | In classroom 304   | WT-042916-2430- A    | 2.7                            | WT-042916-2430- B    | < 1                            |  |             |                |
| 67 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002424      | Classroom    | 3     | In classroom 313   | WT-042916-2441- A    | 3.1                            | WT-042916-2441- B    | < 1                            |  |             |                |
| 68 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002393      | Classroom    | 2     | In resource room 241   | WT-042916-2410- A    | 3.3                            | WT-042916-2410- B    | < 1                            |  |             |                |
| 69 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002383      | Classroom    | 2     | In classroom 203   | WT-042916-2400- A    | 3.3                            | WT-042916-2400- B    | < 1                            |  |             |                |
| 70 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002392      | Fountain     | 2     | In resource room 241   | WT-042916-2409- A    | 3.8                            | WT-042916-2409- B    | < 1                            |  |             |                |
| 71 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002389      | Classroom    | 2     | In classroom 212   | WT-042916-2406- A    | 4                              | WT-042916-2406- B    | < 1                            |  |             |                |
| 72 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002425      | Fountain     | 3     | In classroom 314   | WT-042916-2442- A    | 5.8                            | WT-042916-2442- B    | 30.8                           | Filter will be installed and then retested                       |             |                |
| 73 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002391      | Classroom    | 2     | In classroom 213   | WT-042916-2408- A    | 7.1                            | WT-042916-2408- B    | < 1                            |  |             |                |
| 74 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002420      | Classroom    | 3     | In classroom 311   | WT-042916-2437- A    | 7.6                            | WT-042916-2437- B    | < 1                            |  |             |                |
| 75 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002352      | Break Room   | 1     | In work Room 130   | WT-042916-2369- A    | 9.5                            | WT-042916-2369- B    | 30.3                           | Filter will be installed and then retested                       |             |                |
| 76 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002369      | Health Suite | 1     | In health suite exam room 103C (sink)                        | WT-042916-2386- A    | 13.3                           | WT-042916-2386- B    | < 1                            |  |             |                |
| 77 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002423      | Fountain     | 3     | In classroom 313   | WT-042916-2440- A    | 20.5                           | WT-042916-2440- B    | 9.9                            | Filter will be installed and then retested                       |             |                |
| 78 | H.D. COOKE ELEMENTARY SCHOOL | 5/4/2016              | WS- 002349      | Utility      | 1     | In boiler room   | WT-042916-2366- A    | 34.1                           | WT-042916-2366- B    | 6.5                            | Non-drinking water source - Not accessible to children (boilers) |             |                |



# H.D. COOKE LEAD WATER TEST RESULTS

May 12th, 2016



| Building Location | Sample Collected Date | Water Source ID | Device Type | Floor | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date | Retest Results |
|-------------------|-----------------------|-----------------|-------------|-------|-----------------|----------------------|--------------------------------|----------------------|--------------------------------|-------------|-------------|----------------|
|-------------------|-----------------------|-----------------|-------------|-------|-----------------|----------------------|--------------------------------|----------------------|--------------------------------|-------------|-------------|----------------|

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.