



# HOUSTON ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	HOUSTON ELEMENTARY SCHOOL	WS- 009341	8/20/2016	1	Cooler	In multi-purpose room	FT-82016-009341-A	< 1	FT-82016-009341-B	< 1
2	HOUSTON ELEMENTARY SCHOOL	WS- 009343	8/20/2016	1	Food Prep Sink	In kitchen Right	FT-82016-009343-A	< 1	FT-82016-009343-B	< 1
3	HOUSTON ELEMENTARY SCHOOL	WS- 009345	8/20/2016	1	Cooler	In hallway across from staff lounge	FT-82016-009345-A	< 1	FT-82016-009345-B	< 1
4	HOUSTON ELEMENTARY SCHOOL	WS- 009346	8/20/2016	1	Cooler	In staff lounge	FT-82016-009346-A	< 1	FT-82016-009346-B	< 1
5	HOUSTON ELEMENTARY SCHOOL	WS- 009351	8/20/2016	1	Cooler	In classroom 147	FT-82016-009351-A	< 1	FT-82016-009351-B	< 1
6	HOUSTON ELEMENTARY SCHOOL	WS- 009353	8/20/2016	1	Fountain	In classroom 148	FT-82016-009353-A	< 1	FT-82016-009353-B	< 1
7	HOUSTON ELEMENTARY SCHOOL	WS- 009355	8/20/2016	1	Cooler	In hallway adjacent to room 156	FT-82016-009355-A	< 1	FT-82016-009355-B	< 1
8	HOUSTON ELEMENTARY SCHOOL	WS- 009356	8/20/2016	1	Cooler	In hallway adjacent to girls' restroom	FT-82016-009356-A	< 1	FT-82016-009356-B	< 1
9	HOUSTON ELEMENTARY SCHOOL	WS- 009658	8/20/2016	1	Health Suite	In restroom in health suite	FT-82016-009658-A	< 1	FT-82016-009658-B	< 1
10	HOUSTON ELEMENTARY SCHOOL	WS- 009659	8/20/2016	1	Cooler	In hallway adjacent to room 112	FT-82016-009659-A	< 1	FT-82016-009659-B	< 1
11	HOUSTON ELEMENTARY SCHOOL	WS- 009660	8/20/2016	2	Cooler	In hallway adjacent to room 212	FT-82016-009660-A	< 1	FT-82016-009660-B	< 1
12	HOUSTON ELEMENTARY SCHOOL	WS- 009661	8/20/2016	2	Cooler	In hallway adjacent to girls' restroom	FT-82016-009661-A	< 1	FT-82016-009661-B	< 1
13	HOUSTON ELEMENTARY SCHOOL	WS- 009663	8/20/2016	1	Classroom Faucet	In classroom 114	FT-72016-009663-A	< 1	FT-72016-009663-B	< 1
14	HOUSTON ELEMENTARY SCHOOL	WS- 009665	8/20/2016	Ground Floor	Cooler	Exterior, adjacent to basketball court Low Right	FT-82016-009665-A	< 1	FT-82016-009665-B	< 1
15	HOUSTON ELEMENTARY SCHOOL	WS- 009666	8/20/2016	Ground Floor	Cooler	Exterior, adjacent to basketball court High Left	FT-82016-009666-A	< 1	FT-82016-009666-B	< 1
16	HOUSTON ELEMENTARY SCHOOL	WS- 009667	8/20/2016	Ground Floor	Cooler	Exterior, adjacent to basketball court Low Right	FT-82016-009667-A	< 1	FT-82016-009667-B	< 1