



JANNEY ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)		
1	JANNEY ELEMENTARY SCHOOL	WS- 002200	8/19/2016	Basement	Fountain	In science lab room fourth clockwise from entry door	FT-82016-002200-A	< 1	FT-82016-002200-B	< 1		
2	JANNEY ELEMENTARY SCHOOL	WS- 002203	8/19/2016	Basement	Fountain	In science lab room third clockwise from entry door	FT-82016-002203-A	< 1	FT-82016-002203-B	< 1		
3	JANNEY ELEMENTARY SCHOOL	WS- 002205	8/19/2016	Basement	Fountain	In science lab room second clockwise from entry door	FT-82016-002205-A	< 1	FT-82016-002205-B	< 1		
4	JANNEY ELEMENTARY SCHOOL	WS- 002207	8/19/2016	Basement	Fountain	In classroom L11	FT-82016-002207-A	< 1	FT-82016-002207-B	< 1		
5	JANNEY ELEMENTARY SCHOOL	WS- 002209	8/19/2016	Basement	Cooler	In hallway adjacent to girls' restroom	FT-82016-002209-A	< 1	FT-82016-002209-B	< 1		
6	JANNEY ELEMENTARY SCHOOL	WS- 002210	8/19/2016	1	Fountain	In classroom 117	Right	FT-82016-002210-A	< 1	FT-82016-002210-B	< 1	
7	JANNEY ELEMENTARY SCHOOL	WS- 002211	8/19/2016	Basement	Fountain	In science lab room first clockwise from entry door	Left	FT-82016-002211-A	< 1	FT-82016-002211-B	< 1	
8	JANNEY ELEMENTARY SCHOOL	WS- 002213	8/19/2016	1	Fountain	In classroom 115	Right	FT-82016-002213-A	< 1	FT-82016-002213-B	< 1	
9	JANNEY ELEMENTARY SCHOOL	WS- 002215	8/19/2016	1	Cooler	In hallway adjacent to room 113	Low	Right	FT-82016-002215-A	< 1	FT-82016-002215-B	< 1
10	JANNEY ELEMENTARY SCHOOL	WS- 002216	8/19/2016	1	Cooler	In hallway adjacent to room 113	High	Left	FT-82016-002216-A	< 1	FT-82016-002216-B	< 1
11	JANNEY ELEMENTARY SCHOOL	WS- 002218	8/19/2016	1	Fountain	In classroom 113	Right	FT-82016-002218-A	< 1	FT-82016-002218-B	< 1	
12	JANNEY ELEMENTARY SCHOOL	WS- 002219	8/19/2016	1	Fountain	In classroom 110	Left	FT-82016-002219-A	< 1	FT-82016-002219-B	< 1	
13	JANNEY ELEMENTARY SCHOOL	WS- 002221	8/19/2016	1	Fountain	In classroom 112	Left	FT-82016-002221-A	< 1	FT-82016-002221-B	< 1	
14	JANNEY ELEMENTARY SCHOOL	WS- 002223	8/19/2016	1	Fountain	In classroom 110	Right	FT-82016-002223-A	< 1	FT-82016-002223-B	< 1	
15	JANNEY ELEMENTARY SCHOOL	WS- 002225	8/19/2016	1	Cooler	In hallway adjacent to room 110	Right	FT-82016-002225-A	< 1	FT-82016-002225-B	< 1	
16	JANNEY ELEMENTARY SCHOOL	WS- 002226	8/19/2016	1	Fountain	In classroom 108	Right	FT-82016-002226-A	< 1	FT-82016-002226-B	< 1	
17	JANNEY ELEMENTARY SCHOOL	WS- 002228	8/19/2016	1	Fountain	In classroom 109	Right	FT-82016-002228-A	< 1	FT-82016-002228-B	< 1	
18	JANNEY ELEMENTARY SCHOOL	WS- 002230	8/19/2016	1	Fountain	In classroom 106	Right	FT-82016-002230-A	< 1	FT-82016-002230-B	< 1	
19	JANNEY ELEMENTARY SCHOOL	WS- 002232	8/19/2016	1	Fountain	In classroom 107	Right	FT-82016-002232-A	< 1	FT-82016-002232-B	< 1	
20	JANNEY ELEMENTARY SCHOOL	WS- 002234	8/19/2016	1	Cooler	In hallway adjacent to room 107	Right	FT-82016-002234-A	< 1	FT-82016-002234-B	< 1	
21	JANNEY ELEMENTARY SCHOOL	WS- 002235	8/19/2016	1	Health Suite	In health suite	Right	FT-82016-002235-A	< 1	FT-82016-002235-B	< 1	
22	JANNEY ELEMENTARY SCHOOL	WS- 002236	8/19/2016	1	Health Suite	In health suite adjacent to restroom	Left	FT-82016-002236-A	< 1	FT-82016-002236-B	< 1	
23	JANNEY ELEMENTARY SCHOOL	WS- 002237	8/19/2016	1	Health Suite	In health suite adjacent to restroom	Right	FT-82016-002237-A	< 1	FT-82016-002237-B	< 1	
24	JANNEY ELEMENTARY SCHOOL	WS- 002238	8/19/2016	1	Cooler	In hallway adjacent to the health suite	Right	FT-82016-002238-A	< 1	FT-82016-002238-B	< 1	
25	JANNEY ELEMENTARY SCHOOL	WS- 002239	8/19/2016	1	Food Prep Sink	In kitchen	Right	FT-72016-002239-A	< 1	FT-72016-002239-B	< 1	
26	JANNEY ELEMENTARY SCHOOL	WS- 002242	8/19/2016	2	Fountain	In classroom 200	Right	FT-82016-002242-A	< 1	FT-82016-002242-B	< 1	
27	JANNEY ELEMENTARY SCHOOL	WS- 002243	8/19/2016	2	Fountain	In classroom 201	Right	FT-82016-002243-A	< 1	FT-82016-002243-B	< 1	
28	JANNEY ELEMENTARY SCHOOL	WS- 002245	8/19/2016	2	Cooler	In hallway adjacent to room 202	Right	FT-82016-002245-A	< 1	FT-82016-002245-B	< 1	
29	JANNEY ELEMENTARY SCHOOL	WS- 002247	8/19/2016	2	Fountain	In classroom 202	Right	FT-82016-002247-A	< 1	FT-82016-002247-B	< 1	
30	JANNEY ELEMENTARY SCHOOL	WS- 002249	8/19/2016	2	Fountain	In classroom 203	Right	FT-82016-002249-A	< 1	FT-82016-002249-B	< 1	
31	JANNEY ELEMENTARY SCHOOL	WS- 002250	8/19/2016	2	Cooler	In hallway adjacent to room 207	Right	FT-82016-002250-A	< 1	FT-82016-002250-B	< 1	
32	JANNEY ELEMENTARY SCHOOL	WS- 002252	8/19/2016	2	Fountain	In classroom 206	Right	FT-82016-002252-A	< 1	FT-82016-002252-B	< 1	
33	JANNEY ELEMENTARY SCHOOL	WS- 002254	8/19/2016	2	Classroom Faucet	In classroom 207	Right	FT-82016-002254-A	< 1	FT-82016-002254-B	< 1	
34	JANNEY ELEMENTARY SCHOOL	WS- 002256	8/19/2016	2	Fountain	In classroom 208	Right	FT-82016-002256-A	< 1	FT-82016-002256-B	< 1	
35	JANNEY ELEMENTARY SCHOOL	WS- 002258	8/19/2016	2	Fountain	In classroom 209	Right	FT-82016-002258-A	< 1	FT-82016-002258-B	< 1	
36	JANNEY ELEMENTARY SCHOOL	WS- 002260	8/19/2016	2	Fountain	In classroom 210A	Left	FT-82016-002260-A	< 1	FT-82016-002260-B	< 1	
37	JANNEY ELEMENTARY SCHOOL	WS- 002261	8/19/2016	2	Cooler	In hallway adjacent to room 210	Right	FT-82016-002261-A	< 1	FT-82016-002261-B	< 1	
38	JANNEY ELEMENTARY SCHOOL	WS- 002262	8/19/2016	2	Fountain	In staff lounge 212	Left	FT-82016-002262-A	< 1	FT-82016-002262-B	< 1	
39	JANNEY ELEMENTARY SCHOOL	WS- 002265	8/19/2016	2	Fountain	In classroom 213	Right	FT-82016-002265-A	< 1	FT-82016-002265-B	< 1	
40	JANNEY ELEMENTARY SCHOOL	WS- 002266	8/19/2016	2	Break Room	In office room 212A in room 212	Right	FT-72016-002266-A	< 1	FT-72016-002266-B	< 1	
41	JANNEY ELEMENTARY SCHOOL	WS- 002267	8/19/2016	3	Cooler	In hallway adjacent to room 316	Low	Right	FT-82016-002267-A	< 1	FT-82016-002267-B	< 1
42	JANNEY ELEMENTARY SCHOOL	WS- 002269	8/19/2016	2	Fountain	In classroom 215	Right	FT-82016-002269-A	< 1	FT-82016-002269-B	< 1	
43	JANNEY ELEMENTARY SCHOOL	WS- 002270	8/19/2016	2	Cooler	In hallway adjacent to room 215	High	Left	FT-82016-002270-A	< 1	FT-82016-002270-B	< 1
44	JANNEY ELEMENTARY SCHOOL	WS- 002271	8/19/2016	2	Cooler	In hallway adjacent to room 215	Low	Right	FT-82016-002271-A	< 1	FT-82016-002271-B	< 1

45	JANNEY ELEMENTARY SCHOOL	WS- 002272	8/19/2016	3	Cooler	In hallway adjacent to room 316	High	Left	FT-82016-002272-A	< 1	FT-82016-002272-B	< 1
46	JANNEY ELEMENTARY SCHOOL	WS- 002274	8/19/2016	2	Fountain	In classroom 217		Right	FT-82016-002274-A	< 1	FT-82016-002274-B	< 1
47	JANNEY ELEMENTARY SCHOOL	WS- 002275	8/19/2016	3	Fountain	In classroom 315		Left	FT-82016-002275-A	< 1	FT-82016-002275-B	< 1
48	JANNEY ELEMENTARY SCHOOL	WS- 002276	8/19/2016	3	Classroom Faucet	In classroom 315		Right	FT-82016-002276-A	< 1	FT-82016-002276-B	< 1
49	JANNEY ELEMENTARY SCHOOL	WS- 002279	8/19/2016	3	Fountain	In classroom 308		Right	FT-82016-002279-A	< 1	FT-82016-002279-B	< 1
50	JANNEY ELEMENTARY SCHOOL	WS- 002280	8/19/2016	3	Fountain	In classroom 317		Right	FT-82016-002280-A	< 1	FT-82016-002280-B	2.3
			10/10/2016						Re-test A	< 1	Re-test B	< 1
51	JANNEY ELEMENTARY SCHOOL	WS- 002281	8/19/2016	3	Cooler	In hallway adjacent to room 310			FT-82016-002281-A	< 1	FT-82016-002281-B	< 1
52	JANNEY ELEMENTARY SCHOOL	WS- 002282	8/19/2016	3	Cooler	In hallway adjacent to room 307			FT-82016-002282-A	< 1	FT-82016-002282-B	< 1
53	JANNEY ELEMENTARY SCHOOL	WS- 002283	8/19/2016	3	Fountain	In classroom 310		Right	FT-82016-002283-A	< 1	FT-82016-002283-B	< 1
54	JANNEY ELEMENTARY SCHOOL	WS- 002286	8/19/2016	3	Fountain	In classroom 309		Right	FT-82016-002286-A	< 1	FT-82016-002286-B	< 1
55	JANNEY ELEMENTARY SCHOOL	WS- 002288	8/19/2016	3	Fountain	In classroom 306		Right	FT-82016-002288-A	< 1	FT-82016-002288-B	< 1
56	JANNEY ELEMENTARY SCHOOL	WS- 002289	8/19/2016	3	Fountain	In classroom 313			FT-82016-002289-A	< 1	FT-82016-002289-B	< 1
57	JANNEY ELEMENTARY SCHOOL	WS- 002292	8/19/2016	3	Fountain	In classroom 304		Right	FT-82016-002292-A	< 1	FT-82016-002292-B	< 1
58	JANNEY ELEMENTARY SCHOOL	WS- 002294	8/19/2016	3	Fountain	In classroom 303		Right	FT-82016-002294-A	< 1	FT-82016-002294-B	< 1
59	JANNEY ELEMENTARY SCHOOL	WS- 002295	8/19/2016	3	Fountain	In classroom 302		Right	FT-82016-002295-A	< 1	FT-82016-002295-B	< 1
60	JANNEY ELEMENTARY SCHOOL	WS- 002297	8/19/2016	3	Cooler	In hallway adjacent to room 303			FT-82016-002297-A	< 1	FT-82016-002297-B	< 1
61	JANNEY ELEMENTARY SCHOOL	WS- 002299	8/19/2016	3	Fountain	In classroom 301		Right	FT-82016-002299-A	< 1	FT-82016-002299-B	< 1
62	JANNEY ELEMENTARY SCHOOL	WS- 002301	8/19/2016	3	Fountain	In classroom 300		Right	FT-82016-002301-A	< 1	FT-82016-002301-B	< 1