



# CHM @ LOGAN ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000015	8/18/2016	1	Cooler	Annex building water fountain adjacent to staff restroom High Right	FT-82016-000015-A	< 1	FT-82016-000015-B	< 1
2	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000016	8/18/2016	1	Cooler	Annex building water fountain adjacent to staff restroom Low Mid	FT-82016-000016-A	< 1	FT-82016-000016-B	< 1
3	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000017	8/18/2016	1	Cooler	Annex building water fountain adjacent to staff restroom High Left	FT-82016-000017-A	< 1	FT-82016-000017-B	< 1
4	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000028	8/18/2016	Basement	Food Prep Sink	In kitchen Left	FT-72016-000028-A	< 1	FT-72016-000028-B	< 1
5	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000029	8/18/2016	Basement	Food Prep Sink	In kitchen Mid	FT-72016-000029-A	< 1	FT-72016-000029-B	< 1
6	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000031	8/18/2016	Basement	Cooler	In cafeteria near kitchen entry	FT-82016-000031-A	< 1	FT-82016-000031-B	< 1
7	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000042	8/18/2016	1	Cooler	In hallway adjacent to classroom 109	FT-82016-000042-A	< 1	FT-82016-000042-B	< 1
8	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000056	8/18/2016	1	Health Suite	In health suite 100	FT-82016-000056-A	< 1	FT-82016-000056-B	< 1
9	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000062	8/18/2016	1	Cooler	In hallway adjacent to classroom 101	FT-82016-000062-A	< 1	FT-82016-000062-B	< 1
10	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000066	8/18/2016	1	Utility	First floor in boys restroom adjacent to classroom 101(tub sink)	FT-72016-000066-A	< 1	FT-72016-000066-B	< 1
11	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000073	8/18/2016	2	Cooler	In hallway adjacent to library 212	FT-82016-000073-A	< 1	FT-82016-000073-B	< 1
12	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000081	8/18/2016	2	Cooler	In hallway adjacent to classroom 202 High Left	FT-82016-000081-A	< 1	FT-82016-000081-B	< 1
13	CAPITOL HILL MONTESSORI ELEMENTARY SCHOOL @ LOGAN	WS- 000082	8/18/2016	2	Cooler	In hallway adjacent to classroom 202 Low Right	FT-82016-000082-A	< 1	FT-82016-000082-B	< 1