



MACFARLAND Jr HS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	MACFARLAND JR. HIGH	WS- 003172	8/24/2016	3	Cooler	In PE room adjacent to the restroom	FT-82016-003172-A	< 1	FT-82016-003172-B	< 1
2	MACFARLAND JR. HIGH	WS- 003173	8/24/2016	3	Cooler	In hallway between gym and stairs	FT-82016-003173-A	< 1	FT-82016-003173-B	< 1
3	MACFARLAND JR. HIGH	WS- 003174	8/24/2016	3	Cooler	In gym locker room adjacent to showers	FT-82016-003174-A	< 1	FT-82016-003174-B	< 1
4	MACFARLAND JR. HIGH	WS- 003175	8/24/2016	1	Health Suite	In health suite restroom	FT-82016-003175-A	< 1	FT-82016-003175-B	< 1
5	MACFARLAND JR. HIGH	WS- 003176	8/24/2016	1	Cooler	In hallway adjacent to room 122	FT-82016-003176-A	< 1	FT-82016-003176-B	< 1
6	MACFARLAND JR. HIGH	WS- 010918	8/24/2016	Basement	Food Prep Sink	In kitchen Right	FT-82016-010918-A	< 1	FT-82016-010918-B	< 1
7	MACFARLAND JR. HIGH	WS- 010922	8/24/2016	Basement	Cooler	In cafeteria	FT-82016-010922-A	< 1	FT-82016-010922-B	< 1
8	MACFARLAND JR. HIGH	WS- 010924	8/24/2016	1	Cooler	In hallway adjacent to room 152	FT-82016-010924-A	< 1	FT-82016-010924-B	< 1
9	MACFARLAND JR. HIGH	WS- 010929	8/24/2016	1	Cooler	In hallway adjacent to room 112	FT-82016-010929-A	< 1	FT-82016-010929-B	< 1
10	MACFARLAND JR. HIGH	WS- 010930	8/24/2016	1	Cooler	In hallway adjacent to room 114	FT-82016-010930-A	< 1	FT-82016-010930-B	< 1
11	MACFARLAND JR. HIGH	WS- 010931	8/24/2016	1	Cooler	In hallway adjacent to room 131	FT-82016-010931-A	< 1	FT-82016-010931-B	< 1
12	MACFARLAND JR. HIGH	WS- 010941	8/24/2016	2	Cooler	In hallway adjacent to room 213	FT-82016-010941-A	< 1	FT-82016-010941-B	< 1
13	MACFARLAND JR. HIGH	WS- 010951	8/24/2016	2	Cooler	In hallway adjacent to room 201	FT-82016-010951-A	< 1	FT-82016-010951-B	< 1
14	MACFARLAND JR. HIGH	WS- 010952	8/24/2016	2	Cooler	In hallway adjacent to room 204	FT-82016-010952-A	< 1	FT-82016-010952-B	< 1
15	MACFARLAND JR. HIGH	WS- 010953	8/24/2016	3	Cooler	In hallway adjacent to room 303	FT-82016-010953-A	< 1	FT-82016-010953-B	< 1
16	MACFARLAND JR. HIGH	WS- 010958	8/24/2016	3	Cooler	In hallway adjacent to room 306	FT-82016-010958-A	< 1	FT-82016-010958-B	< 1