



MANN ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	MANN ELEMENTARY SCHOOL	WS- 003942	12/23/2016	1	Combo Faucet	In classroom 154 High Left	FT-122016-003942-A	< 1	FT-122016-003942-B	< 1
2	MANN ELEMENTARY SCHOOL	WS- 003940	12/23/2016	1	Combo Faucet	In classroom 142 High Right	FT-122016-003940-A	< 1	FT-122016-003940-B	< 1
3	MANN ELEMENTARY SCHOOL	WS- 003937	12/23/2016	1	Combo Faucet	In classroom 146 High Left	FT-122016-003937-A	< 1	FT-122016-003937-B	< 1
4	MANN ELEMENTARY SCHOOL	WS- 003935	12/23/2016	1	Combo Faucet	In classroom 150 High Left	FT-122016-003935-A	< 1	FT-122016-003935-B	< 1
5	MANN ELEMENTARY SCHOOL	WS- 003944	12/23/2016	1	Combo Faucet	In classroom 138 High Mid	FT-122016-003944-A	< 1	FT-122016-003944-B	< 1
6	MANN ELEMENTARY SCHOOL	WS- 003956	12/23/2016	1	Break Room	In staff lounge 133 High Left	FT-112016-003956-A	< 1	FT-112016-003956-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb