



MINER ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	MINER ELEMENTARY SCHOOL	WS- 000393	12/21/2016	2	Combo Faucet	In resource room 212 Right	FT-122016-000393-A	< 1	FT-122016-000393-B	< 1
2	MINER ELEMENTARY SCHOOL	WS- 000286	12/21/2016	1	Combo Faucet	In classroom 137 Right	FT-122016-000286-A	< 1	FT-122016-000286-B	< 1
3	MINER ELEMENTARY SCHOOL	WS- 000395	12/21/2016	2	Classroom Faucet	In music room 206 Right	FT-122016-000395-A	< 1	FT-122016-000395-B	< 1
4	MINER ELEMENTARY SCHOOL	WS- 000386	12/21/2016	2	Combo Faucet	In classroom 211 Right	FT-122016-000386-A	< 1	FT-122016-000386-B	< 1
5	MINER ELEMENTARY SCHOOL	WS- 000271	12/21/2016	1	Combo Faucet	In classroom 115 Left	FT-122016-000271-A	< 1	FT-122016-000271-B	< 1
6	MINER ELEMENTARY SCHOOL	WS- 000270	12/21/2016	1	Combo Faucet	In classroom 117	FT-122016-000270-A	< 1	FT-122016-000270-B	< 1
7	MINER ELEMENTARY SCHOOL	WS- 000275	12/21/2016	1	Combo Faucet	In classroom 119	FT-122016-000275-A	< 1	FT-122016-000275-B	< 1
8	MINER ELEMENTARY SCHOOL	WS- 000300	12/21/2016	1	Combo Faucet	In classroom 127	FT-122016-000300-A	< 1	FT-122016-000300-B	< 1
9	MINER ELEMENTARY SCHOOL	WS- 000261	12/21/2016	1	Combo Faucet	In classroom 103 Right	FT-122016-000261-A	< 1	FT-122016-000261-B	< 1
10	MINER ELEMENTARY SCHOOL	WS- 000281	12/21/2016	1	Combo Faucet	In classroom 129	FT-122016-000281-A	< 1	FT-122016-000281-B	< 1
11	MINER ELEMENTARY SCHOOL	WS- 000305	12/21/2016	1	Combo Faucet	In classroom 135 Left	FT-122016-000305-A	< 1	FT-122016-000305-B	< 1
12	MINER ELEMENTARY SCHOOL	WS- 000266	12/21/2016	1	Combo Faucet	In classroom 107 Left	FT-122016-000266-A	< 1	FT-122016-000266-B	< 1
13	MINER ELEMENTARY SCHOOL	WS- 000258	12/21/2016	1	Combo Faucet	In classroom 101 Left	FT-122016-000258-A	< 1	FT-122016-000258-B	< 1
14	MINER ELEMENTARY SCHOOL	WS- 000311	12/21/2016	1	Combo Faucet	In classroom 130	FT-122016-000311-A	< 1	FT-122016-000311-B	< 1
15	MINER ELEMENTARY SCHOOL	WS- 000280	12/21/2016	1	Combo Faucet	In classroom 121 Mid	FT-122016-000280-A	< 1	FT-122016-000280-B	< 1
16	MINER ELEMENTARY SCHOOL	WS- 000267	12/21/2016	1	Combo Faucet	In classroom 109	FT-122016-000267-A	< 1	FT-122016-000267-B	< 1
17	MINER ELEMENTARY SCHOOL	WS- 000312	12/21/2016	1	Combo Faucet	In classroom 132 Mid	FT-122016-000312-A	< 1	FT-122016-000312-B	< 1
18	MINER ELEMENTARY SCHOOL	WS- 000273	12/21/2016	1	Combo Faucet	In classroom 111 Mid	FT-122016-000273-A	< 1	FT-122016-000273-B	< 1
19	MINER ELEMENTARY SCHOOL	WS- 000304	12/21/2016	1	Combo Faucet	In classroom 131 Mid	FT-122016-000304-A	< 1	FT-122016-000304-B	< 1
20	MINER ELEMENTARY SCHOOL	WS- 000278	12/21/2016	1	Combo Faucet	In classroom 123 Left	FT-122016-000278-A	< 1	FT-122016-000278-B	< 1
21	MINER ELEMENTARY SCHOOL	WS- 000284	12/21/2016	1	Combo Faucet	In classroom 133 Mid	FT-122016-000284-A	< 1	FT-122016-000284-B	< 1
22	MINER ELEMENTARY SCHOOL	WS- 000263	12/21/2016	1	Combo Faucet	In classroom 105	FT-122016-000263-A	< 1	FT-122016-000263-B	< 1
23	MINER ELEMENTARY SCHOOL	WS- 012573	12/21/2016	1	Break Room	In work room 171	FT-112016-012573-A	< 1	FT-112016-012573-B	< 1
24	MINER ELEMENTARY SCHOOL	WS- 000257	12/21/2016	1	Break Room	In staff lounge	FT-112016-000257-A	< 1	FT-112016-000257-B	< 1
25	MINER ELEMENTARY SCHOOL	WS- 000297	12/21/2016	1	Break Room	In laundry room 112 Mid	FT-112016-000297-A	< 1	FT-112016-000297-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb