



# MOTEN ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	MOTEN ELEMENTARY SCHOOL	WS- 004317	8/13/2016	Basement	Classroom Faucet	In classroom B08	FT-72016-004317-A	< 1	FT-72016-004317-B	< 1
2	MOTEN ELEMENTARY SCHOOL	WS- 004318	8/13/2016	Basement	Cooler	In hallway across from room B08	FT-72016-004318-A	< 1	FT-72016-004318-B	< 1
3	MOTEN ELEMENTARY SCHOOL	WS- 004322	8/13/2016	Ground Floor	Cooler	In hallway adjacent to room G06 High Left	FT-72016-004322-A	< 1	FT-72016-004322-B	< 1
4	MOTEN ELEMENTARY SCHOOL	WS- 004323	8/13/2016	Ground Floor	Cooler	In hallway adjacent to room G06 Low Right	FT-72016-004323-A	2.8	FT-72016-004323-B	< 1
5	MOTEN ELEMENTARY SCHOOL	WS- 004324	8/13/2016	Ground Floor	Food Prep Sink	In kitchen fourth clockwise from entry door Low	FT-72016-004324-A	< 1	FT-72016-004324-B	< 1
6	MOTEN ELEMENTARY SCHOOL	WS- 004329	8/13/2016	Ground Floor	Cooler	In hallway adjacent to room G10 High Left	FT-72016-004329-A	< 1	FT-72016-004329-B	< 1
7	MOTEN ELEMENTARY SCHOOL	WS- 004330	8/13/2016	Ground Floor	Cooler	In hallway adjacent to room G10 Low Right	FT-72016-004330-A	< 1	FT-72016-004330-B	< 1
8	MOTEN ELEMENTARY SCHOOL	WS- 004333	8/13/2016	Ground Floor	Cooler	In hallway adjacent to room G25	FT-72016-004333-A	< 1	FT-72016-004333-B	< 1
9	MOTEN ELEMENTARY SCHOOL	WS- 004337	8/13/2016	Ground Floor	Cooler	In hallway adjacent to room G31	FT-72016-004337-A	< 1	FT-72016-004337-B	< 1
10	MOTEN ELEMENTARY SCHOOL	WS- 004338	8/13/2016	1	Cooler	In hallway adjacent to girls' restroom 103 High Left	FT-72016-004338-A	< 1	FT-72016-004338-B	< 1
11	MOTEN ELEMENTARY SCHOOL	WS- 004339	8/13/2016	1	Cooler	In hallway adjacent to girls' restroom 103 Low Right	FT-72016-004339-A	< 1	FT-72016-004339-B	< 1
12	MOTEN ELEMENTARY SCHOOL	WS- 004342	8/13/2016	1	Health Suite	In health suite	FT-72016-004342-A	< 1	FT-72016-004342-B	< 1
13	MOTEN ELEMENTARY SCHOOL	WS- 004343	8/13/2016	1	Cooler	In hallway adjacent to room 119 High Left	FT-72016-004343-A	< 1	FT-72016-004343-B	< 1
14	MOTEN ELEMENTARY SCHOOL	WS- 004344	8/13/2016	1	Cooler	In hallway adjacent to room 119 Low Right	FT-72016-004344-A	< 1	FT-72016-004344-B	< 1
15	MOTEN ELEMENTARY SCHOOL	WS- 004346	8/13/2016	1	Cooler	In hallway adjacent to room 124	FT-72016-004346-A	< 1	FT-72016-004346-B	< 1
16	MOTEN ELEMENTARY SCHOOL	WS- 004348	8/13/2016	1	Classroom Faucet	In classroom 133	FT-72016-004348-A	< 1	FT-72016-004348-B	< 1
17	MOTEN ELEMENTARY SCHOOL	WS- 004350	8/13/2016	1	Cooler	In hallway adjacent to room 134	FT-72016-004350-A	< 1	FT-72016-004350-B	< 1
18	MOTEN ELEMENTARY SCHOOL	WS- 004351	8/13/2016	2	Cooler	In hallway adjacent to room 224B	FT-72016-004351-A	< 1	FT-72016-004351-B	< 1
19	MOTEN ELEMENTARY SCHOOL	WS- 004352	8/13/2016	2	Cooler	In hallway adjacent to room 203A High Left	FT-72016-004352-A	< 1	FT-72016-004352-B	< 1
20	MOTEN ELEMENTARY SCHOOL	WS- 004353	8/13/2016	2	Cooler	In hallway adjacent to room 203A Low Right	FT-72016-004353-A	< 1	FT-72016-004353-B	< 1
21	MOTEN ELEMENTARY SCHOOL	WS- 004357	8/13/2016	2	Cooler	In hallway across from room 210 High Left	FT-72016-004357-A	< 1	FT-72016-004357-B	< 1
22	MOTEN ELEMENTARY SCHOOL	WS- 004358	8/13/2016	2	Cooler	In hallway across from room 210 Low Right	FT-72016-004358-A	< 1	FT-72016-004358-B	< 1
23	MOTEN ELEMENTARY SCHOOL	WS- 004362	8/13/2016	2	Classroom Faucet	In classroom 212 Mid	FT-72016-004362-A	< 1	FT-72016-004362-B	< 1
24	MOTEN ELEMENTARY SCHOOL	WS- 004364	8/13/2016	2	Cooler	In hallway adjacent to room 216	FT-72016-004364-A	< 1	FT-72016-004364-B	< 1
25	MOTEN ELEMENTARY SCHOOL	WS- 004366	8/13/2016	3	Cooler	In hallway adjacent to room 301 High Left	FT-72016-004366-A	< 1	FT-72016-004366-B	< 1
26	MOTEN ELEMENTARY SCHOOL	WS- 004367	8/13/2016	3	Cooler	In hallway adjacent to room 301 High Right	FT-72016-004367-A	< 1	FT-72016-004367-B	< 1
27	MOTEN ELEMENTARY SCHOOL	WS- 004374	8/13/2016	3	Cooler	In hallway adjacent to room 312 High Left	FT-72016-004374-A	< 1	FT-72016-004374-B	< 1
28	MOTEN ELEMENTARY SCHOOL	WS- 004375	8/13/2016	3	Cooler	In hallway adjacent to room 312 Low Right	FT-72016-004375-A	< 1	FT-72016-004375-B	< 1
29	MOTEN ELEMENTARY SCHOOL	WS- 004378	8/13/2016	3	Cooler	In hallway adjacent to room 317	FT-72016-004378-A	< 1	FT-72016-004378-B	< 1
30	MOTEN ELEMENTARY SCHOOL	WS- 004383	8/13/2016	3	Cooler	In hallway adjacent to room 327	FT-72016-004383-A	< 1	FT-72016-004383-B	< 1