



PAYNE ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	PAYNE ELEMENTARY SCHOOL	WS-000111	8/21/2016	1	Food Prep Sink	In kitchen sixth clockwise from entry door Right	FT-82016-000111-A	< 1	FT-82016-000111-B	< 1
2	PAYNE ELEMENTARY SCHOOL	WS-000115	8/21/2016	1	Cooler	In hallway adjacent to restaurant Low Right	FT-82016-000115-A	< 1	FT-82016-000115-B	< 1
3	PAYNE ELEMENTARY SCHOOL	WS-000116	8/21/2016	1	Bottle Filler	In hallway adjacent to restaurant (bottle filler) High Left	FT-82016-000116-A	< 1	FT-82016-000116-B	< 1
4	PAYNE ELEMENTARY SCHOOL	WS-000117	8/21/2016	1	Cooler	In hallway adjacent to restaurant Low Left	FT-82016-000117-A	< 1	FT-82016-000117-B	< 1
5	PAYNE ELEMENTARY SCHOOL	WS-000122	8/21/2016	1	Cooler	In hallway adjacent to room 132 Low Right	FT-82016-000122-A	< 1	FT-82016-000122-B	< 1
6	PAYNE ELEMENTARY SCHOOL	WS-000124	8/21/2016	1	Cooler	In hallway adjacent to room 132 Low Left	FT-82016-000124-A	< 1	FT-82016-000124-B	< 1
7	PAYNE ELEMENTARY SCHOOL	WS-000125	8/21/2016	1	Fountain	In classroom 131 Right	FT-82016-000125-A	< 1	FT-82016-000125-B	< 1
8	PAYNE ELEMENTARY SCHOOL	WS-000126	8/21/2016	1	Bottle Filler	In hallway adjacent to room 132 (bottle filler) High Left	FT-82016-000126-A	< 1	FT-82016-000126-B	< 1
9	PAYNE ELEMENTARY SCHOOL	WS-000130	8/21/2016	1	Health Suite	In unisex restroom 129 in health suite	FT-82016-000130-A	< 1	FT-82016-000130-B	< 1
10	PAYNE ELEMENTARY SCHOOL	WS-000131	8/21/2016	1	Health Suite	In health suite 129A Left	FT-82016-000131-A	< 1	FT-82016-000131-B	< 1
11	PAYNE ELEMENTARY SCHOOL	WS-000133	8/21/2016	1	Fountain	In health suite 129A Right	FT-82016-000133-A	< 1	FT-82016-000133-B	< 1
12	PAYNE ELEMENTARY SCHOOL	WS-000137	8/21/2016	1	Fountain	In classroom 161 Low Left	FT-82016-000137-A	< 1	FT-82016-000137-B	< 1
13	PAYNE ELEMENTARY SCHOOL	WS-000143	8/21/2016	1	Fountain	In classroom 190 Low Right	FT-82016-000143-A	< 1	FT-82016-000143-B	< 1
14	PAYNE ELEMENTARY SCHOOL	WS-000146	8/21/2016	1	Fountain	In classroom 168 Low Left	FT-82016-000146-A	< 1	FT-82016-000146-B	< 1
15	PAYNE ELEMENTARY SCHOOL	WS-000147	8/21/2016	1	Bottle Filler	In hallway adjacent to room 184 (bottle filler) High Left	FT-82016-000147-A	< 1	FT-82016-000147-B	< 1
16	PAYNE ELEMENTARY SCHOOL	WS-000151	8/21/2016	1	Cooler	In hallway adjacent to room 184 Low Left	FT-82016-000151-A	< 1	FT-82016-000151-B	< 1
17	PAYNE ELEMENTARY SCHOOL	WS-000153	8/21/2016	1	Fountain	In classroom 187 Low Right	FT-82016-000153-A	< 1	FT-82016-000153-B	< 1
18	PAYNE ELEMENTARY SCHOOL	WS-000154	8/21/2016	1	Cooler	In hallway adjacent to room 184 Right	FT-82016-000154-A	< 1	FT-82016-000154-B	< 1
19	PAYNE ELEMENTARY SCHOOL	WS-000158	8/21/2016	1	Fountain	In classroom 184 Low Right	FT-82016-000158-A	< 1	FT-82016-000158-B	< 1
20	PAYNE ELEMENTARY SCHOOL	WS-000164	8/21/2016	1	Fountain	In classroom 181 Low Left	FT-82016-000164-A	< 1	FT-82016-000164-B	< 1
21	PAYNE ELEMENTARY SCHOOL	WS-000168	8/21/2016 10/17/2016	1	Bottle Filler	In hallway between rooms 180 and 181 (bottle filler) High Left	FT-82016-000168-A Res-test A	< 1 < 1	FT-82016-000168-B Re-test B	3 < 1
22	PAYNE ELEMENTARY SCHOOL	WS-000169	8/21/2016	1	Cooler	In hallway between rooms 180 and 181 Low Right	FT-82016-000169-A	< 1	FT-82016-000169-B	< 1
23	PAYNE ELEMENTARY SCHOOL	WS-000170	8/21/2016	1	Cooler	In hallway between rooms 180 and 181 Low Left	FT-82016-000170-A	< 1	FT-82016-000170-B	< 1
24	PAYNE ELEMENTARY SCHOOL	WS-000173	8/21/2016	2	Fountain	In classroom 204 High Left	FT-82016-000173-A	< 1	FT-82016-000173-B	< 1
25	PAYNE ELEMENTARY SCHOOL	WS-000177	8/21/2016	2	Bottle Filler	In classroom 204 (bottle filler) High Left	FT-82016-000177-A	< 1	FT-82016-000177-B	< 1
26	PAYNE ELEMENTARY SCHOOL	WS-000179	8/21/2016	2	Cooler	In classroom 204 High Left	FT-82016-000179-A	< 1	FT-82016-000179-B	< 1
27	PAYNE ELEMENTARY SCHOOL	WS-000180	8/21/2016	2	Fountain	In classroom 205 Right	FT-82016-000180-A	< 1	FT-82016-000180-B	< 1
28	PAYNE ELEMENTARY SCHOOL	WS-000181	8/21/2016	2	Cooler	In classroom 204 Low Right	FT-82016-000181-A	< 1	FT-82016-000181-B	< 1
29	PAYNE ELEMENTARY SCHOOL	WS-000182	8/21/2016	2	Cooler	In hallway adjacent to boys' restroom High Left	FT-82016-000182-A	< 1	FT-82016-000182-B	< 1
30	PAYNE ELEMENTARY SCHOOL	WS-000185	8/21/2016	2	Cooler	In hallway adjacent to boys' restroom Low Right	FT-82016-000185-A	< 1	FT-82016-000185-B	< 1
31	PAYNE ELEMENTARY SCHOOL	WS-000188	8/21/2016	2	Bottle Filler	In hallway adjacent to boys' restroom (bottle filler) High Left	FT-82016-000188-A	< 1	FT-82016-000188-B	< 1
32	PAYNE ELEMENTARY SCHOOL	WS-000191	8/21/2016	2	Fountain	In classroom 207 Right	FT-82016-000191-A	< 1	FT-82016-000191-B	< 1
33	PAYNE ELEMENTARY SCHOOL	WS-000194	8/21/2016	3	Cooler	In hallway adjacent to girls' restroom Low Right	FT-82016-000194-A	< 1	FT-82016-000194-B	< 1
34	PAYNE ELEMENTARY SCHOOL	WS-000198	8/21/2016	3	Cooler	In hallway adjacent to girls' restroom High Left	FT-82016-000198-A	< 1	FT-82016-000198-B	< 1
35	PAYNE ELEMENTARY SCHOOL	WS-000200	8/21/2016	3	Bottle Filler	In hallway adjacent to girls' restroom (bottle filler) High Left	FT-82016-000200-A	< 1	FT-82016-000200-B	< 1
36	PAYNE ELEMENTARY SCHOOL	WS-000204	8/21/2016	3	Fountain	In break room 305	FT-82016-000204-A	< 1	FT-82016-000204-B	< 1
37	PAYNE ELEMENTARY SCHOOL	WS-000205	8/21/2016	1	Ice Maker	In kitchen (ice maker)	FT-82016-000205-A	< 1	FT-82016-000205-B	< 1
38	PAYNE ELEMENTARY SCHOOL	WS-000209	8/21/2016	2	Cooler	In hallway adjacent to room 243 Low Left	FT-82016-000209-A	< 1	FT-82016-000209-B	< 1
39	PAYNE ELEMENTARY SCHOOL	WS-000210	8/21/2016	2	Fountain	In classroom 246	FT-82016-000210-A	< 1	FT-82016-000210-B	< 1

40	PAYNE ELEMENTARY SCHOOL	WS- 000211	8/21/2016	2	Bottle Filler	In hallway adjacent to room 258 (bottle filler) High Left	FT-82016-000211-A	< 1	FT-82016-000211-B	< 1
41	PAYNE ELEMENTARY SCHOOL	WS- 000214	8/21/2016	2	Cooler	In hallway adjacent to room 258 Low Right	FT-82016-000214-A	< 1	FT-82016-000214-B	< 1
42	PAYNE ELEMENTARY SCHOOL	WS- 000222	8/21/2016	2	Cooler	In hallway adjacent to room 233 Low Left	FT-82016-000222-A	< 1	FT-82016-000222-B	< 1
43	PAYNE ELEMENTARY SCHOOL	WS- 000223	8/21/2016	2	Bottle Filler	In hallway adjacent to room 233 (bottle filler) High Left	FT-82016-000223-A	< 1	FT-82016-000223-B	< 1
44	PAYNE ELEMENTARY SCHOOL	WS- 000224	8/21/2016	2	Cooler	In hallway adjacent to room 233 Low Right	FT-82016-000224-A	< 1	FT-82016-000224-B	< 1