



RH TERREL REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location			1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	RH TERRELL RECREATION CENTER	WS- 006160	9/22/2016	1	Cooler	In lobby across from elevator	High	Left	FT-82016-006160-A	< 1	FT-82016-006160-B	< 1
2	RH TERRELL RECREATION CENTER	WS- 006161	9/22/2016	1	Cooler	In lobby across from elevator	Low	Right	FT-82016-006161-A	< 1	FT-82016-006161-B	< 1