RAYMOND EC LEAD WATER TEST RESULTS

Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	RAYMOND EDUCATIONAL CAMPUS	WS- 008649	12/7/2016	2	Break Room	In staff lounge	FT-102016-008649-A	< 1	FT-102016-008649-B	< 1
2	RAYMOND EDUCATIONAL CAMPUS	WS- 008662	12/7/2016	3	Break Room	In staff lounge room 304	FT-102016-008662-A	< 1	FT-102016-008662-B	< 1
3	RAYMOND EDUCATIONAL CAMPUS	WS- 009142	12/7/2016	1	Bathroom	In classroom 113 in bathroom	FT-122016-009142-A	1.9	FT-122016-009142-B	< 1
4	RAYMOND EDUCATIONAL CAMPUS	WS- 009157	12/7/2016	1	Classroom Faucet	In classroom 117	FT-122016-009157-A	< 1	FT-122016-009157-B	< 1
5	RAYMOND EDUCATIONAL CAMPUS	WS- 009140	12/7/2016	1	Bathroom	In classroom 111 in bathroom	FT-122016-009140-A	< 1	FT-122016-009140-B	< 1
6	RAYMOND EDUCATIONAL CAMPUS	WS- 009159	12/7/2016	1	Classroom Faucet	In classroom 111	FT-122016-009159-A	< 1	FT-122016-009159-B	< 1
7	RAYMOND EDUCATIONAL CAMPUS	WS- 009143	12/7/2016	1	Bathroom	In classroom 116 in bathroom	FT-122016-009143-A	1.2	FT-122016-009143-B	< 1
8	RAYMOND EDUCATIONAL CAMPUS	WS- 009141	12/7/2016	1	Bathroom	In classroom 110 in bathroom	FT-122016-009141-A	< 1	FT-122016-009141-B	< 1
9	RAYMOND EDUCATIONAL CAMPUS	WS- 009158	12/7/2016	1	Classroom Faucet	In classroom 110	FT-122016-009158-A	< 1	FT-122016-009158-B	< 1
10	RAYMOND EDUCATIONAL CAMPUS	WS- 009156	12/7/2016	1	Classroom Faucet	In classroom 116	FT-122016-009156-A	< 1	FT-122016-009156-B	< 1
11	RAYMOND EDUCATIONAL CAMPUS	WS- 009155	12/7/2016	1	Classroom Faucet	In classroom 115	FT-122016-009155-A	< 1	FT-122016-009155-B	< 1
12	RAYMOND EDUCATIONAL CAMPUS	WS- 009154	12/7/2016	1	Classroom Faucet	In classroom 113	FT-122016-009154-A	< 1	FT-122016-009154-B	< 1
13	RAYMOND EDUCATIONAL CAMPUS	WS- 009152	12/7/2016	2	Classroom Faucet	In classroom 20	FT-122016-009152-A	14	FT-122016-009152-B	< 1
14	RAYMOND EDUCATIONAL CAMPUS	WS- 009153	12/7/2016	3	Classroom Faucet	In classroom 36 Right	FT-122016-009153-A	< 1	FT-122016-009153-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

3	RAYMOND EDUCATIONAL CAMPUS	WS- 009142	1/25/2017	1	Bathroom	In classroom 113 in bathroom	FT-122016-009142-A	1.4	FT-122016-009142-B	< 1
7	RAYMOND EDUCATIONAL CAMPUS	WS- 009143	1/25/2017	1	Bathroom	In classroom 116 in bathroom	FT-122016-009143-A	< 1	FT-122016-009143-B	< 1
13	RAYMOND EDUCATIONAL CAMPUS	WS- 009152	1/25/2017	2	Classroom Faucet	In classroom 20	FT-122016-009152-A	7.2	FT-122016-009152-B	< 1

Note :
Filter re-tests are only performed to devices that have sampling results greater than 1 ppb