



# SHARPE HEALTH LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 008562	8/22/2016	1	Cooler	In hallway adjacent to room 301	FT-82016-008562-A	< 1	FT-82016-008562-B	< 1
2	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 008563	8/22/2016	1	Cooler	In hallway across classroom 307	FT-82016-008563-A	< 1	FT-82016-008563-B	< 1
3	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 008565	8/22/2016	1	Cooler	In hallway adjacent to room 314	FT-82016-008565-A	< 1	FT-82016-008565-B	< 1
4	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 008574	8/22/2016	1	Food Prep Sink	In kitchen Right	FT-82016-008574-A	< 1	FT-82016-008574-B	< 1
5	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 008575	8/22/2016	1	Cooler	In classroom 206	FT-82016-008575-A	< 1	FT-82016-008575-B	< 1
6	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 008577	8/22/2016	1	Cooler	In hallway adjacent to room 205	FT-82016-008577-A	< 1	FT-82016-008577-B	< 1
7	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 008580	8/22/2016	1	Cooler	In hallway adjacent to room 213	FT-82016-008580-A	< 1	FT-82016-008580-B	< 1
8	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 008585	8/22/2016	1	Cooler	In hallway adjacent to pool room	FT-82016-008585-A	< 1	FT-82016-008585-B	< 1
9	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 008593	8/22/2016	1	Cooler	In hallway adjacent to classroom 119	FT-82016-008593-A	< 1	FT-82016-008593-B	< 1
10	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 008599	8/22/2016	1	Cooler	In hallway across room 113	FT-82016-008599-A	< 1	FT-82016-008599-B	< 1
11	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 008602	8/22/2016	1	Cooler	In hallway adjacent to room 105	FT-82016-008602-A	< 1	FT-82016-008602-B	< 1
12	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	WS- 009168	8/22/2016	1	Health Suite	In room 202	FT-82016-009168-A	< 1	FT-82016-009168-B	< 1