



1818 New York Avenue, N.E.
Washington, DC 20002

Telephone: (202) 832-1433
Fax: (202) 832-1434
www.gciusa.biz

February 19, 2016

Department of General Services
Office of Safety and Health, Facilities Division
2000 14th Street NW, 5th Floor
Washington, DC 20009

Attention: Mr. Ricardo Eley, Mr. Brian Killian

RE: Weekly Indoor Air Quality Evaluation at Shepard Elementary School

Global Project Number: V0225

Dear Mr. Eley and Mr. Killian:

On February 17, 2016, Global Consulting, Inc. (GLOBAL) conducted a weekly indoor air quality (IAQ) evaluation at the Shepherd Elementary school, a property maintained by the Department of General Services (DGS), located at 7800 14th St. NW Washington DC 20012. This report provides a summary of observations and findings.

Methodology

The IAQ evaluation included a visual assessment, IAQ instrumentation screening, as well as sampling for non-viable mold in representative locations within the building. Additionally, one ambient set of samples was taken for comparison.

Non-viable fungal spore samples were collected on *Air-O-Cell* cassettes using a Buck BioAire calibrated pump. The air sample was taken within the breathing zone and no closer than three feet from the ground. In tandem with collecting mold samples, real-time readings for temperature, relative humidity, carbon dioxide, and carbon monoxide were collected using a Fluke 975 Air Meter.

Respirable particulate in air (PM_{2.5} and PM₁₀, size classes) was measured using an Aerocet 531 Particle Mass Counter and calibrated prior to sampling.

Microbial samples were delivered to EMSL Analytical, Inc. of Beltsville, Maryland, for analysis. The sample chain-of-custodies and laboratory reports are attached.



Observations

The table below summarizes the main observations at each space visited on February 17, 2016.

Location	Summary of Observations
Room C-111; First Floor; ca. 750 ft ²	No occupant at the time of inspection; Two ceiling mounted AC units; Dropped ceiling and Terrazzo floor; No visible water leaks in the room; No visual signs of microbial growth, Mild odor; No visible dust on floor/ other surfaces; One ceiling tile was open on the ceiling.
Room B-105; First Floor; ca. 880 ft ²	Thirteen occupants at the time of inspection; Two ceiling mounted AC units; Dropped ceiling and Terrazzo floor; No visible water leaks in the room; No visual signs of microbial growth, No odor; No visible dust on floor/ other surfaces.
Corridor near B107; First Floor; ca. 870 ft ²	No occupants at the time of inspection; Dropped ceiling and tiled floor; No visible water leaks in the room; No visual signs of microbial growth, No odor; No visible dust on floor/ other surfaces.
Auditorium; First Floor; ca. 3000 ft ²	Thirty eight occupants at the time of inspection; 16 Ceiling mounted AC units; Drop ceiling and Rubber/Plastic tiled floor; No visible water leaks in the area; No visual signs of microbial growth, No odor; No visible dust on floor/ other surfaces.
Room A-102; First Floor; ca. 750 ft ²	Nineteen occupants at the time of inspection; Two ceiling mounted AC units; Dropped ceiling and wood floor; No visible water leaks in the room; No visual signs of microbial growth, No odor; Visible dust near the air diffusers on the ceiling; Two potted plants in the area.



Room A-206; Second Floor; ca. 760 ft ²	One occupant at the time of inspection; Two ceiling mounted AC units; Dropped ceiling and wood floor; No visible water leaks in the room; No visual signs of microbial growth, No odor; Visible dust near the air diffusers on the ceiling.
Room C201; Second Floor; ca. 810 ft ²	No occupants at the time of inspection; Dropped ceiling and Terrazzo floor; No visible water leaks in the room. No visual signs of microbial growth, No odor; Visible dust near the air diffusers on the ceiling.

Measurements of Indoor Environmental Quality Parameters

A summary of average measurements of comfort parameters and respirable particulates is provided in Table 1.

Temperature

The American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) have published recommendations for year round acceptable temperatures in Standard 55-2010 (*Thermal Environmental Conditions for Human Occupancy*). The winter comfort range is 20 to 24°C (68 to 75°F) and 23 to 26°C (73 to 79°F) is the summer comfort range. All the temperature readings fell within the ASHRAE recommended ranges.

Relative Humidity (RH)

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 60%. ASHRAE standard 62.1-2010 (*Ventilation for Acceptable Indoor Air Quality*) recommends a maximum indoor relative humidity of 65% to preclude the likelihood of condensation on cool surfaces encouraging mold growth. All RH measurements fell within the ASHRAE recommended range.

Carbon Monoxide

Carbon monoxide (CO) is a colorless and odorless gas that is produced by the incomplete combustion of carbon-containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of CO. All registered CO concentrations were below the EPA National Ambient Air Quality Standard (NAAQS) of 9 ppm.

Carbon Dioxide

Under conditions of maximum occupancy, ASHRAE Standard 62.1-2010, Appendix C, infers that the acceptable carbon dioxide upper limit is the prevailing outdoor carbon dioxide concentration plus 700 parts per million (ppm). On the day of the space evaluation, the outdoor (ambient) carbon dioxide concentration was approximately 530.0 ppm so indoor concentrations should not exceed approximately 1230 ppm (700 + 530). All indoor carbon dioxide measurements were within the ASHRAE standards.

Respirable Particulates

Respirable particulate concentrations under PM_{2.5} & PM₁₀ size classes were below their respective National Ambient Air Quality Standard (NAAQS) levels. The highest average PM_{2.5} concentration during the monitoring period was 0.003mg/m³ (3 µg/m³). This is compared to the NAAQS primary standard for PM_{2.5} of 12 µg/m³ annual mean. The highest average PM₁₀ concentration during the same period was 0.017 mg/m³ (17 µg/m³), in the class room A102. This is compared to NAAQS standard for PM₁₀ of 150µg/m³ 24 hr. average. <http://www.epa.gov/air/criteria.html>

**Table 1: Shepherd Elementary School, Measurements of Indoor Environmental Quality Parameters;
February 17, 2016. (09:30 AM- 11:50 AM)**

Sample Location	Temp °F	RH%	CO ppm	CO2 ppm	PM 2.5 mg/m ³	PM 10 mg/m ³
Standards	ASHRAE 68 to 75°F	ASHRAE <65%	NAAQS 9	ASHRAE 1230	NAAQS 0.012	NAAQS 0.150
Ambient	49.6	45.3	2.0	530.0	0.001	0.006
Class room C111	70.3	25.5	2.0	630.0	0.003	0.006
Class room B105	71.6	31.7	2.0	1063.0	0.002	0.020
Corridor near Rm B107	68.0	31.9	2.0	968.0	0.002	0.015
Auditorium	68.0	34.1	2.0	879.5	0.001	0.007
Class room A102	75.2	26.3	2.5	973.0	0.003	0.017
Class room A206	71.2	25.7	2.5	728.5	0.000	0.002
Class room C201	70.7	27.1	2.0	775.0	0.001	0.006



Mold-in-Air Samples

There are no definitive regulations or standardized guidelines for addressing airborne mold in an indoor setting. If building systems (ventilation, envelope) are functioning properly, the indoor population profile should mimic what is encountered outdoors and the concentrations should be below the ambient levels.

Table 2 summarizes airborne mold spore (non-viable) sampling results and locations. On the day of sampling, the indoor mold concentrations (spore count/m³ of air) in the areas tested were either non-detect or very low. Laboratory analysis follows this report (see attachment).

**Table 2: Shepherd Elementary School, Measurements of Mold-in-Air samples;
February 17, 2016. (09:30 AM- 11:50 AM)**

Sample Location	Ambient	Class room C111	Class room B105	Corridor near B107	Auditorium	Class room A102	Class room A206	Class room C201
<i>Iternaria</i>	-	-	-	-	-	-	-	-
<i>Ascospores</i>	-	-	-	-	10	40	-	-
<i>Aspergillus/Penicillium</i>	-	-	-	-	-	-	40	-
<i>Basidiospores</i>	-	40	-	-	-	-	-	-
<i>Bipolaris++</i>	-	-	-	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-	-	-	-
<i>Cladosporium</i>	-	-	-	-	-	-	-	-
<i>Curoualaria</i>	-	-	-	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-	-	-	-
<i>Fusarium</i>	-	-	-	-	-	-	-	-
<i>Gonoderma</i>	-	-	-	-	-	-	-	-
<i>Myxomycetes++</i>	-	-	40	-	-	10	-	-
<i>Pithomyces</i>	-	-	-	-	-	-	-	-
<i>Rust</i>	-	-	-	-	-	-	-	-
<i>Scopulariopsis</i>	-	-	-	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-	-	-	-
<i>Unidentifiable Spores</i>	-	-	-	-	-	-	-	-
<i>Zygomycetes</i>	-	-	-	-	-	-	-	-
<i>Hyphal Fragment</i>	-	10	-	-	10	-	-	-
<i>Insect Fragment</i>	-	-	-	-	-	-	-	-
<i>Pollen</i>	-	-	-	-	-	-	-	-
Total Molds	None Detect	50	40	None Detect	20	50	40	None Detect



1818 New York Avenue, N.E.
Washington, DC 20002

Telephone: (202) 832-1433
Fax: (202) 832-1434
www.gciusa.biz

Conclusions

The comfort parameters (i.e., temperature, relative humidity, carbon dioxide, and carbon monoxide levels) and respirable particulates in the areas of concern conform to ASHRAE and/or NAAQS guidelines. The indoor mold spore concentrations do not indicate any mold growth related air quality concerns. Based on the observations and results of the IAQ inspection at Shepherd Elementary School building, we have no further recommendations at this time.

Thank you for the opportunity to provide industrial hygiene services for the Department of General Services. If you have any questions, please contact me at 202.832.1433 (office).

Sincerely,

Channa Bambaradeniya, Ph.D., CIH, CHMM, PMP
Global Consulting, Inc.



1818 New York Avenue, N.E.
Washington, DC 20002

Telephone: (202) 832-1433
Fax: (202) 832-1434
www.gciusa.biz

Attachment

Mold Spore Sample Analytical Results and Chain-of-Custody

Forms



EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705
Tel/Fax: (301) 937-5700 / (301) 937-5701
<http://www.EMSL.com/beltsvillelab@emsl.com>

EMSL Order: 191601411
Customer ID: GLOC62
Customer PO:
Project ID:

Attn: Indika J.
Global Consulting, Inc.
1818 New York Avenue N.E.
Suite 107
Washington, DC 20002
Project: SHEPHERD ES - V0225

Phone: (202) 832-1433
Fax: (202) 832-1434
Collected: 02/17/2016
Received: 02/17/2016
Analyzed: 02/18/2016

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods EMSL 05-TP-003, ASTM D7391)

Lab Sample Number:	191601411-0001			191601411-0002			191601411-0003		
Client Sample ID:	SES-021716-001			SES-021716-002			SES-021716-003		
Volume (L):	75			75			75		
Sample Location	AMBIENT			C111			B105		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-
Basidiospores	-	-	-	1	40	100	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	1	40	100
Pithomyces	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis	-	-	-	-	-	-	-	-	-
Stachybotrys	-	-	-	-	-	-	-	-	-
Torula	-	-	-	-	-	-	-	-	-
Ulocladium	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Total Fungi	-	None Detect	-	1	40	100	1	40	100
Hyphal Fragment	-	-	-	1*	10*	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	41	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	2	-	-	4	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	2	-	-	2	-

Bipolaris++ = Bipolaris/Drechslera/Exserohilum
Myxomycetes++ = Myxomycetes/Periconia/Smut

Stefanie Schneider, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "*" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 02/18/2016 12:09:52

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705
Tel/Fax: (301) 937-5700 / (301) 937-5701
<http://www.EMSL.com/beltsvillelab@emsl.com>

EMSL Order: 191601411
Customer ID: GLOC62
Customer PO:
Project ID:

Attn: Indika J.
Global Consulting, Inc.
1818 New York Avenue N.E.
Suite 107
Washington, DC 20002
Project: SHEPHERD ES - V0225

Phone: (202) 832-1433
Fax: (202) 832-1434
Collected: 02/17/2016
Received: 02/17/2016
Analyzed: 02/18/2016

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods EMSL 05-TP-003, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	191601411-0004 SES-021716-004 75 CORRIDOR NEAR B107			191601411-0005 SES-021716-005 75 AUDITORIUM			191601411-0006 SES-021716-006 75 A102		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	1*	10*	100	1	40	80
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-
Basidiospores	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	1*	10*	20
Pithomyces	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis	-	-	-	-	-	-	-	-	-
Stachybotrys	-	-	-	-	-	-	-	-	-
Torula	-	-	-	-	-	-	-	-	-
Ulocladium	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Total Fungi	-	None Detect	-	1	10	100	2	50	100
Hyphal Fragment	-	-	-	1*	10*	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	41	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	4	-	-	3	-	-	4	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	2	-	-	2	-	-	2	-

Bipolaris++ = Bipolaris/Drechslera/Exserohilum
Myxomycetes++ = Myxomycetes/Periconia/Smut

Stefanie Schneider, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. ""*"" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 02/18/2016 12:09:52

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705
Tel/Fax: (301) 937-5700 / (301) 937-5701
<http://www.EMSL.com/beltsvillelab@emsl.com>

EMSL Order: 191601411
Customer ID: GLOC62
Customer PO:
Project ID:

Attn: Indika J.
Global Consulting, Inc.
1818 New York Avenue N.E.
Suite 107
Washington, DC 20002
Project: SHEPHERD ES - V0225

Phone: (202) 832-1433
Fax: (202) 832-1434
Collected: 02/17/2016
Received: 02/17/2016
Analyzed: 02/18/2016

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods EMSL 05-TP-003, ASTM D7391)

Lab Sample Number:	191601411-0007			191601411-0008			191601411-0009		
Client Sample ID:	SES-021716-007			SES-021716-008			SES-021716-009		
Volume (L):	75			75			0		
Sample Location	A206			C201			FIELD BLANK		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	1	40	100	-	-	-	-	-	-
Basidiospores	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis	-	-	-	-	-	-	-	-	-
Stachybotrys	-	-	-	-	-	-	-	-	-
Torula	-	-	-	-	-	-	-	-	-
Ulocladium	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Total Fungi	1	40	100	-	None Detect	-	-	No Trace	-
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	0	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	0*	-
Skin Fragments (1-4)	-	3	-	-	3	-	-	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	-	-
Background (1-5)	-	1	-	-	1	-	-	-	-

Bipolaris++ = Bipolaris/Drechslera/Exserohilum
Myxomycetes++ = Myxomycetes/Periconia/Smut

Stefanie Schneider, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "*" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 02/18/2016 12:09:52

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705
Tel/Fax: (301) 937-5700 / (301) 937-5701
<http://www.EMSL.com / beltsvillelab@emsl.com>

EMSL Order: 191601411
Customer ID: GLOC62
Customer PO:
Project ID:

Attn: Indika J.
Global Consulting, Inc.
1818 New York Avenue N.E.
Suite 107
Washington, DC 20002
Project: SHEPHERD ES - V0225

Phone: (202) 832-1433
Fax: (202) 832-1434
Collected: 02/17/2016
Received: 02/17/2016
Analyzed: 02/18/2016

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods EMSL 05-TP-003, ASTM D7391)

Lab Sample Number:	191601411-0010		
Client Sample ID:	SES-021716-010		
Volume (L):	0		
Sample Location:	FIELD BLANK		
Spore Types	Raw Count	Count/m³	% of Total
Alternaria	-	-	-
Ascospores	-	-	-
Aspergillus/Penicillium	-	-	-
Basidiospores	-	-	-
Bipolaris++	-	-	-
Chaetomium	-	-	-
Cladosporium	-	-	-
Curvularia	-	-	-
Epicoccum	-	-	-
Fusarium	-	-	-
Ganoderma	-	-	-
Myxomycetes++	-	-	-
Pithomyces	-	-	-
Rust	-	-	-
Scopulariopsis	-	-	-
Stachybotrys	-	-	-
Torula	-	-	-
Ulocladium	-	-	-
Unidentifiable Spores	-	-	-
Zygomycetes	-	-	-
Total Fungi	-	No Trace	-
Hyphal Fragment	-	-	-
Insect Fragment	-	-	-
Pollen	-	-	-
Analyt. Sensitivity 600x	-	0	-
Analyt. Sensitivity 300x	-	0*	-
Skin Fragments (1-4)	-	-	-
Fibrous Particulate (1-4)	-	-	-
Background (1-5)	-	-	-

Bipolaris++ = Bipolaris/Drechslera/Exserohilum
Myxomycetes++ = Myxomycetes/Periconia/Smut

Stefanie Schneider, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "*" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 02/18/2016 12:09:52

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

Microbiology Chain of Custody

EMSL Order Number (Lab Use Only):

191601411

PHONE:
FAX:

Company: <u>Global Consulting Inc.</u>		EMSL-Bill to: <input type="checkbox"/> Different <input type="checkbox"/> Same <small>If Bill to is Different note instructions in Comments**</small>	
Street: <u>1818 New York Ave. NE 11</u>		<small>Third Party Billing requires written authorization from third party</small>	
City: <u>Washington</u>	State/Province: <u>DC</u>	Zip/Postal Code: <u>20004</u>	Country:
Report To (Name): <u>Indika J.</u>		Telephone #: <u>202 800 9705</u>	
Email Address: <u>ijayatilake@gciusa.biz</u>		Fax #:	Purchase Order:
Project Name/Number: <u>Shepherd ES - V0225</u>		Please Provide Results: <input type="checkbox"/> FAX <input type="checkbox"/> E-mail <input type="checkbox"/> Mail	
U.S. State Samples Taken: <u>DC</u>		Connecticut Samples: <input type="checkbox"/> Commercial <input type="checkbox"/> Residential	

Turnaround Time (TAT) Options* - Please Check

3 Hour
 6 Hour
 24 Hour
 48 Hour
 72 Hour
 96 Hour
 1 Week
 2 Week

*Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements

Non Culturable Air Samples (Spore Traps) - Test Codes

- | | | | | |
|-------------------|-------------------|--------------------|---------------------|-------------------|
| • M001 Air-O-Cell | • M173 Allegro M2 | • M004 Allergenco | • M032 Allergenco-D | • M172 Versa Trap |
| • M049 BioSIS | • M003 Burkard | • M043 Cyclex | • M002 Cyclex-d | |
| • M030 Micro 5 | • M174 MoldSnap | • M176 Relle Smart | • M130 Via-Cell | |

Other Microbiology Test Codes

- | | | |
|---|--|--|
| <ul style="list-style-type: none"> • M041 Fungal Direct Examination • M005 Viable Fungi ID and Count • M006 Viable Fungi ID and Count (Speciation) • M007 Culturable Fungi • M008 Culturable Fungi (Speciation) • M009 Gram Stain Culturable Bacteria • M010 Bacterial Count and ID - 3 Most Prominent • M011 Bacterial Count and ID - 5 Most Prominent • M013 Sewage Contamination in Buildings | <ul style="list-style-type: none"> • M014 Endotoxin Analysis • M015 Heterotrophic Plate Count • M180 Real Time Q-PCR-ERMI 36 Panel • M018 Total Coliform (Membrane Filtration) • M020 Fecal Streptococcus (Membrane Filtration) • M210-215 Legionella Detection • M026 Recreational Water Screen • M027 Mycotoxin Analysis | <ul style="list-style-type: none"> • M029 Enterococci • M019 Fecal Coliform • M133 MRSA Analysis • M028 Cryptococcus neoformans Detection • M120 Histoplasma capsulatum Detection • M033-39 Allergen Testing • M044 Group Allergen (Cat, Dog, Cockroach, Dustmites) • Other See Analytical Price Guide |
|---|--|--|

Preservation Method (Water):

Name of Sampler: <u>Madhusha S.</u>	Signature of Sampler: 
-------------------------------------	---

Sample #	Sample Location	Sample Type	Test Code	Volume/Area	Date/Time Collected
Example A1	Kitchen	Air	M001	75L	1/1/16
SES-021716-001	Ambient	Air	M001	75L	2/17/16
-002	C111	↓	↓	↓	↓
003	B105	↓	↓	↓	↓
004	Corridor near B107	↓	↓	↓	↓
005	Auditorium	↓	↓	↓	↓
006	A102	↓	↓	↓	↓
007	A206	↓	↓	↓	↓
008	C201	↓	↓	↓	↓
009/10	Field blank	↓	↓	↓	↓

Client Sample # (s):	-	Total # of Samples:	
Relinquished (Client):	Date:	Time:	
Received (Client): 	Date: <u>2/18/16</u>	Time: <u>8:30 am</u>	<u>Drop</u>
Comments:			