



SHEPHERD LEAD WATER TEST RESULTS

May 11th, 2016



| | Building Location | Sample Collected Date | Water Source ID | Device Type | Floor | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date | Retest Results |
|----|----------------------------|-----------------------|-----------------|-------------|----------|---------------------------------------|----------------------|--------------------------------|----------------------|--------------------------------|-------------|-------------|----------------|
| 1 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000609 | Utility | Basement | Water source | WT-042916-626- A | 4.6 | WT-042916-626- B | 1.8 | | | |
| 2 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000610 | Cooler | Basement | In hallway adjacent to AG06 Left High | WT-042916-627- A | < 1 | WT-042916-627- B | < 1 | | | |
| 3 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000611 | Cooler | Basement | In hallway adjacent to AG06 Right Low | WT-042916-628- A | < 1 | WT-042916-628- B | < 1 | | | |
| 4 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000612 | Break Room | Basement | In teacher lounge | WT-042916-629- A | < 1 | WT-042916-629- B | < 1 | | | |
| 5 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000613 | Cooler | Basement | In room AG06 | WT-042916-630- A | < 1 | WT-042916-630- B | < 1 | | | |
| 6 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000614 | Cooler | Basement | In cafeteria | WT-042916-631- A | < 1 | WT-042916-631- B | < 1 | | | |
| 7 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000615 | Kitchen | Basement | In kitchen Low | WT-042916-632- A | 1.4 | WT-042916-632- B | < 1 | | | |
| 8 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000616 | Kitchen | Basement | In kitchen (spray nozzle) High | WT-042916-633- A | < 1 | WT-042916-633- B | < 1 | | | |
| 9 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000617 | Kitchen | Basement | In kitchen, handwash station | WT-042916-634- A | 11.4 | WT-042916-634- B | 2.3 | | | |
| 10 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000618 | Fountain | 1 | In classroom A106 Right | WT-042916-635- A | < 1 | WT-042916-635- B | < 1 | | | |
| 11 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000619 | Classroom | 1 | In room A106 Left | WT-042916-636- A | < 1 | WT-042916-636- B | < 1 | | | |
| 12 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000620 | Cooler | 1 | In hallway adjacent to A106 | WT-042916-637- A | < 1 | WT-042916-637- B | < 1 | | | |
| 13 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000621 | Classroom | 1 | In room A103 Left | WT-042916-638- A | < 1 | WT-042916-638- B | < 1 | | | |
| 14 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000622 | Fountain | 1 | In classroom A103 Right | WT-042916-639- A | < 1 | WT-042916-639- B | < 1 | | | |
| 15 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000623 | Cooler | 1 | In hallway adjacent to A101 | WT-042916-640- A | < 1 | WT-042916-640- B | < 1 | | | |
| 16 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000624 | Classroom | 1 | In room A101 Left | WT-042916-641- A | < 1 | WT-042916-641- B | < 1 | | | |
| 17 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000625 | Fountain | 1 | In room A101 Right | WT-042916-642- A | < 1 | WT-042916-642- B | < 1 | | | |
| 18 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000626 | Classroom | 1 | In room A102 Left | WT-042916-643- A | < 1 | WT-042916-643- B | < 1 | | | |
| 19 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000627 | Fountain | 1 | In room A102 Right | WT-042916-644- A | < 1 | WT-042916-644- B | < 1 | | | |
| 20 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000628 | Cooler | 1 | In hallway adjacent to B105 Left High | WT-042916-645- A | < 1 | WT-042916-645- B | < 1 | | | |
| 21 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000629 | Cooler | 1 | In hallway adjacent to B105 Right Low | WT-042916-646- A | < 1 | WT-042916-646- B | < 1 | | | |
| 22 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000630 | Fountain | 1 | In room C102 | WT-042916-647- A | < 1 | WT-042916-647- B | < 1 | | | |
| 23 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000631 | Other | 1 | In office room C105 | WT-042916-648- A | < 1 | WT-042916-648- B | < 1 | | | |
| 24 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000632 | Other | 1 | In room C105 icemaker in fridge | WT-042916-649- A | 1.6 | WT-042916-649- B | 1.5 | | | |
| 25 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000633 | Cooler | 1 | In hallway adjacent to C109 Left High | WT-042916-650- A | < 1 | WT-042916-650- B | < 1 | | | |



SHEPHERD LEAD WATER TEST RESULTS

May 11th, 2016



| | Building Location | Sample Collected Date | Water Source ID | Device Type | Floor | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date | Retest Results |
|----|----------------------------|-----------------------|-----------------|--------------|-------|---|----------------------|--------------------------------|----------------------|--------------------------------|-------------|-------------|----------------|
| 26 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000634 | Cooler | 1 | In hallway adjacent C109 Right Low | WT-042916-651- A | < 1 | WT-042916-651- B | < 1 | | | |
| 27 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000635 | Health Suite | 1 | C108B Left | WT-042916-652- A | < 1 | WT-042916-652- B | < 1 | | | |
| 28 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000637 | Fountain | 1 | In room C108B Right | WT-042916-654- A | < 1 | WT-042916-654- B | < 1 | | | |
| 29 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000638 | Fountain | 1 | In room 111 Right | WT-042916-655- A | < 1 | WT-042916-655- B | < 1 | | | |
| 30 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000639 | Classroom | 1 | In room C111 Left | WT-042916-656- A | < 1 | WT-042916-656- B | < 1 | | | |
| 31 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000640 | Classroom | 1 | In room 110 Left | WT-042916-657- A | < 1 | WT-042916-657- B | < 1 | | | |
| 32 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000641 | Fountain | 1 | In room 110 Right | WT-042916-658- A | < 1 | WT-042916-658- B | < 1 | | | |
| 33 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000642 | Cooler | 2 | In hallway adjacent to C212 & C211 Left High | WT-042916-659- A | < 1 | WT-042916-659- B | < 1 | | | |
| 34 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000643 | Cooler | 2 | In hallway adjacent to room C212 & C211 Right Low | WT-042916-660- A | < 1 | WT-042916-660- B | < 1 | | | |
| 35 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000644 | Classroom | 2 | In room C204 Left | WT-042916-661- A | < 1 | WT-042916-661- B | < 1 | | | |
| 36 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000645 | Fountain | 2 | In room C204 Right | WT-042916-662- A | 1.3 | WT-042916-662- B | < 1 | | | |
| 37 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000646 | Classroom | 2 | In room C203 Left | WT-042916-663- A | 1.6 | WT-042916-663- B | < 1 | | | |
| 38 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000647 | Fountain | 2 | In room C206 Right | WT-042916-664- A | < 1 | WT-042916-664- B | < 1 | | | |
| 39 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000648 | Cooler | 2 | In hallway adjacent to C203 Left High | WT-042916-665- A | < 1 | WT-042916-665- B | < 1 | | | |
| 40 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000649 | Cooler | 2 | In hallway adjacent to C203 Right Low | WT-042916-666- A | < 1 | WT-042916-666- B | < 1 | | | |
| 41 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000650 | Cooler | 2 | In hallway adjacent to A210 | WT-042916-667- A | < 1 | WT-042916-667- B | < 1 | | | |
| 42 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000651 | Classroom | 2 | In room A205 Left | WT-042916-668- A | < 1 | WT-042916-668- B | < 1 | | | |
| 43 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000652 | Fountain | 2 | In room 205 | WT-042916-669- A | < 1 | WT-042916-669- B | < 1 | | | |
| 44 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000653 | Cooler | 2 | In hallway adjacent to A201 | WT-042916-670- A | < 1 | WT-042916-670- B | < 1 | | | |
| 45 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000654 | Classroom | 2 | In room A201 Left | WT-042916-671- A | < 1 | WT-042916-671- B | < 1 | | | |
| 46 | SHEPHERD ELEMENTARY SCHOOL | 4/30/2016 | WS- 000655 | Classroom | 2 | In room A201 Right | WT-042916-672- A | < 1 | WT-042916-672- B | < 1 | | | |

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.