



SIMON ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	SIMON ELEMENTARY SCHOOL	WS- 010293	8/12/2016	1	Cooler	In hallway adjacent to room 105	FT-82016-010293-A	< 1	FT-82016-010293-B	< 1
2	SIMON ELEMENTARY SCHOOL	WS- 010294	8/12/2016	1	Cooler	In hallway adjacent to room 116	FT-82016-010294-A	< 1	FT-82016-010294-B	< 1
3	SIMON ELEMENTARY SCHOOL	WS- 010296	8/12/2016	1	Fountain	In classroom 115	FT-82016-010296-A	< 1	FT-82016-010296-B	< 1
4	SIMON ELEMENTARY SCHOOL	WS- 010298	8/12/2016	1	Fountain	In classroom 114	FT-82016-010298-A	< 1	FT-82016-010298-B	< 1
5	SIMON ELEMENTARY SCHOOL	WS- 010299	8/12/2016	2	Cooler	In hallway adjacent to room 211	FT-82016-010299-A	< 1	FT-82016-010299-B	1.4
			10/10/2016				Re-test A	< 1	Re-test B	< 1
6	SIMON ELEMENTARY SCHOOL	WS- 010300	8/12/2016	2	Cooler	In hallway adjacent to room 205	FT-82016-010300-A	< 1	FT-82016-010300-B	< 1
7	SIMON ELEMENTARY SCHOOL	WS- 010302	8/12/2016	3	Cooler	In hallway adjacent to room 305	FT-82016-010302-A	< 1	FT-82016-010302-B	< 1
8	SIMON ELEMENTARY SCHOOL	WS- 010303	8/12/2016	3	Cooler	In hallway adjacent to room 309	FT-82016-010303-A	< 1	FT-82016-010303-B	< 1
9	SIMON ELEMENTARY SCHOOL	WS- 010304	8/12/2016	Ground Floor	Cooler	In hallway adjacent to room 013	FT-82016-010304-A	< 1	FT-82016-010304-B	< 1
10	SIMON ELEMENTARY SCHOOL	WS- 010306	8/12/2016	Ground Floor	Fountain	In classroom 014	FT-82016-010306-A	< 1	FT-82016-010306-B	< 1
11	SIMON ELEMENTARY SCHOOL	WS- 010307	8/12/2016	Ground Floor	Fountain	In classroom 015	FT-82016-010307-A	< 1	FT-82016-010307-B	< 1
12	SIMON ELEMENTARY SCHOOL	WS- 010309	8/12/2016	Ground Floor	Health Suite	In health suite 013	FT-82016-010309-A	< 1	FT-82016-010309-B	< 1
13	SIMON ELEMENTARY SCHOOL	WS- 010311	8/12/2016	Ground Floor	Food Prep Sink	In kitchen	FT-82016-010311-A	< 1	FT-82016-010311-B	< 1
14	SIMON ELEMENTARY SCHOOL	WS- 010313	8/12/2016	Ground Floor	Cooler	In hallway adjacent to room 003	FT-82016-010313-A	< 1	FT-82016-010313-B	< 1
15	SIMON ELEMENTARY SCHOOL	WS- 010316	8/12/2016	Ground Floor	Fountain	In classroom 001	FT-82016-010316-A	< 1	FT-82016-010316-B	< 1