



SMOTHERS LEAD WATER TEST RESULTS

May 15, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001599	Utility	Basement	In boiler room (water source)	WT-042916-1616- A	4.5	WT-042916-1616- B	< 1				
2	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001600	Cooler	3	In hallway adjacent to room 310	WT-042916-1617- A	< 1	WT-042916-1617- B	< 1				
3	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001601	Break Room	3	In breakroom, left wall adjacent to refrigerator	WT-042916-1618- A	< 1	WT-042916-1618- B	< 1				
4	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001602	Cooler	3	In hallway adjacent to 301	WT-042916-1619- A	< 1	WT-042916-1619- B	< 1				
5	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001603	Bathroom	2	In health suite bathroom (sink)	WT-042916-1620- A	1.8	WT-042916-1620- B	1.1				
6	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001604	Cooler	2	In hallway adjacent to room 201	WT-042916-1621- A	< 1	WT-042916-1621- B	< 1				
7	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001605	Cooler	2	In hallway adjacent to room 212	WT-042916-1622- A	< 1	WT-042916-1622- B	< 1				
8	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001606	Cooler	1	In hallway adjacent to room 108	WT-042916-1623- A	< 1	WT-042916-1623- B	< 1				
9	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001607	Kitchen	1	In kitchen, north wall	WT-042916-1624- A	< 1	WT-042916-1624- B	< 1				
10	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001608	Kitchen	1	In kitchen, north wall	WT-042916-1625- A	< 1	WT-042916-1625- B	< 1				
11	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001609	Kitchen	1	In kitchen, east wall	WT-042916-1626- A	< 1	WT-042916-1626- B	< 1				
12	SMOTHERS ELEMENTARY SCHOOL	5/3/2016	WS-001613	Cooler	1	In hallway adjacent to room 104	WT-042916-1630- A	< 1	WT-042916-1630- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.