



# STEAD REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	STEAD RECREATION CENTER	WS- 006535	9/22/2016	2	Cooler	In hallway adjacent to restrooms	FT-82016-006535-A	< 1	FT-82016-006535-B	< 1
2	STEAD RECREATION CENTER	WS- 006536**	9/22/2016	2	Food Prep Sink	In kitchen	FT-82016-006536-A	1.2	FT-82016-006536-B	< 1
			10/7/2016				Re-test A	< 1	Re-test B	< 1
3	STEAD RECREATION CENTER	WS- 006537	9/22/2016	1	Cooler	In computer room	FT-82016-006537-A	< 1	FT-82016-006537-B	< 1

\*\*Filters and plumbing checked and filters re-tested.