



THOMAS ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	THOMAS ELEMENTARY SCHOOL	WS- 002323	8/9/2016	1	Cooler	In cafeteria	FT-72016-002323-A	< 1	FT-72016-002323-B	< 1
2	THOMAS ELEMENTARY SCHOOL	WS- 008770	8/9/2016	1	Cooler	In health suite	FT-72016-008770-A	< 1	FT-72016-008770-B	< 1
3	THOMAS ELEMENTARY SCHOOL	WS- 008771	8/9/2016	1	Health Suite	In health suite	FT-72016-008771-A	< 1	FT-72016-008771-B	< 1
4	THOMAS ELEMENTARY SCHOOL	WS- 008772	8/9/2016	1	Cooler	In hallway adjacent to health suite High Left	FT-82016-008772-A	< 1	FT-82016-008772-B	< 1
5	THOMAS ELEMENTARY SCHOOL	WS- 008773	8/9/2016	1	Cooler	In hallway adjacent to health suite Low Right	FT-82016-008773-A	< 1	FT-82016-008773-B	< 1
6	THOMAS ELEMENTARY SCHOOL	WS- 008776	8/9/2016	1	Cooler	In hallway adjacent room 109 Low Left	FT-82016-008776-A	< 1	FT-82016-008776-B	< 1
7	THOMAS ELEMENTARY SCHOOL	WS- 008777	8/9/2016	1	Cooler	In hallway adjacent room 109 High Right	FT-72016-008777-A	< 1	FT-72016-008777-B	< 1
8	THOMAS ELEMENTARY SCHOOL	WS- 008785	8/9/2016	1	Food Prep Sink	In kitchen fourth clockwise from entry door	FT-72016-008785-A	< 1	FT-72016-008785-B	< 1
9	THOMAS ELEMENTARY SCHOOL	WS- 008786	8/9/2016	1	Food Prep Sink	In kitchen fifth clockwise from entry door Right	FT-72016-008786-A	< 1	FT-72016-008786-B	< 1
10	THOMAS ELEMENTARY SCHOOL	WS- 008787	8/9/2016	1	Cooler	In hallway adjacent to multi-purpose room	FT-72016-008787-A	< 1	FT-72016-008787-B	< 1
11	THOMAS ELEMENTARY SCHOOL	WS- 008788	8/9/2016	1	Cooler	In multi-purpose room	FT-72016-008788-A	< 1	FT-72016-008788-B	< 1
12	THOMAS ELEMENTARY SCHOOL	WS- 008789	8/9/2016	1	Cooler	In hallway adjacent to restrooms	FT-72016-008789-A	< 1	FT-72016-008789-B	< 1
13	THOMAS ELEMENTARY SCHOOL	WS- 008791	8/9/2016	2	Cooler	In hallway adjacent to room 201 High Left	FT-72016-008791-A	< 1	FT-72016-008791-B	< 1
14	THOMAS ELEMENTARY SCHOOL	WS- 008792	8/9/2016	2	Cooler	In hallway adjacent to room 201 Low Right	FT-82016-008792-A	< 1	FT-82016-008792-B	< 1
15	THOMAS ELEMENTARY SCHOOL	WS- 008801	8/9/2016	2	Cooler	In hallway adjacent to room 209 High Left	FT-72016-008801-A	< 1	FT-72016-008801-B	< 1
16	THOMAS ELEMENTARY SCHOOL	WS- 008802	8/9/2016	2	Cooler	In hallway adjacent to room 209 Low Right	FT-82016-008802-A	< 1	FT-82016-008802-B	< 1
17	THOMAS ELEMENTARY SCHOOL	WS- 008804	8/9/2016	2	Cooler	In hallway adjacent to room 220	FT-72016-008804-A	< 1	FT-72016-008804-B	< 1
18	THOMAS ELEMENTARY SCHOOL	WS- 008808	8/9/2016	2	Cooler	In hallway adjacent to room 214	FT-72016-008808-A	< 1	FT-72016-008808-B	< 1
19	THOMAS ELEMENTARY SCHOOL	WS- 008811	8/9/2016	3	Cooler	In hallway adjacent to room 309 High Left	FT-72016-008811-A	< 1	FT-72016-008811-B	< 1
20	THOMAS ELEMENTARY SCHOOL	WS- 008812	8/9/2016	3	Cooler	In hallway adjacent to room 309 Low Right	FT-82016-008812-A	< 1	FT-82016-008812-B	< 1
21	THOMAS ELEMENTARY SCHOOL	WS- 008813	8/9/2016	3	Cooler	In hallway adjacent to room 300 High Left	FT-72016-008813-A	< 1	FT-72016-008813-B	< 1
22	THOMAS ELEMENTARY SCHOOL	WS- 008814	8/9/2016	3	Cooler	In hallway adjacent to room 300 Low Right	FT-82016-008814-A	< 1	FT-82016-008814-B	< 1