



THOMSON LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
1	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000548	Classroom	2	Second floor in art class room 225 RHS Right	WT-042916-565- A	2.1	WT-042916-565- B	1.3			
2	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000547	Classroom	2	Second floor in classroom 225 Left	WT-042916-564- A	1.3	WT-042916-564- B	< 1			
3	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000546	Kitchen	2	Second floor in staff lounge	WT-042916-563- A	< 1	WT-042916-563- B	< 1			
4	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000545	Classroom	1	First floor in office suite parent resource center	WT-042916-562- A	< 1	WT-042916-562- B	< 1			
5	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000544	Kitchen	1	Basement in kitchen third from the left Right High	WT-042916-561- A	< 1	WT-042916-561- B	< 1			
6	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000543	Kitchen	1	Basement in kitchen second from the left Mid	WT-042916-560- A	< 1	WT-042916-560- B	< 1			
7	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000542	Kitchen	1	Basement in kitchen hand wash device Right Low	WT-042916-559- A	< 1	WT-042916-559- B	< 1			
8	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000541	Kitchen	1	Basement in kitchen first from left Left Low	WT-042916-558- A	< 1	WT-042916-558- B	< 1			
9	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000540	Cooler	1	Basement in cafeteria Right Low	WT-042916-557- A	< 1	WT-042916-557- B	< 1			
10	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000539	Cooler	1	Basement in cafeteria Left High	WT-042916-556- A	< 1	WT-042916-556- B	< 1			
11	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000538	Cooler	3	Third floor in hallway across room 322 Left High	WT-042916-555- A	< 1	WT-042916-555- B	< 1			
12	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000537	Cooler	3	Third floor in hallway across room 322 Right Low	WT-042916-554- A	< 1	WT-042916-554- B	< 1			
13	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000536	Fountain	3	Third floor in classroom 307 Right	WT-042916-553- A	< 1	WT-042916-553- B	< 1			
14	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000535	Classroom	3	Third floor in classroom 307 Right	WT-042916-552- A	< 1	WT-042916-552- B	< 1			
15	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000533	Classroom	3	Third floor in classroom 308 Left	WT-042916-550- A	2.5	WT-042916-550- B	< 1			
16	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000532	Fountain	3	Third floor in classroom 310 Right	WT-042916-549- A	< 1	WT-042916-549- B	< 1			
17	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000531	Classroom	3	Third floor in classroom 310 Left	WT-042916-548- A	4.9	WT-042916-548- B	< 1			
18	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000530	Fountain	3	Third floor in classroom 309 Right	WT-042916-547- A	< 1	WT-042916-547- B	< 1			
19	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000529	Classroom	3	Third floor in classroom 309 Left	WT-042916-546- A	2	WT-042916-546- B	< 1			
20	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000528	Fountain	2	Second floor in classroom 219 Right	WT-042916-545- A	< 1	WT-042916-545- B	< 1			
21	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000527	Classroom	2	Second floor in classroom 219 Left	WT-042916-544- A	< 1	WT-042916-544- B	< 1			
22	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000526	Fountain	2	Second floor in classroom 220 Right	WT-042916-543- A	< 1	WT-042916-543- B	< 1			
23	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000525	Classroom	2	Second floor in classroom 220 Right	WT-042916-542- A	< 1	WT-042916-542- B	< 1			
24	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000524	Fountain	2	Second floor in classroom 221 Right	WT-042916-541- A	1.8	WT-042916-541- B	< 1			
25	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000523	Classroom	2	Second floor classroom 221 Left	WT-042916-540- A	< 1	WT-042916-540- B	< 1			



THOMSON LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
26	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000522	Fountain	2	Second floor in classroom 223 Right	WT-042916-539- A	< 1	WT-042916-539- B	< 1			
27	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000521	Classroom	2	Second floor in classroom 223 Left	WT-042916-538- A	< 1	WT-042916-538- B	< 1			
28	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000520	Cooler	2	Second floor in hallway adjacent to room 201 Right Low	WT-042916-537- A	< 1	WT-042916-537- B	< 1			
29	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000519	Cooler	2	Second floor in hallway adjacent to room 201 Right Low	WT-042916-536- A	< 1	WT-042916-536- B	< 1			
30	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000518	Fountain	2	Second floor in classroom 208 Right	WT-042916-535- A	< 1	WT-042916-535- B	< 1			
31	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000517	Classroom	2	Second floor in classroom 208 Left	WT-042916-534- A	< 1	WT-042916-534- B	< 1			
32	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000516	Fountain	2	Second floor in classroom 211 Right	WT-042916-533- A	< 1	WT-042916-533- B	< 1			
33	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000515	Classroom	2	Second floor in classroom 211 Left	WT-042916-532- A	1.2	WT-042916-532- B	< 1			
34	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000514	Fountain	2	Second floor in classroom 209 Right	WT-042916-531- A	< 1	WT-042916-531- B	< 1			
35	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000513	Classroom	2	Second floor in classroom 209 Left	WT-042916-530- A	1.1	WT-042916-530- B	1			
36	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000512	Classroom	2	Second floor in room 210 Left	WT-042916-529- A	1.3	WT-042916-529- B	< 1			
37	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000511	Fountain	2	Second floor in room 210 Right	WT-042916-528- A	< 1	WT-042916-528- B	< 1			
38	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000508	Classroom	1	First floor in classroom113 Left	WT-042916-525- A	< 1	WT-042916-525- B	< 1			
39	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000507	Fountain	1	First floor in classroom 114 Right	WT-042916-524- A	< 1	WT-042916-524- B	< 1			
40	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000506	Classroom	1	First floor in room 114 Left	WT-042916-523- A	1.2	WT-042916-523- B	< 1			
41	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000505	Fountain	1	First floor in room 115 Right	WT-042916-522- A	< 1	WT-042916-522- B	< 1			
42	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000504	Classroom	1	First floor in classroom 115 Left	WT-042916-521- A	< 1	WT-042916-521- B	< 1			
43	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000503	Classroom	1	First floor in classroom112 Left	WT-042916-520- A	< 1	WT-042916-520- B	< 1			
44	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000502	Fountain	1	First floor in classroom 112 Right	WT-042916-519- A	< 1	WT-042916-519- B	< 1			
45	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000501	Health Suite	1	First floor in treatment room 110 Mid	WT-042916-518- A	< 1	WT-042916-518- B	< 1			
46	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000500	Cooler	1	First floor in hallway adjacent to room 129 Right Low	WT-042916-517- A	< 1	WT-042916-517- B	< 1			
47	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000499	Cooler	1	First floor in hallway adjacent to room 130 Left High	WT-042916-516- A	< 1	WT-042916-516- B	< 1			
48	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000498	Classroom	1	First floor in classroom 127 Left	WT-042916-515- A	< 1	WT-042916-515- B	< 1			
49	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000497	Fountain	1	First floor in classroom 127 Right	WT-042916-514- A	< 1	WT-042916-514- B	< 1			
50	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000496	Fountain	1	First floor classroom 126 Right	WT-042916-513- A	< 1	WT-042916-513- B	< 1			



THOMSON LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
51	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000495	Classroom	1	First floor in classroom 126 Left	WT-042916-512- A	< 1	WT-042916-512- B	< 1			
52	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000494	Fountain	1	First floor in classroom 124 Right	WT-042916-511- A	< 1	WT-042916-511- B	< 1			
53	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000493	Classroom	1	First floor in classroom 124 Left	WT-042916-510- A	< 1	WT-042916-510- B	< 1			
54	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000492	Fountain	1	First floor in classroom 123 Right	WT-042916-509- A	< 1	WT-042916-509- B	< 1			
55	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000491	Classroom	1	First floor in classroom 123 Left	WT-042916-508- A	6.6	WT-042916-508- B	1.3			
56	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000490	Classroom	Basement	Ground floor in room G02	WT-042916-507- A	< 1	WT-042916-507- B	5.1			
57	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000489	Cooler	Basement	Ground floor in hallway adjacent to room G02 Right Low	WT-042916-506- A	2.9	WT-042916-506- B	8.3			
58	THOMSON ELEMENTARY SCHOOL	4/30/2016	WS- 000488	Cooler	Basement	Ground floor in hallway adjacent to room G02 Left High	WT-042916-505- A	3.8	WT-042916-505- B	4.3			

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.