



# TURKEY THICKET REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	TURKEY THICKET RECREATION CENTER	WS- 005503	9/22/2016	1	Cooler	In pool area across from men's locker room High	FT-82016-005503-A	< 1	FT-82016-005503-B	< 1
2	TURKEY THICKET RECREATION CENTER	WS- 005504**	9/22/2016	1	Cooler	In pool area across from men's locker room Low	FT-82016-005504-A	1.6	FT-82016-005504-B	< 1
			10/7/2016				Re-test A	< 1	Re-test B	< 1
3	TURKEY THICKET RECREATION CENTER	WS- 005505	9/22/2016	1	Food Prep Sink	In kitchen 104	FT-82016-005505-A	< 1	FT-82016-005505-B	< 1
4	TURKEY THICKET RECREATION CENTER	WS- 005506	9/22/2016	1	Food Prep Sink	In multi-purpose room 102	FT-82016-005506-A	< 1	FT-82016-005506-B	< 1
5	TURKEY THICKET RECREATION CENTER	WS- 005507	9/22/2016	1	Cooler	In lobby adjacent to weights and exercise room 118 High	FT-82016-005507-A	< 1	FT-82016-005507-B	< 1
6	TURKEY THICKET RECREATION CENTER	WS- 005508	9/22/2016	1	Cooler	In lobby adjacent to weights and exercise room 119 Low	FT-82016-005508-A	< 1	FT-82016-005508-B	< 1

\*\*Filters and plumbing checked and filters re-tested.