



# TURNER ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	TURNER ELEMENTARY SCHOOL	WS- 003842	8/12/2016	1	Cooler	In hallway adjacent to room 102	High Left FT-82016-003842-A	< 1	FT-82016-003842-B	< 1
2	TURNER ELEMENTARY SCHOOL	WS- 003843	8/12/2016	1	Cooler	In hallway adjacent to room 102	Low Right FT-72016-003843-A	< 1	FT-72016-003843-B	< 1
3	TURNER ELEMENTARY SCHOOL	WS- 003844	8/12/2016	1	Fountain	In classroom 106	Left FT-82016-003844-A	< 1	FT-82016-003844-B	< 1
4	TURNER ELEMENTARY SCHOOL	WS- 003845	8/12/2016	1	Classroom Faucet	In classroom 106	Mid FT-82016-003845-A	< 1	FT-82016-003845-B	< 1
5	TURNER ELEMENTARY SCHOOL	WS- 003849	8/12/2016	1	Fountain	In classroom 107	Right FT-72016-003849-A	< 1	FT-72016-003849-B	< 1
6	TURNER ELEMENTARY SCHOOL	WS- 003852	8/12/2016	1	Fountain	In classroom 108	Right FT-82016-003852-A	< 1	FT-82016-003852-B	< 1
7	TURNER ELEMENTARY SCHOOL	WS- 003853	8/12/2016	1	Cooler	In hallway adjacent to room 110	High Left FT-72016-003853-A	< 1	FT-72016-003853-B	< 1
8	TURNER ELEMENTARY SCHOOL	WS- 003854	8/12/2016	1	Bottle Filler	In hallway adjacent to room 110 (bottle filler)	Low Right FT-82016-003854-A	< 1	FT-82016-003854-B	< 1
9	TURNER ELEMENTARY SCHOOL	WS- 003856	8/12/2016	1	Fountain	In classroom 109B	Right FT-82016-003856-A	< 1	FT-82016-003856-B	< 1
10	TURNER ELEMENTARY SCHOOL	WS- 003858	8/12/2016	1	Fountain	In classroom 109A	Right FT-72016-003858-A	< 1	FT-72016-003858-B	< 1
11	TURNER ELEMENTARY SCHOOL	WS- 003860	8/12/2016	1	Fountain	In classroom 113	Left FT-72016-003860-A	< 1	FT-72016-003860-B	< 1
12	TURNER ELEMENTARY SCHOOL	WS- 003863	8/12/2016	1	Classroom Faucet	In classroom 112	Mid FT-72016-003863-A	< 1	FT-72016-003863-B	< 1
13	TURNER ELEMENTARY SCHOOL	WS- 003865	8/12/2016	1	Fountain	In classroom 112	Right FT-82016-003865-A	< 1	FT-82016-003865-B	< 1
14	TURNER ELEMENTARY SCHOOL	WS- 003866	8/12/2016	1	Cooler	In hallway adjacent to elevator	High Left FT-72016-003866-A	< 1	FT-72016-003866-B	< 1
15	TURNER ELEMENTARY SCHOOL	WS- 003867	8/12/2016	1	Cooler	In hallway adjacent to elevator	Low Right FT-72016-003867-A	< 1	FT-72016-003867-B	< 1
16	TURNER ELEMENTARY SCHOOL	WS- 003869	8/12/2016	1	Fountain	In classroom 116	Low Right FT-72016-003869-A	< 1	FT-72016-003869-B	< 1
17	TURNER ELEMENTARY SCHOOL	WS- 003872	8/12/2016	1	Classroom Faucet	In classroom 117	Mid FT-72016-003872-A	< 1	FT-72016-003872-B	< 1
18	TURNER ELEMENTARY SCHOOL	WS- 003873**	8/12/2016 8/20/2016	1	Fountain	In classroom 117	Low Right FT-72016-003873-A Re-test A	41.7 < 1	FT-72016-003873-B Re-test B	< 1 < 1
19	TURNER ELEMENTARY SCHOOL	WS- 003874	8/12/2016 10/10/2016	1	Health Suite	In health suite	FT-82016-003874-A Re-test A	< 1 2.2	FT-82016-003874-B Re-test B	2.9 < 1
20	TURNER ELEMENTARY SCHOOL	WS- 003875	8/12/2016	1	Cooler	In hallway adjacent to stairwell A	Low Right FT-72016-003875-A	< 1	FT-72016-003875-B	< 1
21	TURNER ELEMENTARY SCHOOL	WS- 003876	8/12/2016	1	Cooler	In hallway adjacent to stairwell A	High Left FT-72016-003876-A	< 1	FT-72016-003876-B	< 1
22	TURNER ELEMENTARY SCHOOL	WS- 003878	8/12/2016	1	Food Prep Sink	In servery room in kitchen on south wall	FT-72016-003878-A	< 1	FT-72016-003878-B	< 1
23	TURNER ELEMENTARY SCHOOL	WS- 003883	8/12/2016	1	Cooler	In hallway adjacent to room 131	High Left FT-82016-003883-A	< 1	FT-82016-003883-B	< 1
24	TURNER ELEMENTARY SCHOOL	WS- 003884	8/12/2016	1	Cooler	In hallway adjacent to room 131	Low Right FT-72016-003884-A	< 1	FT-72016-003884-B	< 1
25	TURNER ELEMENTARY SCHOOL	WS- 003885	8/12/2016	2	Cooler	In hallway adjacent to stairwell A	High Left FT-72016-003885-A	< 1	FT-72016-003885-B	< 1
26	TURNER ELEMENTARY SCHOOL	WS- 003886	8/12/2016	2	Cooler	In hallway adjacent to stairwell A	Low Right FT-72016-003886-A	< 1	FT-72016-003886-B	< 1
27	TURNER ELEMENTARY SCHOOL	WS- 003894	8/12/2016	2	Cooler	In hallway adjacent to stairwell B	High Left FT-82016-003894-A	< 1	FT-82016-003894-B	< 1
28	TURNER ELEMENTARY SCHOOL	WS- 003895	8/12/2016	2	Cooler	In hallway adjacent to stairwell B	Low Right FT-72016-003895-A	< 1	FT-72016-003895-B	< 1
29	TURNER ELEMENTARY SCHOOL	WS- 003897	8/12/2016	2	Cooler	In hallway adjacent to media center	High Left FT-72016-003897-A	< 1	FT-72016-003897-B	< 1
30	TURNER ELEMENTARY SCHOOL	WS- 003898	8/12/2016	2	Cooler	In hallway adjacent to media center	Low Right FT-72016-003898-A	< 1	FT-72016-003898-B	< 1
31	TURNER ELEMENTARY SCHOOL	WS- 003900	8/12/2016	2	Cooler	In hallway adjacent to room 202	High Left FT-72016-003900-A	< 1	FT-72016-003900-B	< 1
32	TURNER ELEMENTARY SCHOOL	WS- 003901	8/12/2016	2	Cooler	In hallway adjacent to room 202	Low Right FT-72016-003901-A	< 1	FT-72016-003901-B	< 1
33	TURNER ELEMENTARY SCHOOL	WS- 003902	8/12/2016	3	Cooler	In hallway adjacent to room 302	High Left FT-72016-003902-A	< 1	FT-72016-003902-B	< 1
34	TURNER ELEMENTARY SCHOOL	WS- 003903	8/12/2016	3	Cooler	In hallway adjacent to room 302	Low Right FT-72016-003903-A	< 1	FT-72016-003903-B	< 1
35	TURNER ELEMENTARY SCHOOL	WS- 003908	8/12/2016	3	Cooler	In hallway adjacent to room 313	High Left FT-72016-003908-A	< 1	FT-72016-003908-B	< 1
36	TURNER ELEMENTARY SCHOOL	WS- 003912	8/12/2016	3	Cooler	In hallway adjacent to room 313	Low Right FT-72016-003912-A	< 1	FT-72016-003912-B	< 1
37	TURNER ELEMENTARY SCHOOL	WS- 003914	8/12/2016	3	Cooler	In hallway adjacent to room 316	High Left FT-72016-003914-A	< 1	FT-72016-003914-B	< 1
38	TURNER ELEMENTARY SCHOOL	WS- 003915	8/12/2016	3	Cooler	In hallway adjacent to room 316	Low Right FT-72016-003915-A	< 1	FT-72016-003915-B	< 1
39	TURNER ELEMENTARY SCHOOL	WS- 003924	8/12/2016	3	Cooler	In hallway adjacent to stairwell A	High Left FT-82016-003924-A	< 1	FT-82016-003924-B	< 1
40	TURNER ELEMENTARY SCHOOL	WS- 003925	8/13/2016	3	Cooler	In hallway adjacent to stairwell A	Low Right FT-72016-003925-A	< 1	FT-72016-003925-B	< 1
41	TURNER ELEMENTARY SCHOOL	WS- 003926	8/13/2016	Basement	Fountain	In art room B06 first clockwise from entry door	FT-82016-003926-A	< 1	FT-82016-003926-B	< 1
42	TURNER ELEMENTARY SCHOOL	WS- 003927	8/13/2016	Basement	Classroom Faucet	In art room B06 first clockwise from entry door	FT-72016-003927-A	< 1	FT-72016-003927-B	< 1

\*\*Filter inspected, found improperly installed, repaired, and re-sampled.