



# TYLER LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-009997	Utility	Basement	In boiler room (main water source)	WT-042916-10014-A	< 1	WT-042916-10014-B	< 1				
2 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-009998	Cooler	Basement	In lunch room	WT-042916-10015-A	< 1	WT-042916-10015-B	< 1				
3 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-009999	Kitchen	Basement	In kitchen	WT-042916-10016-A	< 1	WT-042916-10016-B	< 1				
4 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010000	Kitchen	Basement	In kitchen	WT-042916-10017-A	< 1	WT-042916-10017-B	< 1				
5 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010001	Cooler	1	In hallway adjacent to room 120	WT-042916-10018-A	< 1	WT-042916-10018-B	< 1				
6 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010002	Cooler	1	In hallway adjacent to room 120	WT-042916-10019-A	< 1	WT-042916-10019-B	< 1				
7 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010003	Break Room	1	In staff lounge	WT-042916-10020-A	< 1	WT-042916-10020-B	< 1				
8 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010004	Classroom	1	In art room	WT-042916-10021-A	< 1	WT-042916-10021-B	< 1				
9 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010005	Classroom	1	In art room	WT-042916-10022-A	< 1	WT-042916-10022-B	< 1				
10 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010006	Cooler	1	In hallway adjacent to main office	WT-042916-10023-A	591	WT-042916-10023-B	31	Filtered	7/1/2016	<1	<1
11 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010007	Cooler	1	In hallway adjacent to main office	WT-042916-10024-A	11	WT-042916-10024-B	22	Filtered	7/1/2016	<1	<1
12 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010008	Classroom	1	In room 110	WT-042916-10025-A	< 1	WT-042916-10025-B	< 1				
13 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010009	Classroom	1	In room 109	WT-042916-10026-A	< 1	WT-042916-10026-B	< 1				
14 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010010	Health Suite	1	In health suite	WT-042916-10027-A	< 1	WT-042916-10027-B	< 1				
15 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010011	Classroom	1	In room 124	WT-042916-10028-A	< 1	WT-042916-10028-B	< 1				
16 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010012	Classroom	1	In room 125	WT-042916-10029-A	< 1	WT-042916-10029-B	< 1				
17 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010013	Classroom	1	In room 127	WT-042916-10030-A	< 1	WT-042916-10030-B	< 1				
18 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010014	Classroom	1	In room 145	WT-042916-10031-A	< 1	WT-042916-10031-B	< 1				
19 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010015	Classroom	1	In room 129	WT-042916-10032-A	< 1	WT-042916-10032-B	< 1				
20 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010016	Classroom	1	In room 144	WT-042916-10033-A	< 1	WT-042916-10033-B	< 1				
21 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010017	Cooler	1	In hallway adjacent to room 144	WT-042916-10034-A	< 1	WT-042916-10034-B	< 1				
22 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010018	Cooler	1	In hallway adjacent to room 144	WT-042916-10035-A	< 1	WT-042916-10035-B	< 1				
23 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010019	Classroom	1	In room 142	WT-042916-10036-A	< 1	WT-042916-10036-B	< 1				
24 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010020	Classroom	1	In room 131	WT-042916-10037-A	< 1	WT-042916-10037-B	< 1				
25 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010021	Cooler	1	In hallway adjacent to room 138	WT-042916-10038-A	< 1	WT-042916-10038-B	< 1				
26 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010022	Cooler	1	In hallway adjacent to room 138	WT-042916-10039-A	< 1	WT-042916-10039-B	< 1				
27 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010024	Classroom	1	In room 132	WT-042916-10041-A	< 1	WT-042916-10041-B	< 1				
28 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010025	Classroom	1	In room 135	WT-042916-10042-A	< 1	WT-042916-10042-B	< 1				
29 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010026	Classroom	1	In room 134	WT-042916-10043-A	< 1	WT-042916-10043-B	< 1				
30 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010027	Classroom	2	In room 209	WT-042916-10044-A	< 1	WT-042916-10044-B	< 1				
31 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010028	Classroom	2	In room 207	WT-042916-10045-A	< 1	WT-042916-10045-B	< 1				
32 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010029	Classroom	2	In room 206	WT-042916-10046-A	< 1	WT-042916-10046-B	< 1				
33 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010030	Classroom	2	In room 210	WT-042916-10047-A	< 1	WT-042916-10047-B	< 1				
34 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010031	Cooler	2	In hallway adjacent to staff restroom	WT-042916-10048-A	< 1	WT-042916-10048-B	< 1				
35 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010032	Cooler	2	In hallway across from boy's washroom	WT-042916-10049-A	< 1	WT-042916-10049-B	< 1				
36 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010033	Classroom	2	In room 202	WT-042916-10050-A	< 1	WT-042916-10050-B	< 1				
37 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010034	Classroom	2	In room 215	WT-042916-10051-A	< 1	WT-042916-10051-B	< 1				
38 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010035	Classroom	2	In room 216	WT-042916-10052-A	< 1	WT-042916-10052-B	< 1				
39 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010036	Classroom	2	In room 201	WT-042916-10053-A	< 1	WT-042916-10053-B	< 1				
40 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010037	Classroom	2	In room 217	WT-042916-10054-A	2	WT-042916-10054-B	4				
41 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010038	Classroom	3	In room 310	WT-042916-10055-A	< 1	WT-042916-10055-B	< 1				
42 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010039	Classroom	3	In room 308	WT-042916-10056-A	< 1	WT-042916-10056-B	< 1				
43 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010040	Classroom	3	In room 307	WT-042916-10057-A	< 1	WT-042916-10057-B	< 1				
44 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010041	Classroom	3	In room 311	WT-042916-10058-A	< 1	WT-042916-10058-B	< 1				
45 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010042	Classroom	3	In room 306	WT-042916-10059-A	< 1	WT-042916-10059-B	< 1				
46 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010043	Classroom	3	In room 304	WT-042916-10060-A	< 1	WT-042916-10060-B	< 1				
47 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010044	Cooler	3	In hallway adjacent to room 304	WT-042916-10061-A	< 1	WT-042916-10061-B	< 1				
48 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010045	Classroom	3	In room 302	WT-042916-10062-A	< 1	WT-042916-10062-B	< 1				
49 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010046	Classroom	3	In room 316	WT-042916-10063-A	< 1	WT-042916-10063-B	< 1				
50 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010047	Classroom	3	In room 317	WT-042916-10064-A	3	WT-042916-10064-B	1				
51 TYLER ELEMENTARY SCHOOL	5/12/2016	WS-010048	Classroom	3	In room 301	WT-042916-10065-A	< 1	WT-042916-10065-B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.