



UPSHUR LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	UPSHUR	WS- 005026	9/21/2016	1	Cooler	In lobby adjacent to closet	FT-82016-005026-A	< 1	FT-82016-005026-B	< 1
2	UPSHUR	WS- 005027	9/22/2016	1	Food Prep Sink	In kitchen	FT-82016-005027-A	< 1	FT-82016-005027-B	< 1