



WALKER-JONES EC LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
1	WALKER-JONES EC	5/3/2016	WS- 002158	Classroom	3	In classroom 325 Left	WT-042916-2175- A	< 1	WT-042916-2175- B	< 1			
2	WALKER-JONES EC	5/3/2016	WS- 002157	Classroom	3	In room 320 Left	WT-042916-2174- A	< 1	WT-042916-2174- B	< 1			
3	WALKER-JONES EC	5/3/2016	WS- 002156	Classroom	3	In classroom 325 Right	WT-042916-2173- A	< 1	WT-042916-2173- B	< 1			
4	WALKER-JONES EC	5/3/2016	WS- 002155	Fountain	3	In room 320 Right	WT-042916-2172- A	2.6	WT-042916-2172- B	< 1			
5	WALKER-JONES EC	5/3/2016	WS- 002154	Classroom	3	In classroom 324 Mid	WT-042916-2171- A	5.1	WT-042916-2171- B	< 1			
6	WALKER-JONES EC	5/3/2016	WS- 002153	Fountain	3	In classroom 324 Right	WT-042916-2170- A	2.2	WT-042916-2170- B	< 1			
7	WALKER-JONES EC	5/3/2016	WS- 002152	Classroom	3	In room 324 Left	WT-042916-2169- A	< 1	WT-042916-2169- B	< 1			
8	WALKER-JONES EC	5/3/2016	WS- 002151	Fountain	3	In room 324 Right	WT-042916-2168- A	< 1	WT-042916-2168- B	< 1			
9	WALKER-JONES EC	5/3/2016	WS- 002150	Classroom	3	In classroom 324 Left	WT-042916-2167- A	< 1	WT-042916-2167- B	< 1			
10	WALKER-JONES EC	5/3/2016	WS- 002149	Fountain	3	In classroom 324 Right	WT-042916-2166- A	1	WT-042916-2166- B	< 1			
11	WALKER-JONES EC	5/3/2016	WS- 002148	Fountain	3	In room 320 Right	WT-042916-2165- A	4	WT-042916-2165- B	< 1			
12	WALKER-JONES EC	5/3/2016	WS- 002147	Classroom	3	In room 320 Left	WT-042916-2164- A	7.2	WT-042916-2164- B	1.1			
13	WALKER-JONES EC	5/3/2016	WS- 002146	Fountain	3	In room 320 Right	WT-042916-2163- A	< 1	WT-042916-2163- B	< 1			
14	WALKER-JONES EC	5/3/2016	WS- 002145	Classroom	3	In room 320 Left	WT-042916-2162- A	15.4	WT-042916-2162- B	< 1	Filtration		
15	WALKER-JONES EC	5/3/2016	WS- 002144	Classroom	3	In room 320 Left	WT-042916-2161- A	13.3	WT-042916-2161- B	< 1			
16	WALKER-JONES EC	5/3/2016	WS- 002143	Fountain	3	In room 320 Right	WT-042916-2160- A	5.8	WT-042916-2160- B	1.1			
17	WALKER-JONES EC	5/3/2016	WS- 002142	Classroom	3	In room 320 Left	WT-042916-2159- A	7.1	WT-042916-2159- B	1.6			
18	WALKER-JONES EC	5/3/2016	WS- 002141	Fountain	3	In room 320 Right	WT-042916-2158- A	4.6	WT-042916-2158- B	< 1			
19	WALKER-JONES EC	5/3/2016	WS- 002140	Fountain	3	In room 310 Right	WT-042916-2157- A	89.6	WT-042916-2157- B	2.6	Filtration		
20	WALKER-JONES EC	5/3/2016	WS- 002139	Classroom	3	In room 310 Left	WT-042916-2156- A	4.1	WT-042916-2156- B	1.9			
21	WALKER-JONES EC	5/3/2016	WS- 002138	Classroom	3	In classroom 310 Left	WT-042916-2155- A	269	WT-042916-2155- B	13.4	Filtration		
22	WALKER-JONES EC	5/3/2016	WS- 002137	Fountain	3	In classroom 310 Right	WT-042916-2154- A	29.8	WT-042916-2154- B	2.9	Filtration		
23	WALKER-JONES EC	5/3/2016	WS- 002136	Classroom	3	In classroom 310 Left	WT-042916-2153- A	452	WT-042916-2153- B	12	Filtration		
24	WALKER-JONES EC	5/3/2016	WS- 002135	Fountain	3	In classroom 310 Right	WT-042916-2152- A	168	WT-042916-2152- B	9.7	Filtration		



WALKER-JONES EC LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
25	WALKER-JONES EC	5/3/2016	WS- 002134	Classroom	3	In classroom 300 Left	WT-042916-2151- A	< 1	WT-042916-2151- B	< 1			
26	WALKER-JONES EC	5/3/2016	WS- 002133	Fountain	3	In classroom 300 Right	WT-042916-2150- A	< 1	WT-042916-2150- B	< 1			
27	WALKER-JONES EC	5/3/2016	WS- 002132	Fountain	3	in hallway adjacent to room 309 Right Low	WT-042916-2149- A	< 1	WT-042916-2149- B	< 1			
28	WALKER-JONES EC	5/3/2016	WS- 002131	Cooler	3	In hallway adjacent to room 312 Left High	WT-042916-2148- A	< 1	WT-042916-2148- B	< 1			
29	WALKER-JONES EC	5/3/2016	WS- 002130	Fountain	2	In classroom 206 Left	WT-042916-2147- A	< 1	WT-042916-2147- B	< 1			
30	WALKER-JONES EC	5/3/2016	WS- 002129	Classroom	2	In classroom 206 Right	WT-042916-2146- A	< 1	WT-042916-2146- B	< 1			
31	WALKER-JONES EC	5/3/2016	WS- 002128	Classroom	2	In classroom 201 Left	WT-042916-2145- A	< 1	WT-042916-2145- B	< 1			
32	WALKER-JONES EC	5/3/2016	WS- 002127	Fountain	2	In classroom 201 Right	WT-042916-2144- A	< 1	WT-042916-2144- B	1			
33	WALKER-JONES EC	5/3/2016	WS- 002126	Classroom	2	In classroom 208 Left	WT-042916-2143- A	1.1	WT-042916-2143- B	< 1			
34	WALKER-JONES EC	5/3/2016	WS- 002125	Fountain	2	In classroom 208 Right	WT-042916-2142- A	3.3	WT-042916-2142- B	< 1			
35	WALKER-JONES EC	5/3/2016	WS- 002124	Classroom	2	In classroom 203 Left	WT-042916-2141- A	< 1	WT-042916-2141- B	< 1			
36	WALKER-JONES EC	5/3/2016	WS- 002123	Fountain	2	In classroom 203 Right	WT-042916-2140- A	< 1	WT-042916-2140- B	< 1			
37	WALKER-JONES EC	5/3/2016	WS- 002122	Classroom	2	In classroom 210 Left	WT-042916-2139- A	< 1	WT-042916-2139- B	< 1			
38	WALKER-JONES EC	5/3/2016	WS- 002121	Fountain	2	In classroom 210 Right	WT-042916-2138- A	< 1	WT-042916-2138- B	1			
39	WALKER-JONES EC	5/3/2016	WS- 002118	Classroom	2	In classroom 212 Left	WT-042916-2135- A	< 1	WT-042916-2135- B	< 1			
40	WALKER-JONES EC	5/3/2016	WS- 002117	Fountain	2	In classroom 212 Right	WT-042916-2134- A	1	WT-042916-2134- B	< 1			
41	WALKER-JONES EC	5/3/2016	WS- 002116	Fountain	2	In hallway adjacent to classroom 209 Left	WT-042916-2133- A	< 1	WT-042916-2133- B	< 1			
42	WALKER-JONES EC	5/3/2016	WS- 002115	Fountain	2	In hallway adjacent to Classroom 209 Right	WT-042916-2132- A	< 1	WT-042916-2132- B	< 1			
43	WALKER-JONES EC	5/3/2016	WS- 002114	Classroom	2	In classroom 220 Left	WT-042916-2131- A	< 1	WT-042916-2131- B	< 1			
44	WALKER-JONES EC	5/3/2016	WS- 002113	Fountain	2	In classroom 220 Right	WT-042916-2130- A	1.3	WT-042916-2130- B	< 1			
45	WALKER-JONES EC	5/3/2016	WS- 002112	Classroom	2	In classroom 217 Mid	WT-042916-2129- A	< 1	WT-042916-2129- B	< 1			
46	WALKER-JONES EC	5/3/2016	WS- 002111	Fountain	2	In classroom 217 Right	WT-042916-2128- A	< 1	WT-042916-2128- B	< 1			
47	WALKER-JONES EC	5/3/2016	WS- 002110	Fountain	2	In classroom 222 Right	WT-042916-2127- A	< 1	WT-042916-2127- B	< 1			
48	WALKER-JONES EC	5/3/2016	WS- 002109	Classroom	2	In classroom 222 Left	WT-042916-2126- A	< 1	WT-042916-2126- B	< 1			



WALKER-JONES EC LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
49	WALKER-JONES EC	5/3/2016	WS- 002108	Classroom	2	In classroom 219 Mid	WT-042916-2125- A	3.5	WT-042916-2125- B	< 1			
50	WALKER-JONES EC	5/3/2016	WS- 002107	Fountain	2	In classroom 219 Right	WT-042916-2124- A	< 1	WT-042916-2124- B	< 1			
51	WALKER-JONES EC	5/3/2016	WS- 002106	Fountain	2	In classroom 224 Right	WT-042916-2123- A	< 1	WT-042916-2123- B	< 1			
52	WALKER-JONES EC	5/3/2016	WS- 002105	Classroom	2	In classroom 224 Left	WT-042916-2122- A	< 1	WT-042916-2122- B	< 1			
53	WALKER-JONES EC	5/3/2016	WS- 002104	Classroom	2	In Classroom 221 Mid	WT-042916-2121- A	< 1	WT-042916-2121- B	< 1			
54	WALKER-JONES EC	5/3/2016	WS- 002103	Fountain	2	In Classroom 221 Right	WT-042916-2120- A	< 1	WT-042916-2120- B	< 1			
55	WALKER-JONES EC	5/3/2016	WS- 002102	Classroom	2	In Classroom 226 Left	WT-042916-2119- A	< 1	WT-042916-2119- B	< 1			
56	WALKER-JONES EC	5/3/2016	WS- 002101	Fountain	2	In classroom 226 Right	WT-042916-2118- A	< 1	WT-042916-2118- B	< 1			
57	WALKER-JONES EC	5/3/2016	WS- 002100	Fountain	2	In classroom 226 Right	WT-042916-2117- A	5.7	WT-042916-2117- B	< 1			
58	WALKER-JONES EC	5/3/2016	WS- 002099	Classroom	2	In classroom 226 Left	WT-042916-2116- A	< 1	WT-042916-2116- B	5.2			
59	WALKER-JONES EC	5/3/2016	WS- 002098	Classroom	2	In classroom 227 Left	WT-042916-2115- A	< 1	WT-042916-2115- B	< 1			
60	WALKER-JONES EC	5/3/2016	WS- 002097	Fountain	2	In classroom 227 Right	WT-042916-2114- A	1.5	WT-042916-2114- B	< 1			
61	WALKER-JONES EC	5/3/2016	WS- 002096	Classroom	2	In classroom 230C Mid High	WT-042916-2113- A	2.6	WT-042916-2113- B	< 1			
62	WALKER-JONES EC	5/3/2016	WS- 002095	Fountain	2	In classroom 230C Right	WT-042916-2112- A	< 1	WT-042916-2112- B	< 1			
63	WALKER-JONES EC	5/3/2016	WS- 002094	Classroom	Basement	In Training room 043 Mid	WT-042916-2111- A	1.3	WT-042916-2111- B	3.5			
64	WALKER-JONES EC	5/3/2016	WS- 002093	Fountain	Basement	In Training room 043 Right	WT-042916-2110- A	2.2	WT-042916-2110- B	11.8			
65	WALKER-JONES EC	5/3/2016	WS- 002092	Fountain	Basement	In classroom 036 Right	WT-042916-2109- A	4.3	WT-042916-2109- B	< 1			
66	WALKER-JONES EC	5/3/2016	WS- 002091	Classroom	Basement	In classroom 036 Left	WT-042916-2108- A	< 1	WT-042916-2108- B	< 1			
67	WALKER-JONES EC	5/3/2016	WS- 002090	Classroom	Basement	In Classroom 034 Mid	WT-042916-2107- A	< 1	WT-042916-2107- B	< 1			
68	WALKER-JONES EC	5/3/2016	WS- 002089	Fountain	Basement	In Classroom 034	WT-042916-2106- A	3	WT-042916-2106- B	< 1			
69	WALKER-JONES EC	5/3/2016	WS- 002088	Fountain	Basement	In classroom 032 Left	WT-042916-2105- A	< 1	WT-042916-2105- B	< 1			
70	WALKER-JONES EC	5/3/2016	WS- 002087	Classroom	Basement	In classroom 032 Left	WT-042916-2104- A	1	WT-042916-2104- B	1.4			
71	WALKER-JONES EC	5/3/2016	WS- 002086	Fountain	Basement	In hallway Adjacent to room 041 Mid	WT-042916-2103- A	< 1	WT-042916-2103- B	< 1			
72	WALKER-JONES EC	5/3/2016	WS- 002085	Fountain	Basement	In hallway adjacent to room 041 Mid	WT-042916-2102- A	< 1	WT-042916-2102- B	< 1			



WALKER-JONES EC LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
73	WALKER-JONES EC	5/3/2016	WS- 002084	Health Suite	1	In health suite 123A	Left	WT-042916-2101- A	< 1	WT-042916-2101- B	< 1			
74	WALKER-JONES EC	5/3/2016	WS- 002083	Fountain	1	In health suite 123A	Right	WT-042916-2100- A	< 1	WT-042916-2100- B	< 1			
75	WALKER-JONES EC	5/3/2016	WS- 002082	Fountain	1	In Classroom 126	Mid	WT-042916-2099- A	2	WT-042916-2099- B	< 1			
76	WALKER-JONES EC	5/3/2016	WS- 002081	Fountain	1	In classroom 126	Right	WT-042916-2098- A	1.7	WT-042916-2098- B	< 1			
77	WALKER-JONES EC	5/3/2016	WS- 002080	Fountain	1	In classroom 128	Right	WT-042916-2097- A	< 1	WT-042916-2097- B	< 1			
78	WALKER-JONES EC	5/3/2016	WS- 002079	Classroom	1	In classroom 128	Left	WT-042916-2096- A	3.5	WT-042916-2096- B	< 1			
79	WALKER-JONES EC	5/3/2016	WS- 002078	Fountain	1	In classroom 119	Right Low	WT-042916-2095- A	< 1	WT-042916-2095- B	< 1			
80	WALKER-JONES EC	5/3/2016	WS- 002077	Fountain	1	In classroom 119	Mid	WT-042916-2094- A	< 1	WT-042916-2094- B	< 1			
81	WALKER-JONES EC	5/3/2016	WS- 002076	Classroom	1	In classroom 117	Left	WT-042916-2093- A	< 1	WT-042916-2093- B	< 1			
82	WALKER-JONES EC	5/3/2016	WS- 002075	Fountain	1	In classroom 117	Right	WT-042916-2092- A	< 1	WT-042916-2092- B	< 1			
83	WALKER-JONES EC	5/3/2016	WS- 002074	Fountain	1	In classroom 122	Right	WT-042916-2091- A	< 1	WT-042916-2091- B	< 1			
84	WALKER-JONES EC	5/3/2016	WS- 002073	Classroom	1	In classroom 122	Left	WT-042916-2090- A	< 1	WT-042916-2090- B	< 1			
85	WALKER-JONES EC	5/3/2016	WS- 002072	Fountain	1	In classroom 120	Right	WT-042916-2089- A	87.3	WT-042916-2089- B	< 1	Filtration		
86	WALKER-JONES EC	5/3/2016	WS- 002071	Classroom	1	In classroom 120	Left	WT-042916-2088- A	< 1	WT-042916-2088- B	< 1			
87	WALKER-JONES EC	5/3/2016	WS- 002070	Fountain	1	In classroom 115	Right	WT-042916-2087- A	< 1	WT-042916-2087- B	< 1			
88	WALKER-JONES EC	5/3/2016	WS- 002069	Classroom	1	In classroom 115	Left	WT-042916-2086- A	3.7	WT-042916-2086- B	< 1			
89	WALKER-JONES EC	5/3/2016	WS- 002068	Classroom	1	In room 112	Left	WT-042916-2085- A	< 1	WT-042916-2085- B	< 1			
90	WALKER-JONES EC	5/3/2016	WS- 002067	Fountain	1	In room 112	Right	WT-042916-2084- A	< 1	WT-042916-2084- B	< 1			
91	WALKER-JONES EC	5/3/2016	WS- 002066	Cooler	1	In hallway adjacent to room 11	Right Low	WT-042916-2083- A	< 1	WT-042916-2083- B	< 1			
92	WALKER-JONES EC	5/3/2016	WS- 002065	Cooler	1	In hallway adjacent to room 11	Left High	WT-042916-2082- A	< 1	WT-042916-2082- B	< 1			
93	WALKER-JONES EC	5/3/2016	WS- 002064	Classroom	1	In classroom 108	Mid	WT-042916-2081- A	< 1	WT-042916-2081- B	< 1			
94	WALKER-JONES EC	5/3/2016	WS- 002063	Fountain	1	In classroom 108	Right	WT-042916-2080- A	< 1	WT-042916-2080- B	< 1			
95	WALKER-JONES EC	5/3/2016	WS- 002062	Fountain	1	In classroom 106	Right	WT-042916-2079- A	< 1	WT-042916-2079- B	< 1			
96	WALKER-JONES EC	5/3/2016	WS- 002061	Classroom	1	In classroom 106	Left	WT-042916-2078- A	< 1	WT-042916-2078- B	< 1			



WALKER-JONES EC LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
97	WALKER-JONES EC	5/3/2016	WS- 002060	Classroom	1	In class room 103 Left	WT-042916-2077- A	< 1	WT-042916-2077- B	< 1			
98	WALKER-JONES EC	5/3/2016	WS- 002059	Classroom	1	In classroom 105 Right	WT-042916-2076- A	< 1	WT-042916-2076- B	< 1			
99	WALKER-JONES EC	5/3/2016	WS- 002058	Fountain	1	In classroom 105 Right	WT-042916-2075- A	< 1	WT-042916-2075- B	< 1			
100	WALKER-JONES EC	5/3/2016	WS- 002057	Fountain	1	In classroom 103 Right	WT-042916-2074- A	< 1	WT-042916-2074- B	< 1			
101	WALKER-JONES EC	5/3/2016	WS- 002056	Classroom	1	In classroom 104 Mid Low	WT-042916-2073- A	< 1	WT-042916-2073- B	< 1			
102	WALKER-JONES EC	5/3/2016	WS- 002055	Fountain	1	In class room 104 Right	WT-042916-2072- A	< 1	WT-042916-2072- B	< 1			
103	WALKER-JONES EC	5/3/2016	WS- 002054	Kitchen	1	In kitchen south wall (spray nozzle) Right	WT-042916-2071- A	1.3	WT-042916-2071- B	< 1			
104	WALKER-JONES EC	5/3/2016	WS- 002053	Kitchen	1	In kitchen south wall Mid	WT-042916-2070- A	< 1	WT-042916-2070- B	< 1			
105	WALKER-JONES EC	5/3/2016	WS- 002052	Kitchen	1	In kitchen south wall Left	WT-042916-2069- A	< 1	WT-042916-2069- B	< 1			
106	WALKER-JONES EC	5/3/2016	WS- 002051	Other	1	In kitchen ice machine next to room 101E	WT-042916-2068- A	< 1	WT-042916-2068- B	< 1			
107	WALKER-JONES EC	5/3/2016	WS- 002050	Kitchen	1	In kitchen east wall Left	WT-042916-2067- A	< 1	WT-042916-2067- B	< 1			
108	WALKER-JONES EC	5/3/2016	WS- 002049	Utility	Basement	In room 051 main water supply line to the building NE corner (water source)	WT-042916-2066- A	68.8	WT-042916-2066- B	2.8	Non-drinking Water Source Flush		

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.