

WASH METRO HS LEAD WATER TEST RESULTS elev+te

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
	WASHINGTON METROPOLITAN HIGH									
1	SCHOOL @ LEWIS	WS- 011967	8/22/2016	1	Cooler	In hallway adjacent to boys' restroom	FT-82016-011967-A	< 1	FT-82016-011967-B	< 1
2	WASHINGTON METROPOLITAN HIGH	WS- 011968	8/22/2016	1	Cooler	In hallway adjacent to room 106	FT-82016-011968-A	< 1	FT-82016-011968-B	1.2
2	SCHOOL @ LEWIS	VV3=011908	10/10/2016	1	COOIEI	In hallway adjacent to room 100	Re-test A	< 1	Re-test B	< 1
	WASHINGTON METROPOLITAN HIGH									
3	SCHOOL @ LEWIS	WS- 011969	8/22/2016	1	Ice Maker	In kitchen (ice maker)	FT-82016-011969-A	< 1	FT-82016-011969-B	< 1
	WASHINGTON METROPOLITAN HIGH									
4	SCHOOL @ LEWIS	WS- 011972	8/22/2016	1	Food Prep Sink	In kitchen third clockwise from entry door Right	FT-72016-011972-A	< 1	FT-72016-011972-B	< 1
	WASHINGTON METROPOLITAN HIGH									
5	SCHOOL @ LEWIS	WS- 011973	8/22/2016	2	Cooler	In hallway adjacent to boys' restroom	FT-82016-011973-A	< 1	FT-82016-011973-B	< 1
	WASHINGTON METROPOLITAN HIGH									
6	SCHOOL @ LEWIS	WS- 011974	8/22/2016	2	Cooler	In hallway adjacent to room 210	FT-82016-011974-A	< 1	FT-82016-011974-B	< 1
	WASHINGTON METROPOLITAN HIGH									
7	SCHOOL @ LEWIS	WS- 011975	8/22/2016	3	Cooler	In hallway adjacent to room 312	FT-82016-011975-A	< 1	FT-82016-011975-B	< 1
	WASHINGTON METROPOLITAN HIGH									
8	SCHOOL @ LEWIS	WS- 011976	8/22/2016	3	Cooler	In hallway adjacent to room 303	FT-82016-011976-A	< 1	FT-82016-011976-B	< 1
	WASHINGTON METROPOLITAN HIGH									
9	SCHOOL @ LEWIS	WS- 011981	8/22/2016	1	Health Suite	In health suite in restroom	FT-82016-011981-A	< 1	FT-82016-011981-B	< 1