

WEST EC LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	WEST EDUCATIONAL CAMPUS	WS- 002846	12/13/2016	Ground Floor	Classroom Faucet	In classroom Pre-K West, in support	FT-122016-002846-A	< 1	FT-122016-002846-B	< 1
2	WEST EDUCATIONAL CAMPUS	WS- 010176	12/13/2016	Ground Floor	Classroom Faucet	In classroom Pre-K West Left	FT-122016-010176-A	1.5	FT-122016-010176-B	< 1
3	WEST EDUCATIONAL CAMPUS	WS- 010177	12/13/2016	Ground Floor	Classroom Faucet	In classroom Pre-K West Mid	FT-122016-010177-A	2	FT-122016-010177-B	< 1
4	WEST EDUCATIONAL CAMPUS	WS- 010179	12/13/2016	Ground Floor	Classroom Faucet	In classroom Pre-K West Righ	FT-122016-010179-A	< 1	FT-122016-010179-B	1.1
5	WEST EDUCATIONAL CAMPUS	WS- 010185	12/13/2016	Ground Floor	Classroom Faucet	In classroom Pre-K East Righ	FT-122016-010185-A	< 1	FT-122016-010185-B	< 1
6	WEST EDUCATIONAL CAMPUS	WS- 010188	12/13/2016	Ground Floor	Classroom Faucet	In classroom Pre-K East Mid	FT-122016-010188-A	< 1	FT-122016-010188-B	< 1
7	WEST EDUCATIONAL CAMPUS	WS- 010189	12/13/2016	Ground Floor	Classroom Faucet	In classroom Pre-K East Left	FT-122016-010189-A	< 1	FT-122016-010189-B	< 1
8	WEST EDUCATIONAL CAMPUS	WS- 010216	12/13/2016	2	Break Room	In staff lounge	FT-102016-010216-A	< 1	FT-102016-010216-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

WEST EDUCATIONAL CAMPUS	WS- 010176	1/25/2017	Ground Floor	Classroom Faucet	In classroom Pre-K West	Left	FT-122016-010176-A	9.5	FT-122016-010176-B	< 1
WEST EDUCATIONAL CAMPUS	WS- 010177	1/25/2017	Ground Floor	Classroom Faucet	In classroom Pre-K West	Mid	FT-122016-010177-A	7.6	FT-122016-010177-B	< 1
WEST EDUCATIONAL CAMPUS	WS- 010179	1/25/2017	Ground Floor	Classroom Faucet	In classroom Pre-K West	Right	FT-122016-010179-A	2	FT-122016-010179-B	< 1