

GOVERNMENT OF THE DISTRICT OF COLUMBIA  
DEPARTMENT OF GENERAL SERVICES



---

SYSTEMIC UPGRADES  
AT THE  
WARD 1 SENIOR WELLNESS CENTER


Solicitation No.: DCAM-13-CS-0130

Addendum No. 3  
Issued: April 8, 2013

This Addendum No. 3 is issued and hereby published on the DGS website on April 8, 2013. Except as modified hereby, the Request for Proposals ("RFP") remains unmodified.

**Item #1 Request For Information (RFI's)**

See the attached responses to the Offeror's Request for Information (RFI's).

By:   
JW Lanum  
Associate Director/ Contracting Officer

Date: 4/8/13

- End of Addendum No. 3 -

**DCAM-13-CS-0130**  
**SYSTEMIC UPGRADES AT THE WARD 1 SENIOR WELLNESS CENTER**

**REQUEST FOR INFORMATION (RFI'S)**

**RESPONSE TO OFFEROR RFI'S:**

- Q-1. The Drawing SK-05 indicates that a Vertical Duplex Grinder Sewage Ejector Pump must be installed, and Section 22446 Part 2.3 of the Specifications indicates that a Simplex Vertical Sewage Pump must be installed. We could not locate a Manufacture of a Vertical Grinder Sewage Pump to meet the Specifications required. In order to meet the 40 gpm requirement in a "grinder" pump we need to use a Sewage Pump with 3450 rpm/ 2 hp/230 v/1ph/60cy.

***Response:*** The Zoeller Dual Pump System Model 267-.5 Hp can be used as the basis of design. The company Little Giant has a similar model as well.

- Q-2. We will be recommending/supplying Two (2) Submersible Zoeller Duplex Grinder Sewage Ejector Pump Systems. Each pump is rated to deliver 40 gpm at 15' TDH – 2 hp – 3450 rpm – 230v/1ph/60cy

***Response:*** See Response 1.

- Q-3. The vent for the Sewer Ejector Pit is not specified in the Drawings and/or Specifications (typically goes through the roof). The vent through the building roof is not considered as part of this proposal price. Can we use an Automatic Vent stubbed up to the ceiling location?

***Response:*** Connect the Sewer Ejector Pit vent to the existing vent stack at the toilets leaving the Basement at P-2 in the immediate area of work. Venting through the building roof with a new vent stack is not required.