

GOVERNMENT OF THE DISTRICT OF COLUMBIA
DEPARTMENT OF GENERAL SERVICES



Addendum No. 3

To

**CONSTRUCTION SERVICES FOR MPD/FEMS HARBOR PATROL
FLOATING SHED & T-DOCK SYSTEM
Solicitation No: DCAM-19-CS-IFB-0010**

Issued: July 23, 2019

This Addendum No. 3 is issued and hereby published on the DGS website on July 23, 2019. Except as modified hereby, the Invitation for Bids ("IFB") remains unmodified.

Item #1: Questions and answers are attached hereto as Exhibit 1.

Item #2: B.3.1 Certain Work Included in the Lump Sum Price

Delete: The Contractor acknowledges and understands that the Lump Sum Price is based on the Scope of Work (Section C), including the Descriptions and Specifications (Attachment J.1), which are incorporated into this Contract.

Insert: The Contractor acknowledges and understands that the Lump Sum Price is based on the Scope of Work (Section C), including the Drawings and Specifications (Attachment J.1), which are incorporated into this Contract.

Item #3 C.10.2 Supervision & Coordination

Delete: a. Meet as necessary The Contractor and DGS Project Manager shall to review

Insert: a. The Contractor and DGS Project Manager shall meet weekly to discuss the progress of the project.

Item #4 C.10.2 Supervision & Coordination

Delete: 1. Prepare and submit to the Department construction meeting minutes, progress meeting minutes, daily logs, inspection reports, preliminary and baseline schedules, (Primavera format) and schedule updates demonstrating the critical

Insert: 1. Prepare and submit to the Department construction meeting minutes, progress meeting minutes, daily logs, inspection reports, preliminary and baseline schedules, (Primavera format) and schedule updates demonstrating the critical milestones.

Item #5 Bid Opening

Delete: July 12, 2019 at 2:30 p.m.
Adams Morgan Conference Room
3rd Floor
1250 U Street, NW | Washington, DC 20009

Insert: July 26, 2019 at 2:30 p.m.
Brookland Conference Room
3rd Floor
1250 U Street, NW | Washington, DC 20009

By: 
Franklin Austin
Contracting Officer

Date: 7/23/2019

- End of Addendum No. 3 -

Exhibit 1

DCAM-19-CS-IFB-0010
 MPD/FEMS Harbor Patrol
 Questions and Responses

No.	Questions	Responses
1	Being that the permits are to be obtained by the contractor, the time period for the permits can be quite lengthy and CANNOT be guaranteed. Will there be any specified time constraints for the permits or any penalty in the event that the permits take however long the approval process is or in the event the permits are not issued?	The Contractor shall file for all necessary permits within 90 days of Contract Execution. There will be no penalty in the event the permits take longer to process than expected.
2	Will we be able to use spuds for anchoring equipment?	Yes, spuds will be allowed as an anchoring system. The Contractor shall meet and coordinate with DC Water, Pepco and Department of Consumer and Regulatory Affairs ("DCRA") to ensure the spuds do not damage/interfere with MPD/FEMS operations or existing utilities.
3	Can we moor vessels along the opposite side of the pier as long as it doesn't interfere with operations?	Yes. Exact location along the pier TBD by MPD/FEMS operations.
4	Can you supply names of any companies that are qualified in DC to meet the 35% goals for CBE, MBE etc. Specifically are there any qualified electricians, disposal companies or suppliers that meet that requirement?	See Addendum 1, Exhibit 2 (issued July 2, 2019) for the link to CBE Certified Contractors.
5	Are the piling to be pulled/ removed entirely or are they required to be cut off at the mudline?	Pilings are to be pulled entirely.
6	Are there any contaminated material or hazardous materials to be removed such as lead paint?	See Section C.6.34 Unsafe and Hazardous Materials. At this time, there are no known contaminated materials by DGS.