**GOVERNMENT OF THE DISTRICT OF COLUMBIA**
**DEPARTMENT OF GENERAL SERVICES**

# INVITATION FOR BID (IFB)

## MPD 6D ADA UPGRADES PROJECT (INTERIOR AND EXTERIOR UPGRADES)

**Solicitation Number: DCAM-19-CS-IFB-0017**

**Addendum No. 5**

**Issued: August 30, 2019**

This Addendum No. 5 is issued and hereby published on the DGS website on **August 30, 2019**. Except as modified hereby, the Invitation for Bid (IFB) remains unmodified.

**Item #1:** The Questions & Answers Spreadsheet is hereby attached as **Exhibit 1**.

**By:** Franklin Austin
Franklin Austin, CPPB, CPM
Contracting Officer

**Date:** 8/30/2019

- End of Addendum No. 5

**EXHIBIT 1**

**QUESTIONS & ANSWERS SPREADSHEET**

**[EXHBIT WILL APPEAR ON THE FOLLOWING PAGE]**

**INVITATION FOR BIDS ("IFB")**

**QUESTIONS & ANSWERS SPREADSHEETS**

**MPD 1D ADA UPGRADES PROJECT (INTERIOR AND EXTERIOR UPGRADES)**

**Solicitation No: DCAM-19-CS-IFB-0015**

| No. | Questions | Department Responses |
|---|---|---|
| 1 | Please confirm Building Permit will be provided by Owner. | A/E of record for each project submitted base building permit application for project. The GC will be responsible for coordinating collecting & payment of permit. GC will be reimbursed for the associated PERMIT FEES charged by DCRA via change order. |
| 2 | Drawing G-03 Section 15.0 Mechanical & Plumbing direct us to see notes on Mechanical and Plumbing drawings. This drawings are not in Bid Set. Drawing A-01 is showing new bathrooms layout, but no new plumbing rough-in details were found. Please provide. | Correct. There are no mechanical or plumbing drawings in this set. Balance of Section 15 notes on sheet G-03 shall apply.<br><br>Mechanical and plumbing work is limited to scope described on architectural drawings – generally replacement in kind and/or minor relocations of existing service. GC shall review proposed rough-in locations vs. existing as called out in general notes #1 and 4. |
| 3 | If any HAZMAT report has been issued, please provide. | DGS does not have and is not aware of the existence of any HAZMAT reports at any of the locations referenced in this IFB. |