



Ridge Road RC Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003804	11/12/2025	11/12/2026	1	Food Prep Sink	In kitchen 108 Right	WF-11122025-003804	3/6/2026	FT-FY26-01282026-003804-A	<2	FT-FY26-01282026-003804-B	<2
WS- 003806	4/16/2025	4/16/2026	1	Cooler	In hallway adjacent to aquatics office 110 High	WF-04162025-003806	3/6/2026	FT-FY26-01282026-003806-A	<2	FT-FY26-01282026-003806-B	<2
WS- 003807	4/16/2025	4/16/2026	1	Bottle Filler	In hallway adjacent to aquatics office 110	WF-04162025-003807	3/6/2026	FT-FY26-01282026-003807-A	<2	FT-FY26-01282026-003807-B	<2
WS- 003808	4/16/2025	4/16/2026	1	Cooler	In hallway adjacent to aquatics office 110 Low	WF-04162025-003808	3/6/2026	FT-FY26-01282026-003808-A	<2	FT-FY26-01282026-003808-B	<2
WS- 003810	4/16/2025	4/16/2026	1	Bottle Filler	In hallway across for room 106	WF-04162025-003810	3/6/2026	FT-FY26-01282026-003810-A	<2	FT-FY26-01282026-003810-B	<2
WS- 003811	4/16/2025	4/16/2026	1	Cooler	In hallway across for room 106 Low	WF-04162025-003811	3/6/2026	FT-FY26-01282026-003811-A	<2	FT-FY26-01282026-003811-B	<2
WS- 003812	4/17/2025	4/17/2026	1	Classroom Faucet	In arts and crafts room 104	WF-04172025-003812	3/6/2026	FT-FY26-01282026-003812-A	<2	FT-FY26-01282026-003812-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.