

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
AES-0321-1A	Adams ES	3rd floor hallway adjacent to Classroom 308	3/21/16	< 1		
AES-0321-1B	Adams ES	3rd floor hallway adjacent to Classroom 308	3/21/16	< 1		
AES-0321-2A	Adams ES	3rd floor hallway adjacent to Computer Lab 302	3/21/16	< 1		
AES-0321-2B	Adams ES	3rd floor hallway adjacent to Computer Lab 302	3/21/16	< 1		
AES-0321-3A	Adams ES	2nd floor hallway adjacent to Classroom 201	3/21/16	< 1		
AES-0321-3B	Adams ES	2nd floor hallway adjacent to Classroom 201	3/21/16	< 1		
AES-0321-4A	Adams ES	2nd floor hallway adjacent to Classroom 202	3/21/16	< 1		
AES-0321-4B	Adams ES	2nd floor hallway adjacent to Classroom 202	3/21/16	< 1		
AES-0321-5A	Adams ES	2nd floor at Gym exit (south)	3/21/16	< 1		
AES-0321-5B	Adams ES	2nd floor at Gym exit (south)	3/21/16	< 1		
AES-0321-6A	Adams ES	1st floor across from Art Room 110	3/21/16	< 1		
AES-0321-6B	Adams ES	1st floor across from Art Room 110	3/21/16	< 1		
AES-0321-7A	Adams ES	1st floor hallway adjacent to Classroom 101	3/21/16	< 1		
AES-0321-7B	Adams ES	1st floor hallway adjacent to Classroom 101	3/21/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
AES-1216-1A	Aiton ES	4th floor hallway adjacent to Classroom 401	12/16/15	< 1		
AES-1216-1B	Aiton ES	4th floor hallway adjacent to Classroom 401	12/16/15	< 1		
AES-1216-2A	Aiton ES	4th floor hallway across from elevator	12/16/15	< 1		
AES-1216-2B	Aiton ES	4th floor hallway across from elevator	12/16/15	< 1		
AES-1216-3A	Aiton ES	3rd floor hallway across from elevator	12/16/15	< 1		
AES-1216-3B	Aiton ES	3rd floor hallway across from elevator	12/16/15	< 1		
AES-1216-4A	Aiton ES	3rd floor hallway adjacent to Classroom 301	12/16/15	< 1		
AES-1216-4B	Aiton ES	3rd floor hallway adjacent to Classroom 301	12/16/15	< 1		
AES-1216-5A	Aiton ES	2nd floor hallway across from elevator	12/16/15	< 1		
AES-1216-5B	Aiton ES	2nd floor hallway across from elevator	12/16/15	< 1		
AES-1216-6A	Aiton ES	2nd floor hallway adjacent to Library	12/16/15	< 1		
AES-1216-6B	Aiton ES	2nd floor hallway adjacent to Library	12/16/15	< 1		
AES-1216-7A	Aiton ES	1st floor inside Classroom Kindergarten 2	12/16/15	< 1		
AES-1216-7B	Aiton ES	1st floor inside Classroom Kindergarten 2	12/16/15	< 1		
AES-1216-8A	Aiton ES	1st floor inside Classroom Kindergarten 1	12/16/15	< 1		
AES-1216-8B	Aiton ES	1st floor inside Classroom Kindergarten 1	12/16/15	< 1		
AES-1216-9A	Aiton ES	1st floor hallway adjacent to Custodian Closet	12/16/15	< 1		
AES-1216-9B	Aiton ES	1st floor hallway adjacent to Custodian Closet	12/16/15	< 1		
AES-1216-10A	Aiton ES	1st floor in Main Lobby	12/16/15	< 1		
AES-1216-10B	Aiton ES	1st floor in Main Lobby	12/16/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
AB-1229-1A	Amidon-Bowen ES	2nd floor hallway at Stair C	12/29/15	< 1		
AB-1229-1B	Amidon-Bowen ES	2nd floor hallway at Stair C	12/29/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
AB-1229-2A	Amidon-Bowen ES	2nd floor inside Classroom B236	12/29/15	< 1		
AB-1229-2B	Amidon-Bowen ES	2nd floor inside Classroom B236	12/29/15	< 1		
AB-1229-3A	Amidon-Bowen ES	2nd floor inside Classroom B231	12/29/15	1.3		
AB-1229-3B	Amidon-Bowen ES	2nd floor inside Classroom B231	12/29/15	< 1		
AB-1229-4A	Amidon-Bowen ES	2nd floor inside Classroom B227	12/29/15	< 1		
AB-1229-4B	Amidon-Bowen ES	2nd floor inside Classroom B227	12/29/15	< 1		
AB-1229-5A	Amidon-Bowen ES	2nd floor inside Classroom B232	12/29/15	< 1		
AB-1229-5B	Amidon-Bowen ES	2nd floor inside Classroom B232	12/29/15	< 1		
AB-1229-6A	Amidon-Bowen ES	2nd floor inside Classroom B225	12/29/15	< 1		
AB-1229-6B	Amidon-Bowen ES	2nd floor inside Classroom B225	12/29/15	< 1		
AB-1229-7A	Amidon-Bowen ES	2nd floor inside Classroom B223	12/29/15	< 1		
AB-1229-7B	Amidon-Bowen ES	2nd floor inside Classroom B223	12/29/15	< 1		
AB-1229-8A	Amidon-Bowen ES	2nd floor inside Classroom B230	12/29/15	< 1		
AB-1229-8B	Amidon-Bowen ES	2nd floor inside Classroom B230	12/29/15	< 1		
AB-1229-9A	Amidon-Bowen ES	2nd floor inside Classroom B202	12/29/15	< 1		
AB-1229-9B	Amidon-Bowen ES	2nd floor inside Classroom B202	12/29/15	< 1		
AB-1229-10A	Amidon-Bowen ES	2nd floor inside Classroom B208	12/29/15	< 1		
AB-1229-10B	Amidon-Bowen ES	2nd floor inside Classroom B208	12/29/15	< 1		
AB-1229-11A	Amidon-Bowen ES	2nd floor inside Classroom B212	12/29/15	< 1		
AB-1229-11B	Amidon-Bowen ES	2nd floor inside Classroom B212	12/29/15	< 1		
AB-1229-12A	Amidon-Bowen ES	2nd floor inside Classroom B213	12/29/15	< 1		
AB-1229-12B	Amidon-Bowen ES	2nd floor inside Classroom B213	12/29/15	< 1		
AB-1229-13A	Amidon-Bowen ES	2nd floor inside Classroom B209	12/29/15	< 1		
AB-1229-13B	Amidon-Bowen ES	2nd floor inside Classroom B209	12/29/15	< 1		
AB-1229-14A	Amidon-Bowen ES	1st floor hallway adjacent to Health Suite	12/29/15	< 1		
AB-1229-14B	Amidon-Bowen ES	1st floor hallway adjacent to Health Suite	12/29/15	< 1		
AB-1229-15A	Amidon-Bowen ES	1st floor inside Classroom A107	12/29/15	1.5		
AB-1229-15B	Amidon-Bowen ES	1st floor inside Classroom A107	12/29/15	< 1		
AB-1229-16A	Amidon-Bowen ES	1st floor inside Classroom A105	12/29/15	4.9		
AB-1229-16B	Amidon-Bowen ES	1st floor inside Classroom A105 (high)	12/29/15	< 1		
AB-1229-17A	Amidon-Bowen ES	1st floor inside Classroom A105 (high)	12/29/15	1.1		
AB-1229-17B	Amidon-Bowen ES	1st floor inside Classroom A105 (low)	12/29/15	< 1		
AB-1229-18A	Amidon-Bowen ES	1st floor inside Classroom A106 (high)	12/29/15	< 1		
AB-1229-18B	Amidon-Bowen ES	1st floor inside Classroom A106 (high)	12/29/15	< 1		
AB-1229-19A	Amidon-Bowen ES	1st floor inside Classroom A106 (low)	12/29/15	1.7		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
AB-1229-19B	Amidon-Bowen ES	1st floor inside Classroom A106 (low)	12/29/15	< 1		
AB-1229-20A	Amidon-Bowen ES	1st floor inside Classroom A103 (high)	12/29/15	< 1		
AB-1229-20B	Amidon-Bowen ES	1st floor inside Classroom A103 (high)	12/29/15	1.1		
AB-1229-21A	Amidon-Bowen ES	1st floor inside Classroom A103 (low)	12/29/15	< 1		
AB-1229-21B	Amidon-Bowen ES	1st floor inside Classroom A103 (low)	12/29/15	< 1		
AB-1229-22A	Amidon-Bowen ES	1st floor inside Classroom B126	12/29/15	< 1		
AB-1229-22B	Amidon-Bowen ES	1st floor inside Classroom B126	12/29/15	< 1		
AB-1229-23A	Amidon-Bowen ES	1st floor hallway adjacent to Classroom B128 (high)	12/29/15	< 1		
AB-1229-23B	Amidon-Bowen ES	1st floor hallway adjacent to Classroom B128 (high)	12/29/15	< 1		
AB-1229-24A	Amidon-Bowen ES	1st floor hallway adjacent to Classroom B128 (low)	12/29/15	< 1		
AB-1229-24B	Amidon-Bowen ES	1st floor hallway adjacent to Classroom B128 (low)	12/29/15	< 1		
AB-1229-25A	Amidon-Bowen ES	1st floor inside Classroom B128	12/29/15	< 1		
AB-1229-25B	Amidon-Bowen ES	1st floor inside Classroom B128	12/29/15	< 1		
AB-1229-26A	Amidon-Bowen ES	1st floor hallway at Gym entrance	12/29/15	< 1		
AB-1229-26B	Amidon-Bowen ES	1st floor hallway at Gym entrance	12/29/15	< 1		
AB-1229-27A	Amidon-Bowen ES	1st floor inside Classroom D161	12/29/15	< 1		
AB-1229-27B	Amidon-Bowen ES	1st floor inside Classroom D161	12/29/15	< 1		
AB-1229-28A	Amidon-Bowen ES	1st floor inside Gym	12/29/15	< 1		
AB-1229-28B	Amidon-Bowen ES	1st floor inside Gym	12/29/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
AHS-1116-1A	Anacostia HS	3rd floor hallway adjacent to Classroom M319	11/16/15	< 1		
AHS-1116-1B	Anacostia HS	3rd floor hallway adjacent to Classroom M319	11/16/15	< 1		
AHS-1116-2A	Anacostia HS	3rd floor hallway adjacent to Classroom M303	11/16/15	< 1		
AHS-1116-2B	Anacostia HS	3rd floor hallway adjacent to Classroom M303	11/16/15	< 1		
AHS-1116-3A	Anacostia HS	2nd floor hallway adjacent to Classroom M202	11/16/15	< 1		
AHS-1116-3B	Anacostia HS	2nd floor hallway adjacent to Classroom M202	11/16/15	< 1		
AHS-1116-4A	Anacostia HS	2nd floor hallway adjacent to Science Lab M220	11/16/15	< 1		
AHS-1116-4B	Anacostia HS	2nd floor hallway adjacent to Science Lab M220	11/16/15	< 1		
AHS-1116-5A	Anacostia HS	2nd floor hallway adjacent to Computer Lab N203	11/16/15	< 1		
AHS-1116-5B	Anacostia HS	2nd floor hallway adjacent to Computer Lab N203	11/16/15	< 1		
AHS-1116-6A	Anacostia HS	2nd floor hallway across from Computer Lab M212	11/16/15	< 1		
AHS-1116-6B	Anacostia HS	2nd floor hallway across from Computer Lab M212	11/16/15	< 1		
AHS-1116-7A	Anacostia HS	2nd floor hallway adjacent to Classroom S204	11/16/15	< 1		
AHS-1116-7B	Anacostia HS	2nd floor hallway adjacent to Classroom S204	11/16/15	< 1		
AHS-1116-8A	Anacostia HS	2nd floor hallway adjacent to Work Room G204	11/16/15	< 1		
AHS-1116-8B	Anacostia HS	2nd floor hallway adjacent to Work Room G204	11/16/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
AHS-1116-9A	Anacostia HS	1st floor hallway across from Gym G102	11/16/15	< 1		
AHS-1116-9B	Anacostia HS	1st floor hallway across from Gym G102	11/16/15	< 1		
AHS-1116-10A	Anacostia HS	1st floor hallway across from Parent Resource M115	11/16/15	< 1		
AHS-1116-10B	Anacostia HS	1st floor hallway across from Parent Resource M115	11/16/15	< 1		
AHS-1116-11A	Anacostia HS	1st floor hallway across from Work Room N110	11/16/15	< 1		
AHS-1116-11B	Anacostia HS	1st floor hallway across from Work Room N110	11/16/15	< 1		
AHS-1116-12A	Anacostia HS	1st floor hallway adjacent to M103 (Admin)	11/16/15	< 1		
AHS-1116-12B	Anacostia HS	1st floor hallway adjacent to M103 (Admin)	11/16/15	< 1		
AHS-1116-13A	Anacostia HS	1st floor hallway adjacent to Classroom S102	11/16/15	< 1		
AHS-1116-13B	Anacostia HS	1st floor hallway adjacent to Classroom S102	11/16/15	< 1		
AHS-1116-14A	Anacostia HS	Basement floor hallway across from Stair 9	11/16/15	< 1		
AHS-1116-14B	Anacostia HS	Basement floor hallway across from Stair 9	11/16/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BHS-1119-1A	Ballou HS	3rd floor hallway between Men's and Women's Rooms near elevator (high)	11/19/15	< 1		
BHS-1119-1B	Ballou HS	3rd floor hallway between Men's and Women's Rooms near elevator (high)	11/19/15	< 1		
BHS-1119-2A	Ballou HS	3rd floor hallway between Men's and Women's Rooms near elevator (low)	11/19/15	< 1		
BHS-1119-2B	Ballou HS	3rd floor hallway between Men's and Women's Rooms near elevator (low)	11/19/15	< 1		
BHS-1119-3A	Ballou HS	3rd floor hallway adjacent to AV Rack Room (high)	11/19/15	< 1		
BHS-1119-3B	Ballou HS	3rd floor hallway adjacent to AV Rack Room (high)	11/19/15	< 1		
BHS-1119-4A	Ballou HS	3rd floor hallway adjacent to AV Rack Room (low)	11/19/15	< 1		
BHS-1119-4B	Ballou HS	3rd floor hallway adjacent to AV Rack Room (low)	11/19/15	< 1		
BHS-1119-5A	Ballou HS	3rd floor hallway across from Classroom 3012 (high)	11/19/15	< 1		
BHS-1119-5B	Ballou HS	3rd floor hallway across from Classroom 3012 (high)	11/19/15	< 1		
BHS-1119-6A	Ballou HS	3rd floor hallway across from Classroom 3012 (low)	11/19/15	< 1		
BHS-1119-6B	Ballou HS	3rd floor hallway across from Classroom 3012 (low)	11/19/15	< 1		
BHS-1119-7A	Ballou HS	3rd floor hallway across from Classroom 3026 (high)	11/19/15	< 1		
BHS-1119-7B	Ballou HS	3rd floor hallway across from Classroom 3026 (high)	11/19/15	< 1		
BHS-1119-8A	Ballou HS	3rd floor hallway across from Classroom 3026 (low)	11/19/15	< 1		
BHS-1119-8B	Ballou HS	3rd floor hallway across from Classroom 3026 (low)	11/19/15	< 1		
BHS-1119-9A	Ballou HS	3rd floor hallway at Gym entrance (high, left)	11/19/15	< 1		
BHS-1119-9B	Ballou HS	3rd floor hallway at Gym entrance (high, left)	11/19/15	< 1		
BHS-1119-10A	Ballou HS	3rd floor hallway at Gym entrance (low, left)	11/19/15	< 1		
BHS-1119-10B	Ballou HS	3rd floor hallway at Gym entrance (low, left)	11/19/15	< 1		
BHS-1119-11A	Ballou HS	3rd floor hallway at Gym entrance (high, right)	11/19/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BHS-1119-11B	Ballou HS	3rd floor hallway at Gym entrance (high, right)	11/19/15	< 1		
BHS-1119-12A	Ballou HS	3rd floor hallway at Gym entrance (low, right)	11/19/15	< 1		
BHS-1119-12B	Ballou HS	3rd floor hallway at Gym entrance (low, right)	11/19/15	< 1		
BHS-1119-13A	Ballou HS	3rd floor hallway between Men's and Women's Rooms near 3202C (high)	11/19/15	< 1		
BHS-1119-13B	Ballou HS	3rd floor hallway between Men's and Women's Rooms near 3202C (high)	11/19/15	< 1		
BHS-1119-14A	Ballou HS	3rd floor hallway between Men's and Women's Rooms near 3202C (low)	11/19/15	< 1		
BHS-1119-14B	Ballou HS	3rd floor hallway between Men's and Women's Rooms near 3202C (low)	11/19/15	< 1		
BHS-1119-15A	Ballou HS	3rd floor in Small Gym (high)	11/19/15	< 1		
BHS-1119-15B	Ballou HS	3rd floor in Small Gym (high)	11/19/15	< 1		
BHS-1119-16A	Ballou HS	3rd floor in Small Gym (low)	11/19/15	< 1		
BHS-1119-16B	Ballou HS	3rd floor in Small Gym (low)	11/19/15	< 1		
BHS-1119-17A	Ballou HS	3rd floor in Weight Room (high)	11/19/15	< 1		
BHS-1119-17B	Ballou HS	3rd floor in Weight Room (high)	11/19/15	< 1		
BHS-1119-18A	Ballou HS	3rd floor in Weight Room (low)	11/19/15	< 1		
BHS-1119-18B	Ballou HS	3rd floor in Weight Room (low)	11/19/15	< 1		
BHS-1119-19A	Ballou HS	2nd floor hallway adjacent to Stair 6 (high)	11/19/15	< 1		
BHS-1119-19B	Ballou HS	2nd floor hallway adjacent to Stair 6 (high)	11/19/15	< 1		
BHS-1119-20A	Ballou HS	2nd floor hallway adjacent to Stair 6 (low)	11/19/15	< 1		
BHS-1119-20B	Ballou HS	2nd floor hallway adjacent to Stair 6 (low)	11/19/15	< 1		
BHS-1119-21A	Ballou HS	2nd floor hallway across from Storage Room 2220 (high, left)	11/19/15	< 1		
BHS-1119-21B	Ballou HS	2nd floor hallway across from Storage Room 2220 (high, left)	11/19/15	< 1		
BHS-1119-22A	Ballou HS	2nd floor hallway across from Storage Room 2220 (low, left)	11/19/15	< 1		
BHS-1119-22B	Ballou HS	2nd floor hallway across from Storage Room 2220 (low, left)	11/19/15	< 1		
BHS-1119-23A	Ballou HS	2nd floor hallway across from Storage Room 2220 (high, right)	11/19/15	< 1		
BHS-1119-23B	Ballou HS	2nd floor hallway across from Storage Room 2220 (high, right)	11/19/15	< 1		
BHS-1119-24A	Ballou HS	2nd floor hallway across from Storage Room 2220 (low, right)	11/19/15	< 1		
BHS-1119-24B	Ballou HS	2nd floor hallway across from Storage Room 2220 (low, right)	11/19/15	< 1		
BHS-1119-25A	Ballou HS	2nd floor hallway adjacent to School Store 2350 (high)	11/19/15	< 1		
BHS-1119-25B	Ballou HS	2nd floor hallway adjacent to School Store 2350 (high)	11/19/15	< 1		
BHS-1119-26A	Ballou HS	2nd floor hallway adjacent to School Store 2350 (low)	11/19/15	< 1		
BHS-1119-26B	Ballou HS	2nd floor hallway adjacent to School Store 2350 (low)	11/19/15	< 1		
BHS-1119-27A	Ballou HS	2nd floor hallway between Men's and Women's Rooms near elevator (high)	11/19/15	< 1		
BHS-1119-27B	Ballou HS	2nd floor hallway between Men's and Women's Rooms near elevator (high)	11/19/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BHS-1119-28A	Ballou HS	2nd floor hallway between Men's and Women's Rooms near elevator (low)	11/19/15	< 1		
BHS-1119-28B	Ballou HS	2nd floor hallway between Men's and Women's Rooms near elevator (low)	11/19/15	< 1		
BHS-1119-29A	Ballou HS	2nd floor hallway adjacent to Room 2623 (high)	11/19/15	< 1		
BHS-1119-29B	Ballou HS	2nd floor hallway adjacent to Room 2623 (high)	11/19/15	< 1		
BHS-1119-30A	Ballou HS	2nd floor hallway adjacent to Room 2623 (low)	11/19/15	< 1		
BHS-1119-30B	Ballou HS	2nd floor hallway adjacent to Room 2623 (low)	11/19/15	< 1		
BHS-1119-31A	Ballou HS	2nd floor hallway across from Classroom 2012 (high)	11/19/15	< 1		
BHS-1119-31B	Ballou HS	2nd floor hallway across from Classroom 2012 (high)	11/19/15	< 1		
BHS-1119-32A	Ballou HS	2nd floor hallway across from Classroom 2012 (low)	11/19/15	< 1		
BHS-1119-32B	Ballou HS	2nd floor hallway across from Classroom 2012 (low)	11/19/15	< 1		
BHS-1119-33A	Ballou HS	2nd floor hallway across from Classroom 2026 (high)	11/19/15	< 1		
BHS-1119-33B	Ballou HS	2nd floor hallway across from Classroom 2026 (high)	11/19/15	< 1		
BHS-1119-34A	Ballou HS	2nd floor hallway across from Classroom 2026 (low)	11/19/15	< 1		
BHS-1119-34B	Ballou HS	2nd floor hallway across from Classroom 2026 (low)	11/19/15	< 1		
BHS-1119-35A	Ballou HS	1st floor hallway across from Classroom 1012 (high)	11/19/15	< 1		
BHS-1119-35B	Ballou HS	1st floor hallway across from Classroom 1012 (high)	11/19/15	< 1		
BHS-1119-36A	Ballou HS	1st floor hallway across from Classroom 1012 (low)	11/19/15	< 1		
BHS-1119-36B	Ballou HS	1st floor hallway across from Classroom 1012 (low)	11/19/15	< 1		
BHS-1119-37A	Ballou HS	1st floor hallway across from Classroom 1026 (high)	11/19/15	< 1		
BHS-1119-37B	Ballou HS	1st floor hallway across from Classroom 1026 (high)	11/19/15	< 1		
BHS-1119-38A	Ballou HS	1st floor hallway across from Classroom 1026 (low)	11/19/15	< 1		
BHS-1119-38B	Ballou HS	1st floor hallway across from Classroom 1026 (low)	11/19/15	< 1		
BHS-1119-39A	Ballou HS	1st floor hallway adjacent to Student Lounge 1301 (high)	11/19/15	< 1		
BHS-1119-39B	Ballou HS	1st floor hallway adjacent to Student Lounge 1301 (high)	11/19/15	< 1		
BHS-1119-40A	Ballou HS	1st floor hallway adjacent to Student Lounge 1301 (low)	11/19/15	< 1		
BHS-1119-40B	Ballou HS	1st floor hallway adjacent to Student Lounge 1301 (low)	11/19/15	< 1		
BHS-1119-41A	Ballou HS	1st floor hallway adjacent to Culinary Arts 1305 (high)	11/19/15	< 1		
BHS-1119-41B	Ballou HS	1st floor hallway adjacent to Culinary Arts 1305 (high)	11/19/15	< 1		
BHS-1119-42A	Ballou HS	1st floor hallway adjacent to Culinary Arts 1305 (low)	11/19/15	< 1		
BHS-1119-42B	Ballou HS	1st floor hallway adjacent to Culinary Arts 1305 (low)	11/19/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BES-0323-1A	Bancroft ES	3rd floor hallway adjacent to Classroom 224	3/23/16	< 1		
BES-0323-1B	Bancroft ES	3rd floor hallway adjacent to Classroom 224	3/23/16	< 1		
BES-0323-2A	Bancroft ES	3rd floor hallway adjacent to Classroom 221	3/23/16	< 1		
BES-0323-2B	Bancroft ES	3rd floor hallway adjacent to Classroom 221	3/23/16	< 1		
BES-0323-3A	Bancroft ES	2nd floor hallway adjacent to Storage Room	3/23/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BES-0323-3B	Bancroft ES	2nd floor hallway adjacent to Storage Room	3/23/16	< 1		
BES-0323-4A	Bancroft ES	1st floor hallway adjacent to Main Office 107	3/23/16	< 1		
BES-0323-4B	Bancroft ES	1st floor hallway adjacent to Main Office 107	3/23/16	< 1		
BES-0323-5A	Bancroft ES	1st floor inside Health Suite 103	3/23/16	< 1		
BES-0323-5B	Bancroft ES	1st floor inside Health Suite 103	3/23/16	< 1		
BES-0323-6A	Bancroft ES	3rd floor hallway across from Classroom 324	3/23/16	< 1		
BES-0323-6B	Bancroft ES	3rd floor hallway across from Classroom 324	3/23/16	< 1		
BES-0323-7A	Bancroft ES	2nd floor hallway across from Classroom 314	3/23/16	< 1		
BES-0323-7B	Bancroft ES	2nd floor hallway across from Classroom 314	3/23/16	< 1		
BES-0323-8A	Bancroft ES	2nd floor inside Pre-School Room 314	3/23/16	< 1		
BES-0323-8B	Bancroft ES	2nd floor inside Pre-School Room 314	3/23/16	< 1		
BES-0323-9A	Bancroft ES	2nd floor inside Pre-School Room 313	3/23/16	< 1		
BES-0323-9B	Bancroft ES	2nd floor inside Pre-School Room 313	3/23/16	< 1		
BES-0323-10A	Bancroft ES	1st floor hallway near Classroom 302	3/23/16	< 1		
BES-0323-10B	Bancroft ES	1st floor hallway near Classroom 302	3/23/16	< 1		
BES-0323-11A	Bancroft ES	Basement floor inside Learning Center adjacent to Boy's Room	3/23/16	< 1		
BES-0323-11B	Bancroft ES	Basement floor inside Learning Center adjacent to Boy's Room	3/23/16	< 1		
BES-0323-12A	Bancroft ES	Basement floor inside Pre-K Room 412 adjacent to Restroom	3/23/16	< 1		
BES-0323-12B	Bancroft ES	Basement floor inside Pre-K Room 412 adjacent to Restroom	3/23/16	< 1		
BES-0323-13A	Bancroft ES	Basement floor inside Library	3/23/16	< 1		
BES-0323-13B	Bancroft ES	Basement floor inside Library	3/23/16	< 1		
BES-0323-14A	Bancroft ES	2nd floor hallway adjacent to Classroom 213	3/23/16	< 1		
BES-0323-14B	Bancroft ES	2nd floor hallway adjacent to Classroom 213	3/23/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BHS-0413-1A	Banneker SHS	3rd floor hallway adjacent to Classroom 306	4/13/16			
BHS-0413-1B	Banneker SHS	3rd floor hallway adjacent to Classroom 306	4/13/16			
BHS-0413-2A	Banneker SHS	3rd floor hallway adjacent to Classroom 305	4/13/16			
BHS-0413-2B	Banneker SHS	3rd floor hallway adjacent to Classroom 305	4/13/16			
BHS-0413-3A	Banneker SHS	3rd floor hallway adjacent to Classroom 315	4/13/16			
BHS-0413-3B	Banneker SHS	3rd floor hallway adjacent to Classroom 315	4/13/16			
BHS-0413-4A	Banneker SHS	3rd floor hallway near Stairwell 5	4/13/16			
BHS-0413-4B	Banneker SHS	3rd floor hallway near Stairwell 5	4/13/16			
BHS-0413-5A	Banneker SHS	2nd floor hallway near Stairwell 5	4/13/16			
BHS-0413-5B	Banneker SHS	2nd floor hallway near Stairwell 5	4/13/16			
BHS-0413-6A	Banneker SHS	2nd floor hallway near Stairwell 2	4/13/16			
BHS-0413-6B	Banneker SHS	2nd floor hallway near Stairwell 2	4/13/16			
BHS-0413-7A	Banneker SHS	2nd floor hallway near Stairwell 1	4/13/16			
BHS-0413-7B	Banneker SHS	2nd floor hallway near Stairwell 1	4/13/16			
BHS-0413-8A	Banneker SHS	2nd floor hallway near Stairwell 6	4/13/16			

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BHS-0413-8B	Banneker SHS	2nd floor hallway near Stairwell 6	4/13/16			
BHS-0413-9A	Banneker SHS	1st floor hallway adjacent to Principal's Office 102	4/13/16			
BHS-0413-9B	Banneker SHS	1st floor hallway adjacent to Principal's Office 102	4/13/16			
BHS-0413-10A	Banneker SHS	1st floor hallway near Stairwell 1	4/13/16			
BHS-0413-10B	Banneker SHS	1st floor hallway near Stairwell 1	4/13/16			
BHS-0413-11A	Banneker SHS	1st floor hallway adjacent to Book Room 113	4/13/16			
BHS-0413-11B	Banneker SHS	1st floor hallway adjacent to Book Room 113	4/13/16			
BHS-0413-12A	Banneker SHS	1st floor inside Gym near Girl's Locker Room	4/13/16			
BHS-0413-12B	Banneker SHS	1st floor inside Gym near Girl's Locker Room	4/13/16			
BHS-0413-13A	Banneker SHS	1st floor hallway near Stairwell 5	4/13/16			
BHS-0413-13B	Banneker SHS	1st floor hallway near Stairwell 5	4/13/16			
BHS-0413-14A	Banneker SHS	Basement floor hallway across from elevator	4/13/16			
BHS-0413-14B	Banneker SHS	Basement floor hallway across from elevator	4/13/16			
BHS-0413-15A	Banneker SHS	Basement floor inside Kitchen	4/13/16			
BHS-0413-15B	Banneker SHS	Basement floor inside Kitchen	4/13/16			
BHS-0413-16A	Banneker SHS	Basement floor hallway near Stairwell 5	4/13/16			
BHS-0413-16B	Banneker SHS	Basement floor hallway near Stairwell 5	4/13/16			
BHS-0413-17A	Banneker SHS	Basement floor hallway adjacent to Maintenance Office 001	4/13/16			
BHS-0413-17B	Banneker SHS	Basement floor hallway adjacent to Maintenance Office 001	4/13/16			
BHS-0413-18A	Banneker SHS	Basement floor inside Cafeteria (next to beverage machine)	4/13/16			
BHS-0413-18B	Banneker SHS	Basement floor inside Cafeteria (next to beverage machine)	4/13/16			
BHS-0413-19A	Banneker SHS	Basement floor inside Cafeteria (next to snack machine)	4/13/16			
BHS-0413-19B	Banneker SHS	Basement floor inside Cafeteria (next to snack machine)	4/13/16			
BHS-0413-20A	Banneker SHS	Basement floor hallway adjacent to Head Custodian's Office	4/13/16			
BHS-0413-20B	Banneker SHS	Basement floor hallway adjacent to Head Custodian's Office	4/13/16			
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BES-0222-1A	Barnard ES	2nd floor hallway adjacent to Classroom 210 (high)	2/22/16	< 1		
BES-0222-1B	Barnard ES	2nd floor hallway adjacent to Classroom 210 (high)	2/22/16	< 1		
BES-0222-2A	Barnard ES	2nd floor hallway adjacent to Classroom 206 (high)	2/22/16	< 1		
BES-0222-2B	Barnard ES	2nd floor hallway adjacent to Classroom 206 (high)	2/22/16	< 1		
BES-0222-3A	Barnard ES	2nd floor hallway across from Art Room 239 (high)	2/22/16	< 1		
BES-0222-3B	Barnard ES	2nd floor hallway across from Art Room 239 (high)	2/22/16	< 1		
BES-0222-4A	Barnard ES	2nd floor hallway across from Art Room 239 (low)	2/22/16	< 1		
BES-0222-4B	Barnard ES	2nd floor hallway across from Art Room 239 (low)	2/22/16	< 1		
BES-0222-5A	Barnard ES	1st floor inside Classroom 120 restroom	2/22/16		22	<b>Device has been turned off. Filter installation pending.</b>
BES-0222-5B	Barnard ES	1st floor inside Classroom 120 restroom	2/22/16	< 1		
BES-0222-6A	Barnard ES	1st floor inside Classroom 105 restroom	2/22/16	10		
BES-0222-6B	Barnard ES	1st floor inside Classroom 105 restroom	2/22/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BES-0222-7A	Barnard ES	1st floor inside Classroom 106 restroom	2/22/16	1.5		
BES-0222-7B	Barnard ES	1st floor inside Classroom 106 restroom	2/22/16	< 1		
BES-0222-8A	Barnard ES	1st floor inside Classroom 118 restroom	2/22/16	< 1		
BES-0222-8B	Barnard ES	1st floor inside Classroom 118 restroom	2/22/16	< 1		
BES-0222-9A	Barnard ES	1st floor inside Classroom 109 restroom	2/22/16	< 1		
BES-0222-9B	Barnard ES	1st floor inside Classroom 109 restroom	2/22/16	< 1		
BES-0222-10A	Barnard ES	1st floor inside Classroom 114 restroom	2/22/16	< 1		
BES-0222-10B	Barnard ES	1st floor inside Classroom 114 restroom	2/22/16	< 1		
BES-0222-11A	Barnard ES	1st floor inside Classroom 110 restroom	2/22/16	< 1		
BES-0222-11B	Barnard ES	1st floor inside Classroom 110 restroom	2/22/16	< 1		
BES-0222-12A	Barnard ES	1st floor inside Classroom 111 restroom	2/22/16	< 1		
BES-0222-12B	Barnard ES	1st floor inside Classroom 111 restroom	2/22/16	< 1		
BES-0222-13A	Barnard ES	1st floor inside Classroom 112 restroom	2/22/16	1.1		
BES-0222-13B	Barnard ES	1st floor inside Classroom 112 restroom	2/22/16	< 1		
BES-0222-14A	Barnard ES	1st floor inside Classroom 113 restroom	2/22/16	1.3		
BES-0222-14B	Barnard ES	1st floor inside Classroom 113 restroom	2/22/16	< 1		
BES-0222-15A	Barnard ES	1st floor hallway adjacent to Classroom 109 (high)	2/22/16	< 1		
BES-0222-15B	Barnard ES	1st floor hallway adjacent to Classroom 109 (high)	2/22/16	< 1		
BES-0222-16A	Barnard ES	1st floor hallway adjacent to Classroom 109 (low)	2/22/16	< 1		
BES-0222-16B	Barnard ES	1st floor hallway adjacent to Classroom 109 (low)	2/22/16	< 1		
BES-0222-17A	Barnard ES	1st floor hallway adjacent to Classroom 106 (high)	2/22/16	< 1		
BES-0222-17B	Barnard ES	1st floor hallway adjacent to Classroom 106 (high)	2/22/16	< 1		
BES-0222-18A	Barnard ES	1st floor hallway adjacent to Classroom 106 (low)	2/22/16	< 1		
BES-0222-18B	Barnard ES	1st floor hallway adjacent to Classroom 106 (low)	2/22/16	< 1		
BES-0222-19A	Barnard ES	1st floor hallway across from OT Room 121 (low)	2/22/16	< 1		
BES-0222-19B	Barnard ES	1st floor hallway across from OT Room 121 (low)	2/22/16	< 1		
<b>Percentage of Passed Samples</b>						<b>97.37%</b>
<b>Percentage of Failed Samples</b>						<b>2.63%</b>
BES-1130-1A	Beers ES	2nd floor hallway adjacent to Classroom B209	11/30/15	< 1		
BES-1130-1B	Beers ES	2nd floor hallway adjacent to Classroom B209	11/30/15	< 1		
BES-1130-2A	Beers ES	2nd floor hallway adjacent to Classroom B201 (high)	11/30/15	< 1		
BES-1130-2B	Beers ES	2nd floor hallway adjacent to Classroom B201 (high)	11/30/15	< 1		
BES-1130-3A	Beers ES	2nd floor hallway adjacent to Classroom B201 (low)	11/30/15	< 1		
BES-1130-3B	Beers ES	2nd floor hallway adjacent to Classroom B201 (low)	11/30/15	< 1		
BES-1130-4A	Beers ES	2nd floor hallway across from Classroom D210	11/30/15	< 1		
BES-1130-4B	Beers ES	2nd floor hallway across from Classroom D210	11/30/15	< 1		
BES-1130-5A	Beers ES	2nd floor hallway adjacent to Classroom D201	11/30/15	< 1		
BES-1130-5B	Beers ES	2nd floor hallway adjacent to Classroom D201	11/30/15	< 1		
BES-1130-6A	Beers ES	2nd floor hallway adjacent to Electric Closet A218	11/30/15	< 1		
BES-1130-6B	Beers ES	2nd floor hallway adjacent to Electric Closet A218	11/30/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BES-1130-7A	Beers ES	2nd floor inside Classroom A205	11/30/15	< 1		
BES-1130-7B	Beers ES	2nd floor inside Classroom A205	11/30/15	< 1		
BES-1130-8A	Beers ES	2nd floor inside Classroom A207	11/30/15	< 1		
BES-1130-8B	Beers ES	2nd floor inside Classroom A207	11/30/15	< 1		
BES-1130-9A	Beers ES	2nd floor inside Classroom A214	11/30/15	< 1		
BES-1130-9B	Beers ES	2nd floor inside Classroom A214	11/30/15	< 1		
BES-1130-10A	Beers ES	2nd floor inside Classroom A211	11/30/15	1.3		
BES-1130-10B	Beers ES	2nd floor inside Classroom A211	11/30/15	< 1		
BES-1130-11A	Beers ES	2nd floor inside Classroom A216	11/30/15	< 1		
BES-1130-11B	Beers ES	2nd floor inside Classroom A216	11/30/15	< 1		
BES-1130-12A	Beers ES	1st floor inside Classroom A112	11/30/15	< 1		
BES-1130-12B	Beers ES	1st floor inside Classroom A112	11/30/15	< 1		
BES-1130-13A	Beers ES	1st floor inside Classroom A110	11/30/15	< 1		
BES-1130-13B	Beers ES	1st floor inside Classroom A110	11/30/15	< 1		
BES-1130-14A	Beers ES	1st floor inside Classroom A119	11/30/15	< 1		
BES-1130-14B	Beers ES	1st floor inside Classroom A119	11/30/15	< 1		
BES-1130-15A	Beers ES	1st floor hallway across from Classroom A110	11/30/15	< 1		
BES-1130-15B	Beers ES	1st floor hallway across from Classroom A110	11/30/15	< 1		
BES-1130-16A	Beers ES	1st floor inside Health Suite A115	11/30/15	< 1		
BES-1130-16B	Beers ES	1st floor inside Health Suite A115	11/30/15	< 1		
BES-1130-17A	Beers ES	1st floor inside Classroom A109	11/30/15	< 1		
BES-1130-17A	Beers ES	1st floor inside Classroom A109	11/30/15	< 1		
BES-1130-18A	Beers ES	1st floor inside Classroom A108	11/30/15	< 1		
BES-1130-18B	Beers ES	1st floor inside Classroom A108	11/30/15	< 1		
BES-1130-19A	Beers ES	1st floor hallway adjacent to Classroom B101 (high)	11/30/15	< 1		
BES-1130-19B	Beers ES	1st floor hallway adjacent to Classroom B101 (high)	11/30/15	< 1		
BES-1130-20A	Beers ES	1st floor hallway adjacent to Classroom B101 (low)	11/30/15	< 1		
BES-1130-20B	Beers ES	1st floor hallway adjacent to Classroom B101 (low)	11/30/15	< 1		
BES-1130-21A	Beers ES	1st floor hallway across from Classroom B106	11/30/15	< 1		
BES-1130-21B	Beers ES	1st floor hallway across from Classroom B106	11/30/15	< 1		
BES-1130-22A	Beers ES	1st floor hallway adjacent to Auditorium C101 (high)	11/30/15	< 1		
BES-1130-22B	Beers ES	1st floor hallway adjacent to Auditorium C101 (high)	11/30/15	< 1		
BES-1130-23A	Beers ES	1st floor hallway adjacent to Auditorium C101 (low)	11/30/15	< 1		
BES-1130-23B	Beers ES	1st floor hallway adjacent to Auditorium C101 (low)	11/30/15	< 1		
BES-1130-24A	Beers ES	Basement floor inside Cafeteria (high)	11/30/15	< 1		
BES-1130-24B	Beers ES	Basement floor inside Cafeteria (high)	11/30/15	< 1		
BES-1130-25A	Beers ES	Basement floor inside Cafeteria (low)	11/30/15	< 1		
BES-1130-25B	Beers ES	Basement floor inside Cafeteria (low)	11/30/15	< 1		
				<b>Percentage of Passed Samples</b>		<b>100.00%</b>
				<b>Percentage of Failed Samples</b>		<b>0.00%</b>

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BES-1210-1A	Brent ES	3rd floor hallway across from Classroom 304	12/10/15	< 1		
BES-1210-1B	Brent ES	3rd floor hallway across from Classroom 304	12/10/15	< 1		
BES-1210-2A	Brent ES	3rd floor hallway across from Classroom 310	12/10/15	< 1		
BES-1210-2B	Brent ES	3rd floor hallway across from Classroom 310	12/10/15	< 1		
BES-1210-3A	Brent ES	2nd floor hallway across from Classroom 210	12/10/15	< 1		
BES-1210-3B	Brent ES	2nd floor hallway across from Classroom 210	12/10/15	< 1		
BES-1210-4A	Brent ES	2nd floor hallway across from Classroom 204	12/10/15	< 1		
BES-1210-4B	Brent ES	2nd floor hallway across from Classroom 204	12/10/15	< 1		
BES-1210-5A	Brent ES	2nd floor inside Classroom 204	12/10/15	< 1		
BES-1210-5B	Brent ES	2nd floor inside Classroom 204	12/10/15	< 1		
BES-1210-6A	Brent ES	2nd floor inside Classroom 202	12/10/15	< 1		
BES-1210-6B	Brent ES	2nd floor inside Classroom 202	12/10/15	< 1		
BES-1210-7A	Brent ES	1st floor inside Classroom 102	12/10/15	< 1		
BES-1210-7B	Brent ES	1st floor inside Classroom 102	12/10/15	< 1		
BES-1210-8A	Brent ES	1st floor inside Classroom 104	12/10/15	< 1		
BES-1210-8B	Brent ES	1st floor inside Classroom 104	12/10/15	< 1		
BES-1210-9A	Brent ES	1st floor inside Classroom 108	12/10/15	< 1		
BES-1210-9B	Brent ES	1st floor inside Classroom 108	12/10/15	< 1		
BES-1210-10A	Brent ES	1st floor inside Classroom 110	12/10/15	< 1		
BES-1210-10B	Brent ES	1st floor inside Classroom 110	12/10/15	< 1		
BES-1210-11A	Brent ES	1st floor inside Classroom 116	12/10/15	< 1		
BES-1210-11B	Brent ES	1st floor inside Classroom 115	12/10/15	< 1		
BES-1210-12A	Brent ES	1st floor inside Classroom 118	12/10/15	< 1		
BES-1210-12B	Brent ES	1st floor inside Classroom 118	12/10/15	< 1		
BES-1210-13A	Brent ES	1st floor hallway adjacent to Storage 111	12/10/15	< 1		
BES-1210-13B	Brent ES	1st floor hallway adjacent to Storage 111	12/10/15	< 1		
BES-1210-14A	Brent ES	1st floor inside Multi-Purpose Room	12/10/15	< 1		
BES-1210-14B	Brent ES	1st floor inside Multi-Purpose Room	12/10/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BEC-0310-1A	Brightwood EC	3rd floor inside Classroom 316	3/10/16	< 1		
BEC-0310-1B	Brightwood EC	3rd floor inside Classroom 316	3/10/16	< 1		
BEC-0310-2A	Brightwood EC	3rd floor inside Classroom 331	3/10/16	< 1		
BEC-0310-2B	Brightwood EC	3rd floor inside Classroom 331	3/10/16	< 1		
BEC-0310-3A	Brightwood EC	3rd floor inside Classroom 314	3/10/16	< 1		
BEC-0310-3B	Brightwood EC	3rd floor inside Classroom 314	3/10/16	< 1		
BEC-0310-4A	Brightwood EC	3rd floor inside Teacher's Workroom 325	3/10/16	< 1		
BEC-0310-4B	Brightwood EC	3rd floor inside Teacher's Workroom 325	3/10/16	< 1		
BEC-0310-5A	Brightwood EC	3rd floor inside Classroom 312	3/10/16	< 1		
BEC-0310-5B	Brightwood EC	3rd floor inside Classroom 312	3/10/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BEC-0310-6A	Brightwood EC	3rd floor inside Classroom 310	3/10/16	< 1		
BEC-0310-6B	Brightwood EC	3rd floor inside Classroom 310	3/10/16	< 1		
BEC-0310-7A	Brightwood EC	3rd floor inside Classroom 308	3/10/16	< 1		
BEC-0310-7B	Brightwood EC	3rd floor inside Classroom 308	3/10/16	< 1		
BEC-0310-8A	Brightwood EC	3rd floor inside Classroom 309	3/10/16	< 1		
BEC-0310-8B	Brightwood EC	3rd floor inside Classroom 309	3/10/16	< 1		
BEC-0310-9A	Brightwood EC	3rd floor hallway adjacent to Storage Room 307 (high)	3/10/16	< 1		
BEC-0310-9B	Brightwood EC	3rd floor hallway adjacent to Storage Room 307 (high)	3/10/16	< 1		
BEC-0310-10A	Brightwood EC	3rd floor hallway adjacent to Storage Room 307 (low)	3/10/16	< 1		
BEC-0310-10B	Brightwood EC	3rd floor hallway adjacent to Storage Room 307 (low)	3/10/16	< 1		
BEC-0310-11A	Brightwood EC	2nd floor inside Classroom 218	3/10/16	< 1		
BEC-0310-11B	Brightwood EC	2nd floor inside Classroom 218	3/10/16	< 1		
BEC-0310-12A	Brightwood EC	2nd floor inside Classroom 231	3/10/16	< 1		
BEC-0310-12B	Brightwood EC	2nd floor inside Classroom 231	3/10/16	< 1		
BEC-0310-13A	Brightwood EC	2nd floor inside Classroom 216	3/10/16	< 1		
BEC-0310-13B	Brightwood EC	2nd floor inside Classroom 216	3/10/16	< 1		
BEC-0310-14A	Brightwood EC	2nd floor inside Classroom 224	3/10/16	< 1		
BEC-0310-14B	Brightwood EC	2nd floor inside Classroom 224	3/10/16	< 1		
BEC-0310-15A	Brightwood EC	2nd floor inside Classroom 228	3/10/16	< 1		
BEC-0310-15B	Brightwood EC	2nd floor inside Classroom 228	3/10/16	< 1		
BEC-0310-16A	Brightwood EC	2nd floor inside Classroom 239	3/10/16	< 1		
BEC-0310-16B	Brightwood EC	2nd floor inside Classroom 239	3/10/16	< 1		
BEC-0310-17A	Brightwood EC	2nd floor inside Teacher's Workroom 237	3/10/16	< 1		
BEC-0310-17B	Brightwood EC	2nd floor inside Teacher's Workroom 237	3/10/16	< 1		
BEC-0310-18A	Brightwood EC	2nd floor inside Classroom 235	3/10/16	< 1		
BEC-0310-18B	Brightwood EC	2nd floor inside Classroom 235	3/10/16	< 1		
BEC-0310-19A	Brightwood EC	2nd floor inside Classroom 212	3/10/16	< 1		
BEC-0310-19B	Brightwood EC	2nd floor inside Classroom 212	3/10/16	< 1		
BEC-0310-20A	Brightwood EC	2nd floor inside Classroom 213	3/10/16	< 1		
BEC-0310-20B	Brightwood EC	2nd floor inside Classroom 213	3/10/16	< 1		
BEC-0310-21A	Brightwood EC	2nd floor inside Classroom 210	3/10/16	< 1		
BEC-0310-21B	Brightwood EC	2nd floor inside Classroom 210	3/10/16	< 1		
BEC-0310-22A	Brightwood EC	2nd floor hallway adjacent to Storage Room 211 (high)	3/10/16	< 1		
BEC-0310-22B	Brightwood EC	2nd floor hallway adjacent to Storage Room 211 (high)	3/10/16	< 1		
BEC-0310-23A	Brightwood EC	2nd floor hallway adjacent to Storage Room 211 (low)	3/10/16	< 1		
BEC-0310-23B	Brightwood EC	2nd floor hallway adjacent to Storage Room 211 (low)	3/10/16	< 1		
BEC-0310-24A	Brightwood EC	2nd floor inside Classroom 214	3/10/16	< 1		
BEC-0310-24B	Brightwood EC	2nd floor inside Classroom 214	3/10/16	< 1		
BEC-0310-25A	Brightwood EC	1st floor inside Classroom 138	3/10/16	< 1		
BEC-0310-25B	Brightwood EC	1st floor inside Classroom 138	3/10/16	< 1		
BEC-0310-26A	Brightwood EC	1st floor inside Classroom 137	3/10/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BEC-0310-26B	Brightwood EC	1st floor inside Classroom 137	3/10/16	< 1		
BEC-0310-27A	Brightwood EC	1st floor inside Classroom 136	3/10/16	< 1		
BEC-0310-27B	Brightwood EC	1st floor inside Classroom 136	3/10/16	< 1		
BEC-0310-28A	Brightwood EC	1st floor inside Classroom 142	3/10/16	< 1		
BEC-0310-28B	Brightwood EC	1st floor inside Classroom 142	3/10/16	< 1		
BEC-0310-29A	Brightwood EC	1st floor inside Classroom 146	3/10/16	< 1		
BEC-0310-29B	Brightwood EC	1st floor inside Classroom 146	3/10/16	< 1		
BEC-0310-30A	Brightwood EC	1st floor inside Classroom 147	3/10/16	< 1		
BEC-0310-30B	Brightwood EC	1st floor inside Classroom 147	3/10/16	< 1		
BEC-0310-31A	Brightwood EC	1st floor inside Teacher's Workroom 145	3/10/16	< 1		
BEC-0310-31B	Brightwood EC	1st floor inside Teacher's Workroom 145	3/10/16	< 1		
BEC-0310-32A	Brightwood EC	1st floor inside Classroom 143	3/10/16	< 1		
BEC-0310-32B	Brightwood EC	1st floor inside Classroom 143	3/10/16	< 1		
BEC-0310-33A	Brightwood EC	1st floor inside Classroom 130	3/10/16	< 1		
BEC-0310-33B	Brightwood EC	1st floor inside Classroom 130	3/10/16	< 1		
BEC-0310-34A	Brightwood EC	1st floor inside Classroom 128	3/10/16	< 1		
BEC-0310-34B	Brightwood EC	1st floor inside Classroom 128	3/10/16	< 1		
BEC-0310-35A	Brightwood EC	1st floor inside Classroom 125	3/10/16	< 1		
BEC-0310-35B	Brightwood EC	1st floor inside Classroom 125	3/10/16	< 1		
BEC-0310-36A	Brightwood EC	1st floor hallway across from Janitor Closet 126 (high)	3/10/16	< 1		
BEC-0310-36B	Brightwood EC	1st floor hallway across from Janitor Closet 126 (high)	3/10/16	< 1		
BEC-0310-37A	Brightwood EC	1st floor hallway across from Janitor Closet 126 (low)	3/10/16	< 1		
BEC-0310-37B	Brightwood EC	1st floor hallway across from Janitor Closet 126 (low)	3/10/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BMS-1103-1A	Brookland MS	2nd floor hallway between Boy's and Girl's Rooms near elevator (high)	11/3/15	< 1		
BMS-1103-1B	Brookland MS	2nd floor hallway between Boy's and Girl's Rooms near elevator (high)	11/3/15	< 1		
BMS-1103-2A	Brookland MS	2nd floor hallway between Boy's and Girl's Rooms near elevator (low)	11/3/15	< 1		
BMS-1103-2B	Brookland MS	2nd floor hallway between Boy's and Girl's Rooms near elevator (low)	11/3/15	< 1		
BMS-1103-3A	Brookland MS	2nd floor hallway across from Digital Lab 2305 (high)	11/3/15	< 1		
BMS-1103-3B	Brookland MS	2nd floor hallway across from Digital Lab 2305 (high)	11/3/15	< 1		
BMS-1103-4A	Brookland MS	2nd floor hallway across from Digital Lab 2305 (low)	11/3/15	< 1		
BMS-1103-4B	Brookland MS	2nd floor hallway across from Digital Lab 2305 (low)	11/3/15	< 1		
BMS-1103-5A	Brookland MS	1st floor hallway across from Assistant Principal's Office 1303 (high)	11/3/15	< 1		
BMS-1103-5B	Brookland MS	1st floor hallway across from Assistant Principal's Office 1303 (high)	11/3/15	< 1		
BMS-1103-6A	Brookland MS	1st floor hallway across from Assistant Principal's Office 1303 (low)	11/3/15	< 1		
BMS-1103-6B	Brookland MS	1st floor hallway across from Assistant Principal's Office 1303 (low)	11/3/15	< 1		
BMS-1103-7A	Brookland MS	1st floor hallway between Boy's and Girl's Rooms near elevator (high)	11/3/15	< 1		
BMS-1103-7B	Brookland MS	1st floor hallway between Boy's and Girl's Rooms near elevator (high)	11/3/15	< 1		
BMS-1103-8A	Brookland MS	1st floor hallway between Boy's and Girl's Rooms near elevator (low)	11/3/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BMS-1103-8B	Brookland MS	1st floor hallway between Boy's and Girl's Rooms near elevator (low)	11/3/15	< 1		
BMS-1103-9A	Brookland MS	Lower level hallway across from Assistant Principal's Office L303 (high)	11/3/15	< 1		
BMS-1103-9B	Brookland MS	Lower level hallway across from Assistant Principal's Office L303 (high)	11/3/15	< 1		
BMS-1103-10A	Brookland MS	Lower level hallway across from Assistant Principal's Office L303 (low)	11/3/15	< 1		
BMS-1103-10B	Brookland MS	Lower level hallway across from Assistant Principal's Office L303 (low)	11/3/15	< 1		
BMS-1103-11A	Brookland MS	Lower level hallway between Boy's and Girl's Rooms near elevator (high)	11/3/15	< 1		
BMS-1103-11B	Brookland MS	Lower level hallway between Boy's and Girl's Rooms near elevator (high)	11/3/15	< 1		
BMS-1103-12A	Brookland MS	Lower level hallway between Boy's and Girl's Rooms near elevator (low)	11/3/15	< 1		
BMS-1103-12B	Brookland MS	Lower level hallway between Boy's and Girl's Rooms near elevator (low)	11/3/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BEC-1020-1A	Browne EC	3rd floor hallway adjacent to Classroom 3-337	10/20/15	< 1		
BEC-1020-1B	Browne EC	3rd floor hallway adjacent to Classroom 3-337	10/20/15	< 1		
BEC-1020-2A	Browne EC	3rd floor hallway adjacent to Classroom 3-328	10/20/15	< 1		
BEC-1020-2B	Browne EC	3rd floor hallway adjacent to Classroom 3-328	10/20/15	< 1		
BEC-1020-3A	Browne EC	3rd floor hallway adjacent to Classroom 3-313	10/20/15	< 1		
BEC-1020-3B	Browne EC	3rd floor hallway adjacent to Classroom 3-313	10/20/15	< 1		
BEC-1020-4A	Browne EC	3rd floor hallway adjacent to Classroom 3-307	10/20/15	< 1		
BEC-1020-4B	Browne EC	3rd floor hallway adjacent to Classroom 3-307	10/20/15	< 1		
BEC-1020-5A	Browne EC	2nd floor hallway adjacent to Classroom 2-301	10/20/15	< 1		
BEC-1020-5B	Browne EC	2nd floor hallway adjacent to Classroom 2-301	10/20/15	< 1		
BEC-1020-6A	Browne EC	2nd floor hallway adjacent to Classroom 2-239	10/20/15	< 1		
BEC-1020-6B	Browne EC	2nd floor hallway adjacent to Classroom 2-239	10/20/15	< 1		
BEC-1020-7A	Browne EC	2nd floor hallway adjacent to Classroom 2-235	10/20/15	< 1		
BEC-1020-7B	Browne EC	2nd floor hallway adjacent to Classroom 2-235	10/20/15	< 1		
BEC-1020-8A	Browne EC	2nd floor hallway adjacent to Classroom 2-213	10/20/15	< 1		
BEC-1020-8B	Browne EC	2nd floor hallway adjacent to Classroom 2-213	10/20/15	< 1		
BEC-1020-9A	Browne EC	2nd floor hallway adjacent to Classroom 2-217	10/20/15	< 1		
BEC-1020-9B	Browne EC	2nd floor hallway adjacent to Classroom 2-217	10/20/15	< 1		
BEC-1020-10A	Browne EC	2nd floor hallway adjacent to Classroom 2-269	10/20/15	< 1		
BEC-1020-10B	Browne EC	2nd floor hallway adjacent to Classroom 2-269	10/20/15	< 1		
BEC-1020-11A	Browne EC	2nd floor hallway adjacent to Classroom 2-273	10/20/15	< 1		
BEC-1020-11B	Browne EC	2nd floor hallway adjacent to Classroom 2-273	10/20/15	< 1		
BEC-1020-12A	Browne EC	1st floor hallway near Classroom 1-193	10/20/15	< 1		
BEC-1020-12B	Browne EC	1st floor hallway near Classroom 1-193	10/20/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BEC-1020-13A	Browne EC	1st floor hallway adjacent to Classroom 1-208	10/20/15	< 1		
BEC-1020-13B	Browne EC	1st floor hallway adjacent to Classroom 1-208	10/20/15	< 1		
BEC-1020-14A	Browne EC	1st floor hallway adjacent to Small Gym	10/20/15	< 1		
BEC-1020-14B	Browne EC	1st floor hallway adjacent to Small Gym	10/20/15	< 1		
BEC-1020-15A	Browne EC	1st floor inside Classroom 1-128	10/20/15	1.3		
BEC-1020-15B	Browne EC	1st floor inside Classroom 1-128	10/20/15	< 1		
BEC-1020-16A	Browne EC	1st floor inside Classroom 1-124	10/20/15	< 1		
BEC-1020-16B	Browne EC	1st floor inside Classroom 1-124	10/20/15	< 1		
BEC-1020-17A	Browne EC	1st floor hallway adjacent to Classroom 1-124	10/20/15	< 1		
BEC-1020-17B	Browne EC	1st floor hallway adjacent to Classroom 1-124	10/20/15	< 1		
BEC-1020-18A	Browne EC	1st floor inside Classroom 1-119	10/20/15		32	Filter installed.
BEC-1020-18B	Browne EC	1st floor inside Classroom 1-119	10/20/15	6.5		
BEC-0113-1A	Browne EC	1st floor inside Classroom 1-119 (Retest)	1/13/16	2.3		
BEC-0113-1B	Browne EC	1st floor inside Classroom 1-119 (Retest)	1/13/16	< 1		
BEC-1020-19A	Browne EC	1st floor hallway adjacent to Classroom 1-119	10/20/15	< 1		
BEC-1020-19B	Browne EC	1st floor hallway adjacent to Classroom 1-119	10/20/15	< 1		
BEC-1020-20A	Browne EC	1st floor inside Classroom 1-099	10/20/15	< 1		
BEC-1020-20B	Browne EC	1st floor inside Classroom 1-099	10/20/15	< 1		
BEC-1020-21A	Browne EC	1st floor inside Classroom 1-112	10/20/15	2		
BEC-1020-21B	Browne EC	1st floor inside Classroom 1-112	10/20/15	< 1		
BEC-1020-22A	Browne EC	1st floor inside Classroom 1-111	10/20/15	< 1		
BEC-1020-22B	Browne EC	1st floor inside Classroom 1-111	10/20/15	< 1		
BEC-1020-23A	Browne EC	1st floor inside Classroom 1-103	10/20/15	< 1		
BEC-1020-23B	Browne EC	1st floor inside Classroom 1-103	10/20/15	< 1		
BEC-1020-24A	Browne EC	1st floor inside Classroom 1-108	10/20/15	< 1		
BEC-1020-24B	Browne EC	1st floor inside Classroom 1-108	10/20/15	< 1		
BEC-1020-25A	Browne EC	1st floor hallway adjacent to Classroom 1-108	10/20/15	< 1		
BEC-1020-25B	Browne EC	1st floor hallway adjacent to Classroom 1-108	10/20/15	< 1		
BEC-1020-26A	Browne EC	1st floor hallway adjacent to Classroom 1-157	10/20/15	< 1		
BEC-1020-26B	Browne EC	1st floor hallway adjacent to Classroom 1-157	10/20/15	< 1		
BEC-1020-27A	Browne EC	1st floor hallway adjacent to Classroom 1-179	10/20/15	< 1		
BEC-1020-27B	Browne EC	1st floor hallway adjacent to Classroom 1-179	10/20/15	< 1		
BEC-1020-28A	Browne EC	Basement floor inside Cafeteria near Kitchen	10/20/15	< 1		
BEC-1020-28B	Browne EC	Basement floor inside Cafeteria near Kitchen	10/20/15	< 1		
BEC-1020-29A	Browne EC	Basement floor inside Cafeteria other side	10/20/15	< 1		
BEC-1020-29B	Browne EC	Basement floor inside Cafeteria other side	10/20/15	< 1		
BEC-1020-30A	Browne EC	Basement floor inside Gym	10/20/15	< 1		
BEC-1020-30B	Browne EC	Basement floor inside Gym	10/20/15	< 1		
BEC-1020-31A	Browne EC	Basement floor across from Gym	10/20/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BEC-1020-31B	Browne EC	Basement floor across from Gym	10/20/15	< 1		
BEC-1020-32A	Browne EC	Basement floor inside Boy's Locker Room	10/20/15	< 1		
BEC-1020-32B	Browne EC	Basement floor inside Boy's Locker Room	10/20/15	< 1		
BEC-1020-33A	Browne EC	Basement floor inside Girl's Locker Room	10/20/15	< 1		
BEC-1020-33B	Browne EC	Basement floor inside Girl's Locker Room	10/20/15	< 1		
<b>Percentage of Passed Samples</b>						<b>98.57%</b>
<b>Percentage of Failed Samples</b>						<b>1.43%</b>
BM-0405-1A	Bruce - Monroe ES @ Parkview	2nd floor hallway across from Classroom 221	4/5/16	< 1		
BM-0405-1B	Bruce - Monroe ES @ Parkview	2nd floor hallway across from Classroom 221	4/5/16	< 1		
BM-0405-2A	Bruce - Monroe ES @ Parkview	2nd floor hallway at entrance to Library	4/5/16	< 1		
BM-0405-2B	Bruce - Monroe ES @ Parkview	2nd floor hallway at entrance to Library	4/5/16	< 1		
BM-0405-3A	Bruce - Monroe ES @ Parkview	2nd floor hallway across from Classroom 213	4/5/16	< 1		
BM-0405-3B	Bruce - Monroe ES @ Parkview	2nd floor hallway across from Classroom 213	4/5/16	< 1		
BM-0405-4A	Bruce - Monroe ES @ Parkview	1st floor hallway across from Classroom 121	4/5/16	< 1		
BM-0405-4B	Bruce - Monroe ES @ Parkview	1st floor hallway across from Classroom 121	4/5/16	< 1		
BM-0405-5A	Bruce - Monroe ES @ Parkview	1st floor hallway near Conference Rm. 103	4/5/16	< 1		
BM-0405-5B	Bruce - Monroe ES @ Parkview	1st floor hallway near Conference Rm. 103	4/5/16	< 1		
BM-0405-6A	Bruce - Monroe ES @ Parkview	1st floor inside Nurse's Office	4/5/16	< 1		
BM-0405-6B	Bruce - Monroe ES @ Parkview	1st floor inside Nurse's Office	4/5/16	< 1		
BM-0405-7A	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 123	4/5/16	< 1		
BM-0405-7B	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 123	4/5/16	< 1		
BM-0405-8A	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 126	4/5/16	< 1		
BM-0405-8B	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 126	4/5/16	< 1		
BM-0405-9A	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 127	4/5/16	< 1		
BM-0405-9B	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 127	4/5/16	< 1		
BM-0405-10A	Bruce - Monroe ES @ Parkview	1st floor hallway across from School Psychologist 134	4/5/16	< 1		
BM-0405-10B	Bruce - Monroe ES @ Parkview	1st floor hallway across from School Psychologist 134	4/5/16	< 1		
BM-0405-11A	Bruce - Monroe ES @ Parkview	Ground floor hallway near entrance to Gym	4/5/16	< 1		
BM-0405-11B	Bruce - Monroe ES @ Parkview	Ground floor hallway near entrance to Gym	4/5/16	< 1		
BM-0405-12A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 024	4/5/16	< 1		
BM-0405-12B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 024	4/5/16	< 1		
BM-0405-13A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 022	4/5/16	< 1		
BM-0405-13B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 022	4/5/16	< 1		
BM-0405-14A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 021	4/5/16	< 1		
BM-0405-14B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 021	4/5/16	< 1		
BM-0405-15A	Bruce - Monroe ES @ Parkview	Ground floor hallway near Auditorium	4/5/16	< 1		
BM-0405-15B	Bruce - Monroe ES @ Parkview	Ground floor hallway near Auditorium	4/5/16	< 1		
BM-0405-16A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 006	4/5/16	< 1		
BM-0405-16B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 006	4/5/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BM-0405-17A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 007	4/5/16	< 1		
BM-0405-17B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 007	4/5/16	< 1		
BM-0405-18A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 008	4/5/16	< 1		
BM-0405-18B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 008	4/5/16	< 1		
BM-0405-19A	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 122	4/5/16	< 1		
BM-0405-19B	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 122	4/5/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BH-1104-1A	Bunker Hill ES	2nd floor hallway adjacent to Classroom 203	11/4/15	< 1		
BH-1104-1B	Bunker Hill ES	2nd floor hallway adjacent to Classroom 203	11/4/15	< 1		
BH-1104-2A	Bunker Hill ES	2nd floor hallway adjacent to Classroom 216	11/4/15	< 1		
BH-1104-2B	Bunker Hill ES	2nd floor hallway adjacent to Classroom 216	11/4/15	< 1		
BH-1104-3A	Bunker Hill ES	2nd floor hallway adjacent to Classroom 210	11/4/15	< 1		
BH-1104-3B	Bunker Hill ES	2nd floor hallway adjacent to Classroom 210	11/4/15	< 1		
BH-1104-4A	Bunker Hill ES	2nd floor hallway adjacent to Classroom 206	11/4/15	< 1		
BH-1104-4B	Bunker Hill ES	2nd floor hallway adjacent to Classroom 206	11/4/15	< 1		
BH-1104-5A	Bunker Hill ES	1st floor inside Classroom 110	11/4/15	< 1		
BH-1104-5B	Bunker Hill ES	1st floor inside Classroom 110	11/4/15	< 1		
BH-1104-6A	Bunker Hill ES	1st floor hallway adjacent to Classroom 110	11/4/15	< 1		
BH-1104-6B	Bunker Hill ES	1st floor hallway adjacent to Classroom 110	11/4/15	< 1		
BH-1104-7A	Bunker Hill ES	1st floor inside Classroom 109	11/4/15	< 1		
BH-1104-7B	Bunker Hill ES	1st floor inside Classroom 109	11/4/15	< 1		
BH-1104-8A	Bunker Hill ES	1st floor inside Classroom 111	11/4/15	< 1		
BH-1104-8B	Bunker Hill ES	1st floor inside Classroom 111	11/4/15	< 1		
BH-1104-9A	Bunker Hill ES	1st floor inside Classroom 108	11/4/15	< 1		
BH-1104-9B	Bunker Hill ES	1st floor inside Classroom 108	11/4/15	< 1		
BH-1104-10A	Bunker Hill ES	1st floor hallway across from Storage Room 131	11/4/15	< 1		
BH-1104-10B	Bunker Hill ES	1st floor hallway across from Storage Room 131	11/4/15	< 1		
BH-1104-11A	Bunker Hill ES	1st floor hallway at entrance to Auditorium	11/4/15	< 1		
BH-1104-11B	Bunker Hill ES	1st floor hallway at entrance to Auditorium	11/4/15	< 1		
BH-1104-12A	Bunker Hill ES	1st floor inside Classroom 103	11/4/15	< 1		
BH-1104-12B	Bunker Hill ES	1st floor inside Classroom 103	11/4/15	< 1		
BH-1104-13A	Bunker Hill ES	1st floor inside Classroom 106	11/4/15	< 1		
BH-1104-13B	Bunker Hill ES	1st floor inside Classroom 106	11/4/15	< 1		
BH-1104-14A	Bunker Hill ES	1st floor inside Classroom 105	11/4/15	< 1		
BH-1104-14B	Bunker Hill ES	1st floor inside Classroom 105	11/4/15	< 1		
BH-1104-15A	Bunker Hill ES	1st floor hallway adjacent to Storage Room 144	11/4/15	< 1		
BH-1104-15B	Bunker Hill ES	1st floor hallway adjacent to Storage Room 144	11/4/15	< 1		
BH-1104-16A	Bunker Hill ES	Basement floor inside Cafeteria	11/4/15	< 1		
BH-1104-16B	Bunker Hill ES	Basement floor inside Cafeteria	11/4/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BES-0116-1A	Burrville ES	2nd floor hallway across from Custodian Closet (high)	11/5/15	< 1		
BES-0116-1B	Burrville ES	2nd floor hallway across from Custodian Closet (high)	11/5/15	< 1		
BES-0116-2A	Burrville ES	2nd floor hallway across from Custodian Closet (low)	11/5/15	< 1		
BES-0116-2B	Burrville ES	2nd floor hallway across from Custodian Closet (low)	11/5/15	< 1		
BES-0116-3A	Burrville ES	2nd floor hallway adjacent to Gym near exit (high)	11/5/15	< 1		
BES-0116-3B	Burrville ES	2nd floor hallway adjacent to Gym near exit (high)	11/5/15	< 1		
BES-0116-4A	Burrville ES	2nd floor hallway adjacent to Gym near exit (low)	11/5/15	< 1		
BES-0116-4B	Burrville ES	2nd floor hallway adjacent to Gym near exit (low)	11/5/15	< 1		
BES-0116-5A	Burrville ES	2nd floor inside Gym, adjacent to Kitchen	11/5/15	< 1		
BES-0116-5B	Burrville ES	2nd floor inside Gym, adjacent to Kitchen	11/5/15	< 1		
BES-0116-6A	Burrville ES	2nd floor hallway adjacent to Media Center (high)	11/5/15	< 1		
BES-0116-6B	Burrville ES	2nd floor hallway adjacent to Media Center (high)	11/5/15	< 1		
BES-0116-7A	Burrville ES	2nd floor hallway adjacent to Media Center (low)	11/5/15	< 1		
BES-0116-7B	Burrville ES	2nd floor hallway adjacent to Media Center (low)	11/5/15	< 1		
BES-0116-8A	Burrville ES	2nd floor hallway near elevator (high)	11/5/15	< 1		
BES-0116-8B	Burrville ES	2nd floor hallway near elevator (high)	11/5/15	< 1		
BES-0116-9A	Burrville ES	2nd floor hallway near elevator (low)	11/5/15	< 1		
BES-0116-9B	Burrville ES	2nd floor hallway near elevator (low)	11/5/15	< 1		
BES-0116-10A	Burrville ES	2nd floor inside Music Room 241	11/5/15	< 1		
BES-0116-10B	Burrville ES	2nd floor inside Music Room 241	11/5/15	< 1		
BES-0116-11A	Burrville ES	2nd floor inside Teacher's Lounge	11/5/15	1.5		
BES-0116-11B	Burrville ES	2nd floor inside Teacher's Lounge	11/5/15	1.8		
BES-0116-12A	Burrville ES	2nd floor inside Classroom 228 Kindergarten	11/5/15	< 1		
BES-0116-12B	Burrville ES	2nd floor inside Classroom 228 Kindergarten	11/5/15	< 1		
BES-0116-13A	Burrville ES	2nd floor inside Classroom 227 Kindergarten	11/5/15	< 1		
BES-0116-13B	Burrville ES	2nd floor inside Classroom 227 Kindergarten	11/5/15	< 1		
BES-0116-14A	Burrville ES	2nd floor hallway across from Classroom 227 Kindergarten (high)	11/5/15	< 1		
BES-0116-14B	Burrville ES	2nd floor hallway across from Classroom 227 Kindergarten (high)	11/5/15	< 1		
BES-0116-15A	Burrville ES	2nd floor hallway across from Classroom 227 Kindergarten (low)	11/5/15	< 1		
BES-0116-15B	Burrville ES	2nd floor hallway across from Classroom 227 Kindergarten (low)	11/5/15	< 1		
BES-0116-16A	Burrville ES	1st floor hallway adjacent to Boy's Room near Stair 1	11/5/15	< 1		
BES-0116-16B	Burrville ES	1st floor hallway adjacent to Boy's Room near Stair 1	11/5/15	< 1		
BES-0116-17A	Burrville ES	1st floor inside Classroom 115	11/5/15	< 1		
BES-0116-17B	Burrville ES	1st floor inside Classroom 115	11/5/15	< 1		
BES-0116-18A	Burrville ES	1st floor inside Classroom 114	11/5/15	< 1		
BES-0116-18B	Burrville ES	1st floor inside Classroom 114	11/5/15	< 1		
BES-0116-19A	Burrville ES	1st floor inside Classroom 113	11/5/15	< 1		
BES-0116-19B	Burrville ES	1st floor inside Classroom 113	11/5/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BES-0116-20A	Burrville ES	1st floor inside Pre-school	11/5/15	< 1		
BES-0116-20B	Burrville ES	1st floor inside Pre-school	11/5/15	< 1		
BES-0116-21A	Burrville ES	1st floor hallway adjacent to Pre-school (high)	11/5/15	< 1		
BES-0116-21B	Burrville ES	1st floor hallway adjacent to Pre-school (high)	11/5/15	< 1		
BES-0116-22A	Burrville ES	1st floor hallway adjacent to Pre-school (low)	11/5/15	< 1		
BES-0116-22B	Burrville ES	1st floor hallway adjacent to Pre-school (low)	11/5/15	< 1		
BES-0116-23A	Burrville ES	1st floor inside Classroom 108	11/5/15	< 1		
BES-0116-23B	Burrville ES	1st floor inside Classroom 108	11/5/15	< 1		
BES-0116-24A	Burrville ES	2nd floor inside Classroom 224	11/5/15	< 1		
BES-0116-24B	Burrville ES	2nd floor inside Classroom 224	11/5/15	< 1		
BES-0116-25A	Burrville ES	2nd floor inside Art Room 223 (left)	11/5/15	< 1		
BES-0116-25B	Burrville ES	2nd floor inside Art Room 223 (left)	11/5/15	< 1		
BES-0116-26A	Burrville ES	2nd floor inside Art Room 223 (right)	11/5/15	< 1		
BES-0116-26B	Burrville ES	2nd floor inside Art Room 223 (right)	11/5/15	< 1		
BES-0116-27A	Burrville ES	2nd floor inside Classroom 221	11/5/15	< 1		
BES-0116-27B	Burrville ES	2nd floor inside Classroom 221	11/5/15	< 1		
BES-0116-28A	Burrville ES	2nd floor inside Gym in Girl's Locker Room	11/5/15	2.2		
BES-0116-28B	Burrville ES	2nd floor inside Gym in Girl's Locker Room	11/5/15	1.8		
BES-0116-29A	Burrville ES	2nd floor inside Gym in Boy's Locker Room	11/5/15	< 1		
BES-0116-29B	Burrville ES	2nd floor inside Gym in Boy's Locker Room	11/5/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BES-0324-1A	Burroughs ES	1st floor hallway across from Classroom 14	11/2/15	< 1		
BES-0324-1B	Burroughs ES	1st floor hallway across from Classroom 14	11/2/15	< 1		
BES-0324-2A	Burroughs ES	1st floor hallway adjacent to Classroom 9	11/2/15	< 1		
BES-0324-2B	Burroughs ES	1st floor hallway adjacent to Classroom 9	11/2/15	< 1		
BES-0324-3A	Burroughs ES	1st floor hallway adjacent to Classroom 8	11/2/15	< 1		
BES-0324-3B	Burroughs ES	1st floor hallway adjacent to Classroom 8	11/2/15	< 1		
BES-0324-4A	Burroughs ES	1st floor hallway across from Classroom 3	11/2/15	< 1		
BES-0324-4B	Burroughs ES	1st floor hallway across from Classroom 3	11/2/15	< 1		
BES-0324-5A	Burroughs ES	1st floor inside Classroom 25	11/2/15	< 1		
BES-0324-5B	Burroughs ES	1st floor inside Classroom 25	11/2/15	< 1		
BES-0324-6A	Burroughs ES	1st floor hallway across from Classroom 27	11/2/15	< 1		
BES-0324-6B	Burroughs ES	1st floor hallway across from Classroom 27	11/2/15	< 1		
BES-0324-7A	Burroughs ES	1st floor inside Classroom 35	11/2/15	< 1		
BES-0324-7B	Burroughs ES	1st floor inside Classroom 35	11/2/15	< 1		
BES-0324-8A	Burroughs ES	1st floor inside Classroom 34	11/2/15	< 1		
BES-0324-8B	Burroughs ES	1st floor inside Classroom 34	11/2/15	< 1		
BES-0324-9A	Burroughs ES	1st floor hallway at entrance to Cafeteria (high)	11/2/15	< 1		
BES-0324-9B	Burroughs ES	1st floor hallway at entrance to Cafeteria (high)	11/2/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
BES-0324-10A	Burroughs ES	1st floor hallway at entrance to Cafeteria (low)	11/2/15	< 1		
BES-0324-10B	Burroughs ES	1st floor hallway at entrance to Cafeteria (low)	11/2/15	< 1		
BES-0324-11A	Burroughs ES	Basement floor inside Classroom 22	11/2/15	< 1		
BES-0324-11B	Burroughs ES	Basement floor inside Classroom 22	11/2/15	< 1		
BES-0324-12A	Burroughs ES	Basement floor inside Classroom 21	11/2/15	< 1		
BES-0324-12B	Burroughs ES	Basement floor inside Classroom 21	11/2/15	< 1		
BES-0324-13A	Burroughs ES	Basement floor inside Classroom 20	11/2/15	< 1		
BES-0324-13B	Burroughs ES	Basement floor inside Classroom 20	11/2/15	< 1		
BES-0324-14A	Burroughs ES	Basement floor hallway adjacent to Classroom 20	11/2/15	< 1		
BES-0324-14B	Burroughs ES	Basement floor hallway adjacent to Classroom 20	11/2/15	< 1		
BES-0324-15A	Burroughs ES	Basement floor inside Classroom 19	11/2/15	< 1		
BES-0324-15B	Burroughs ES	Basement floor inside Classroom 19	11/2/15	< 1		
BES-0324-16A	Burroughs ES	Basement floor hallway adjacent to Classroom 19	11/2/15	< 1		
BES-0324-16B	Burroughs ES	Basement floor hallway adjacent to Classroom 19	11/2/15	< 1		
BES-0324-17A	Burroughs ES	Basement floor inside Classroom 18	11/2/15	< 1		
BES-0324-17B	Burroughs ES	Basement floor inside Classroom 18	11/2/15	< 1		
<b>Percentage of Passed Samples</b>					<b>100.00%</b>	
<b>Percentage of Failed Samples</b>					<b>0.00%</b>	
CAE-1019-1A	C.H.O.I.C.E Academy @ Emery	3rd floor hallway at Stairwell 3	10/19/15	< 1		
CAE-1019-1B	C.H.O.I.C.E Academy @ Emery	3rd floor hallway at Stairwell 3	10/19/15	< 1		
CAE-1019-2A	C.H.O.I.C.E Academy @ Emery	3rd floor hallway adjacent to Classroom 315	10/19/15	< 1		
CAE-1019-2B	C.H.O.I.C.E Academy @ Emery	3rd floor hallway adjacent to Classroom 315	10/19/15	< 1		
CAE-1019-3A	C.H.O.I.C.E Academy @ Emery	3rd floor hallway at Stairwell 1	10/19/15	< 1		
CAE-1019-3B	C.H.O.I.C.E Academy @ Emery	3rd floor hallway at Stairwell 1	10/19/15	< 1		
CAE-1010-4A	C.H.O.I.C.E Academy @ Emery	3rd floor inside Classroom 316	10/19/15	4.1		
CAE-1019-4B	C.H.O.I.C.E Academy @ Emery	3rd floor inside Classroom 316	10/19/15		32	Filter Installed.
CE-0205-2A	C.H.O.I.C.E Academy @ Emery	3rd floor inside Classroom 316 (Retest)	2/5/16	4.3		
CE-0205-2B	C.H.O.I.C.E Academy @ Emery	3rd floor inside Classroom 316 (Retest)	2/5/16	4		
CAE-1019-5A	C.H.O.I.C.E Academy @ Emery	3rd floor inside Classroom 312	10/19/15	13		
CAE-1019-5B	C.H.O.I.C.E Academy @ Emery	3rd floor inside Classroom 312	10/19/15	3.1		
CAE-1019-6A	C.H.O.I.C.E Academy @ Emery	2nd floor hallway adjacent to Girl's Room	10/19/15	< 1		
CAE-1019-6B	C.H.O.I.C.E Academy @ Emery	2nd floor hallway adjacent to Girl's Room	10/19/15	< 1		
CAE-1019-7A	C.H.O.I.C.E Academy @ Emery	2nd floor hallway at Stairwell 1	10/19/15	< 1		
CAE-1019-7B	C.H.O.I.C.E Academy @ Emery	2nd floor hallway at Stairwell 1	10/19/15	< 1		
CAE-1019-8A	C.H.O.I.C.E Academy @ Emery	2nd floor hallway adjacent to Men's Restroom	10/19/15	< 1		
CAE-1019-8B	C.H.O.I.C.E Academy @ Emery	2nd floor hallway adjacent to Men's Restroom	10/19/15	< 1		
CAE-1019-9A	C.H.O.I.C.E Academy @ Emery	1st floor hallway adjacent to Men's Restroom	10/19/15	< 1		
CAE-1019-9B	C.H.O.I.C.E Academy @ Emery	1st floor hallway adjacent to Men's Restroom	10/19/15	< 1		
CAE-1019-10A	C.H.O.I.C.E Academy @ Emery	1st floor hallway adjacent to Classroom 110	10/19/15	< 1		
CAE-1019-10B	C.H.O.I.C.E Academy @ Emery	1st floor hallway adjacent to Classroom 110	10/19/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
CAE-1019-11A	C.H.O.I.C.E Academy @ Emery	1st floor inside Classroom 113	10/19/15	< 1		
CAE-1019-11B	C.H.O.I.C.E Academy @ Emery	1st floor inside Classroom 113	10/19/15	< 1		
CAE-1019-12A	C.H.O.I.C.E Academy @ Emery	1st floor inside Classroom 112	10/19/15	< 1		
CAE-1019-12B	C.H.O.I.C.E Academy @ Emery	1st floor inside Classroom 112	10/19/15	< 1		
CAE-1019-13A	C.H.O.I.C.E Academy @ Emery	3rd floor inside Classroom 314	10/19/15		44	Filter Installed.
CAE-1019-13B	C.H.O.I.C.E Academy @ Emery	3rd floor inside Classroom 314	10/19/15	8.5		
CE-0205-1A	C.H.O.I.C.E Academy @ Emery	3rd floor inside Classroom 314 (Retest)	2/5/16	2.5		
CE-0205-1B	C.H.O.I.C.E Academy @ Emery	3rd floor inside Classroom 314 (Retest)	2/5/16	< 1		
<b>Percentage of Passed Samples</b>						<b>93.33%</b>
<b>Percentage of Failed Samples</b>						<b>6.67%</b>
CWH-1202-1A	C.W. Harris ES	2nd floor hallway across from Classroom 246	12/2/15	< 1		
CWH-1202-1B	C.W. Harris ES	2nd floor hallway across from Classroom 246	12/2/15	< 1		
CWH-1202-2A	C.W. Harris ES	2nd floor hallway across from Classroom 218	12/2/15	< 1		
CWH-1202-2B	C.W. Harris ES	2nd floor hallway across from Classroom 218	12/2/15	< 1		
CWH-1202-3A	C.W. Harris ES	1st floor hallway across from Storage Room	12/2/15	< 1		
CWH-1202-3B	C.W. Harris ES	1st floor hallway across from Storage Room	12/2/15	< 1		
CWH-1202-4A	C.W. Harris ES	1st floor inside Health Suite	12/2/15	< 1		
CWH-1202-4B	C.W. Harris ES	1st floor inside Health Suite	12/2/15	< 1		
CWH-1202-5A	C.W. Harris ES	1st floor inside Multi-Purpose Room	12/2/15	< 1		
CWH-1202-5B	C.W. Harris ES	1st floor inside Multi-Purpose Room	12/2/15	< 1		
CWH-1202-6A	C.W. Harris ES	1st floor hallway between Boy's and Girl's Restrooms	12/2/15	< 1		
CWH-1202-6B	C.W. Harris ES	1st floor hallway between Boy's and Girl's Restrooms	12/2/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
CEC-0204-1A	Cardozo EC	3rd floor hallway across from Classroom 3502 (high)	2/4/16	< 1		
CEC-0204-1B	Cardozo EC	3rd floor hallway across from Classroom 3502 (high)	2/4/16	< 1		
CEC-0204-2A	Cardozo EC	3rd floor hallway across from Classroom 3502 (low)	2/4/16	< 1		
CEC-0204-2B	Cardozo EC	3rd floor hallway across from Classroom 3502 (low)	2/4/16	< 1		
CEC-0204-3A	Cardozo EC	3rd floor hallway across from Classroom 3204 (high)	2/4/16	< 1		
CEC-0204-3B	Cardozo EC	3rd floor hallway across from Classroom 3204 (high)	2/4/16	< 1		
CEC-0204-4A	Cardozo EC	3rd floor hallway across from Classroom 3204 (low)	2/4/16	< 1		
CEC-0204-4B	Cardozo EC	3rd floor hallway across from Classroom 3204 (low)	2/4/16	< 1		
CEC-0204-5A	Cardozo EC	2nd floor hallway across from Classroom 2204 (high)	2/4/16	< 1		
CEC-0204-5B	Cardozo EC	2nd floor hallway across from Classroom 2204 (high)	2/4/16	< 1		
CEC-0204-6A	Cardozo EC	2nd floor hallway across from Classroom 2204 (low)	2/4/16	< 1		
CEC-0203-6B	Cardozo EC	2nd floor hallway across from Classroom 2204 (low)	2/4/16	< 1		
CEC-0204-7A	Cardozo EC	2nd floor hallway across from Classroom 2602 (high)	2/4/16	< 1		
CEC-0204-7B	Cardozo EC	2nd floor hallway across from Classroom 2602 (high)	2/4/16	< 1		
CEC-0204-8A	Cardozo EC	2nd floor hallway across from Classroom 2602 (low)	2/4/16	< 1		
CEC-0204-8B	Cardozo EC	2nd floor hallway across from Classroom 2602 (low)	2/4/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
CEC-0204-9A	Cardozo EC	1st floor hallway across from Classroom 1203 (high)	2/4/16	< 1		
CEC-0204-9B	Cardozo EC	1st floor hallway across from Classroom 1203 (high)	2/4/16	< 1		
CEC-0204-10A	Cardozo EC	1st floor hallway across from Classroom 1203 (low)	2/4/16	< 1		
CEC-0204-10B	Cardozo EC	1st floor hallway across from Classroom 1203 (low)	2/4/16	< 1		
CEC-0204-11A	Cardozo EC	1st floor hallway across from Classroom 1603 (high)	2/4/16	< 1		
CEC-0204-11B	Cardozo EC	1st floor hallway across from Classroom 1603 (high)	2/4/16	< 1		
CEC-0204-12A	Cardozo EC	1st floor hallway across from Classroom 1603 (low)	2/4/16	< 1		
CEC-0204-12B	Cardozo EC	1st floor hallway across from Classroom 1603 (low)	2/4/16	< 1		
CEC-0204-13A	Cardozo EC	C floor hallway across from Classroom C205 (high)	2/4/16	< 1		
CEC-0204-13B	Cardozo EC	C floor hallway across from Classroom C205 (high)	2/4/16	< 1		
CEC-0204-14A	Cardozo EC	C floor hallway across from Classroom C205 (low)	2/4/16	< 1		
CEC-0204-14B	Cardozo EC	C floor hallway across from Classroom C205 (low)	2/4/16	< 1		
CEC-0204-15A	Cardozo EC	LT floor in Pool Area (high)	2/4/16	< 1		
CEC-0204-15B	Cardozo EC	LT floor in Pool Area (high)	2/4/16	< 1		
CEC-0204-16A	Cardozo EC	LT floor in Pool Area (low)	2/4/16	< 1		
CEC-0204-16B	Cardozo EC	LT floor in Pool Area (low)	2/4/16	< 1		
CEC-0204-17A	Cardozo EC	LT floor hallway across from Girl's Locker Room LT55 (high)	2/4/16	< 1		
CEC-0204-17B	Cardozo EC	LT floor hallway across from Girl's Locker Room LT55 (high)	2/4/16	< 1		
CEC-0204-18A	Cardozo EC	LT floor hallway across from Girl's Locker Room LT55 (low)	2/4/16	< 1		
CEC-0204-18B	Cardozo EC	LT floor hallway across from Girl's Locker Room LT55 (low)	2/4/16	< 1		
CEC-0204-19A	Cardozo EC	LT floor hallway across from Custodian Closet LT58 (high)	2/4/16	< 1		
CEC-0204-19B	Cardozo EC	LT floor hallway across from Custodian Closet LT58 (high)	2/4/16	< 1		
CEC-0204-20A	Cardozo EC	LT floor hallway across from Custodian Closet LT58 (low)	2/4/16	< 1		
CEC-0204-20B	Cardozo EC	LT floor hallway across from Custodian Closet LT58 (low)	2/4/16	< 1		
CEC-0204-21A	Cardozo EC	T floor in Lobby near T04A Mechanical Room (high)	2/4/16	< 1		
CEC-0204-21B	Cardozo EC	T floor in Lobby near T04A Mechanical Room (high)	2/4/16	< 1		
CEC-0204-22A	Cardozo EC	T floor in Lobby near T04A Mechanical Room (low)	2/4/16	< 1		
CEC-0204-22B	Cardozo EC	T floor in Lobby near T04A Mechanical Room (low)	2/4/16	< 1		
			<b>Percentage of Passed Samples</b>			<b>100.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
CES-0311-1A	Cleveland ES	3rd floor hallway across from Elevator (high)	3/11/16	< 1		
CES-0311-1B	Cleveland ES	3rd floor hallway across from Elevator (high)	3/11/16	< 1		
CES-0311-2A	Cleveland ES	3rd floor hallway across from Elevator (low)	3/11/16	< 1		
CES-0311-2B	Cleveland ES	3rd floor hallway across from Elevator (low)	3/11/16	< 1		
CES-0311-3A	Cleveland ES	3rd floor inside Classroom 302	3/11/16	< 1		
CES-0311-3B	Cleveland ES	3rd floor inside Classroom 302	3/11/16	1.1		
CES-0311-4A	Cleveland ES	3rd floor inside Classroom 301	3/11/16	< 1		
CES-0311-4B	Cleveland ES	3rd floor inside Classroom 301	3/11/16	< 1		
CES-0311-5A	Cleveland ES	3rd floor inside Classroom 315	3/11/16	< 1		
CES-0311-5B	Cleveland ES	3rd floor inside Classroom 315	3/11/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
CES-0311-6A	Cleveland ES	3rd floor inside Teacher's Lounge 313	3/11/16	< 1		
CES-0311-6B	Cleveland ES	3rd floor inside Teacher's Lounge 313	3/11/16	< 1		
CES-0311-7A	Cleveland ES	3rd floor inside Classroom 308	3/11/16	< 1		
CES-0311-7B	Cleveland ES	3rd floor inside Classroom 308	3/11/16	< 1		
CES-0311-8A	Cleveland ES	3rd floor inside Classroom 304	3/11/16	< 1		
CES-0311-8B	Cleveland ES	3rd floor inside Classroom 304	3/11/16	< 1		
CES-0311-9A	Cleveland ES	2nd floor hallway across from Elevator (high)	3/11/16	< 1		
CES-0311-9B	Cleveland ES	2nd floor hallway across from Elevator (high)	3/11/16	< 1		
CES-0311-10A	Cleveland ES	2nd floor hallway across from Elevator (low)	3/11/16	< 1		
CES-0311-10B	Cleveland ES	2nd floor hallway across from Elevator (low)	3/11/16	< 1		
CES-0311-11A	Cleveland ES	2nd floor inside Classroom 207	3/11/16	< 1		
CES-0311-11B	Cleveland ES	2nd floor inside Classroom 207	3/11/16	< 1		
CES-0311-12A	Cleveland ES	2nd floor inside Classroom 212	3/11/16	< 1		
CES-0311-12B	Cleveland ES	2nd floor inside Classroom 212	3/11/16	< 1		
CES-0311-13A	Cleveland ES	2nd floor inside Classroom 203	3/11/16	1.9		
CES-0311-13B	Cleveland ES	2nd floor inside Classroom 203	3/11/16	< 1		
CES-0311-14A	Cleveland ES	2nd floor inside Science Room 216 (south side, left)	3/11/16	1.5		
CES-0311-14B	Cleveland ES	2nd floor inside Science Room 216 (south side, left)	3/11/16	< 1		
CES-0311-15A	Cleveland ES	2nd floor inside Science Room 216 (south side, right)	3/11/16	2.2		
CES-0311-15B	Cleveland ES	2nd floor inside Science Room 216 (south side, right)	3/11/16	< 1		
CES-0311-16A	Cleveland ES	2nd floor inside Science Room 216 (north side, left)	3/11/16	1.5		
CES-0311-16B	Cleveland ES	2nd floor inside Science Room 216 (north side, left)	3/11/16	< 1		
CES-0311-17A	Cleveland ES	2nd floor inside Science Room 216 (north side, right)	3/11/16	< 1		
CES-0311-17B	Cleveland ES	2nd floor inside Science Room 216 (north side, right)	3/11/16	< 1		
CES-0311-18A	Cleveland ES	2nd floor inside Classroom 201	3/11/16	< 1		
CES-0311-18B	Cleveland ES	2nd floor inside Classroom 201	3/11/16	< 1		
CES-0311-19A	Cleveland ES	2nd floor inside Classroom 218	3/11/16	< 1		
CES-0311-19B	Cleveland ES	2nd floor inside Classroom 218	3/11/16	< 1		
CES-0311-20A	Cleveland ES	1st floor hallway across from Elevator (high)	3/11/16	< 1		
CES-0311-20B	Cleveland ES	1st floor hallway across from Elevator (high)	3/11/16	< 1		
CES-0311-21A	Cleveland ES	1st floor hallway across from Elevator (low)	3/11/16	< 1		
CES-0311-21B	Cleveland ES	1st floor hallway across from Elevator (low)	3/11/16	< 1		
CES-0311-22A	Cleveland ES	1st floor inside Classroom 111	3/11/16	1.5		
CES-0311-22B	Cleveland ES	1st floor inside Classroom 111	3/11/16	< 1		
CES-0311-23A	Cleveland ES	1st floor inside Classroom 106	3/11/16	< 1		
CES-0311-23B	Cleveland ES	1st floor inside Classroom 106	3/11/16	< 1		
CES-0311-24A	Cleveland ES	1st floor inside Classroom 115	3/11/16	< 1		
CES-0311-24B	Cleveland ES	1st floor inside Classroom 115	3/11/16	< 1		
CES-0311-25A	Cleveland ES	1st floor inside Classroom 117	3/11/16	< 1		
CES-0311-25B	Cleveland ES	1st floor inside Classroom 117	3/11/16	< 1		
CES-0311-26A	Cleveland ES	1st floor inside Classroom 103	3/11/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
CES-0311-26B	Cleveland ES	1st floor inside Classroom 103	3/11/16	< 1		
CES-0311-27A	Cleveland ES	1st floor inside Classroom 101	3/11/16	< 1		
CES-0311-27B	Cleveland ES	1st floor inside Classroom 101	3/11/16	< 1		
CES-0311-28A	Cleveland ES	1st floor inside Classroom 120	3/11/16	< 1		
CES-0311-28B	Cleveland ES	1st floor inside Classroom 120	3/11/16	< 1		
CES-0311-29A	Cleveland ES	Ground floor hallway across from Elevator (high)	3/11/16	< 1		
CES-0311-29B	Cleveland ES	Ground floor hallway across from Elevator (high)	3/11/16	< 1		
CES-0311-30A	Cleveland ES	Ground floor hallway across from Elevator (low)	3/11/16	< 1		
CES-0311-30B	Cleveland ES	Ground floor hallway across from Elevator (low)	3/11/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
CH-0418-1A	Columbia Heights EC	4th floor hallway between Boy's and Girl's Rooms (high)	4/18/16			
CH-0418-1B	Columbia Heights EC	4th floor hallway between Boy's and Girl's Rooms (high)	4/18/16			
CH-0418-2A	Columbia Heights EC	4th floor hallway between Boy's and Girl's Rooms (low)	4/18/16			
CH-0418-2B	Columbia Heights EC	4th floor hallway between Boy's and Girl's Rooms (low)	4/18/16			
CH-0418-3A	Columbia Heights EC	3rd floor hallway between Boy's and Girl's Rooms (low)	4/18/16			
CH-0418-3B	Columbia Heights EC	3rd floor hallway between Boy's and Girl's Rooms (low)	4/18/16			
CH-0418-4A	Columbia Heights EC	2nd floor hallway across from display cases (high, left)	4/18/16			
CH-0418-4B	Columbia Heights EC	2nd floor hallway across from display cases (high, left)	4/18/16			
CH-0418-5A	Columbia Heights EC	2nd floor hallway across from display cases (low, left)	4/18/16			
CH-0418-5B	Columbia Heights EC	2nd floor hallway across from display cases (low, left)	4/18/16			
CH-0418-6A	Columbia Heights EC	2nd floor hallway across from display cases (high, right)	4/18/16			
CH-0418-6B	Columbia Heights EC	2nd floor hallway across from display cases (high, right)	4/18/16			
CH-0418-7A	Columbia Heights EC	2nd floor hallway across from display cases (low, right)	4/18/16			
CH-0418-7B	Columbia Heights EC	2nd floor hallway across from display cases (low, right)	4/18/16			
CH-0418-8A	Columbia Heights EC	2nd floor inside Girl's Locker Room (high)	4/18/16			
CH-0418-8B	Columbia Heights EC	2nd floor inside Girl's Locker Room (high)	4/18/16			
CH-0418-9A	Columbia Heights EC	2nd floor inside Girl's Locker Room (low)	4/18/16			
CH-0418-9B	Columbia Heights EC	2nd floor inside Girl's Locker Room (low)	4/18/16			
CH-0418-10A	Columbia Heights EC	2nd floor inside Boy's Locker Room (high)	4/18/16			
CH-0418-10B	Columbia Heights EC	2nd floor inside Boy's Locker Room (high)	4/18/16			
CH-0418-11A	Columbia Heights EC	2nd floor inside Boy's Locker Room D211 (high)	4/18/16			
CH-0418-11B	Columbia Heights EC	2nd floor inside Boy's Locker Room D211 (high)	4/18/16			
CH-0418-12A	Columbia Heights EC	2nd floor inside Boy's Locker Room D211 (low)	4/18/16			
CH-0418-12B	Columbia Heights EC	2nd floor inside Boy's Locker Room D211 (low)	4/18/16			
CH-0418-13A	Columbia Heights EC	2nd floor inside Girl's Locker Room D204 (high)	4/18/16			
CH-0418-13B	Columbia Heights EC	2nd floor inside Girl's Locker Room D204 (high)	4/18/16			
CH-0418-14A	Columbia Heights EC	2nd floor inside Girl's Locker Room D204 (low)	4/18/16			
CH-0418-14B	Columbia Heights EC	2nd floor inside Girl's Locker Room D204 (low)	4/18/16			
CH-0418-15A	Columbia Heights EC	2nd floor hallway near elevator (high, right)	4/18/16			

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
CH-0418-15B	Columbia Heights EC	2nd floor hallway near elevator (high, right)	4/18/16			
CH-0418-16A	Columbia Heights EC	2nd floor hallway near elevator (low, right)	4/18/16			
CH-0418-16B	Columbia Heights EC	2nd floor hallway near elevator (low, right)	4/18/16			
CH-0418-17A	Columbia Heights EC	1st floor hallway across from Janitor's Closet C135 (high)	4/18/16			
CH-0418-17B	Columbia Heights EC	1st floor hallway across from Janitor's Closet C135 (high)	4/18/16			
CH-0418-18A	Columbia Heights EC	1st floor hallway across from Janitor's Closet C135 (low)	4/18/16			
CH-0418-18B	Columbia Heights EC	1st floor hallway across from Janitor's Closet C135 (low)	4/18/16			
CH-0418-19A	Columbia Heights EC	1st floor hallway across from Janitor's Closet A146 (high)	4/18/16			
CH-0418-19B	Columbia Heights EC	1st floor hallway across from Janitor's Closet A146 (high)	4/18/16			
CH-0418-20A	Columbia Heights EC	1st floor hallway across from Janitor's Closet A146 (low)	4/18/16			
CH-0418-20B	Columbia Heights EC	1st floor hallway across from Janitor's Closet A146 (low)	4/18/16			
CH-0418-21A	Columbia Heights EC	1st floor hallway near Cafeteria exit (high)	4/18/16			
CH-0418-21B	Columbia Heights EC	1st floor hallway near Cafeteria exit (high)	4/18/16			
CH-0418-22A	Columbia Heights EC	1st floor hallway near Cafeteria exit (low)	4/18/16			
CH-0418-22B	Columbia Heights EC	1st floor hallway near Cafeteria exit (low)	4/18/16			
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
CHS-0301-1A	Coolidge HS	3rd floor hallway across from Stairwell 5	3/1/16	< 1		
CHS-0301-1B	Coolidge HS	3rd floor hallway across from Stairwell 5	3/1/16	< 1		
CHS-0301-2A	Coolidge HS	3rd floor hallway adjacent to Classroom T313	3/1/16	< 1		
CHS-0301-2B	Coolidge HS	3rd floor hallway adjacent to Classroom T313	3/1/16	< 1		
CHS-0301-3A	Coolidge HS	3rd floor hallway adjacent to Classroom 314	3/1/16	< 1		
CHS-0301-3B	Coolidge HS	3rd floor hallway adjacent to Classroom 314	3/1/16	< 1		
CHS-0301-4A	Coolidge HS	3rd floor hallway adjacent to Classroom 330	3/1/16	< 1		
CHS-0301-4B	Coolidge HS	3rd floor hallway adjacent to Classroom 330	3/1/16	< 1		
CHS-0301-5A	Coolidge HS	2nd floor hallway across from Stairwell 5	3/1/16	< 1		
CHS-0301-5B	Coolidge HS	2nd floor hallway across from Stairwell 5	3/1/16	< 1		
CHS-0301-6A	Coolidge HS	2nd floor hallway adjacent to Classroom 209	3/1/16	< 1		
CHS-0301-6B	Coolidge HS	2nd floor hallway adjacent to Classroom 209	3/1/16	< 1		
CHS-0301-7A	Coolidge HS	2nd floor hallway adjacent to Classroom S212	3/1/16	< 1		
CHS-0301-7B	Coolidge HS	2nd floor hallway adjacent to Classroom S212	3/1/16	< 1		
CHS-0301-8A	Coolidge HS	2nd floor hallway adjacent to Classroom S232	3/1/16	< 1		
CHS-0301-8B	Coolidge HS	2nd floor hallway adjacent to Classroom S232	3/1/16	< 1		
CHS-0301-9A	Coolidge HS	1st floor hallway across from Stairwell 6	3/1/16	< 1		
CHS-0301-9B	Coolidge HS	1st floor hallway across from Stairwell 6	3/1/16	< 1		
CHS-0301-10A	Coolidge HS	1st floor hallway near Stairwell 3	3/1/16	< 1		
CHS-0301-10B	Coolidge HS	1st floor hallway near Stairwell 3	3/1/16	< 1		
CHS-0301-11A	Coolidge HS	1st floor hallway near Stairwell 4	3/1/16	< 1		
CHS-0301-11B	Coolidge HS	1st floor hallway near Stairwell 4	3/1/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
CHS-0301-12A	Coolidge HS	Basement floor inside Gym	3/1/16	< 1		
CHS-0301-12B	Coolidge HS	Basement floor inside Gym	3/1/16	< 1		
CHS-0301-13A	Coolidge HS	Basement floor hallway near Stairwell 4	3/1/16	< 1		
CHS-0301-13B	Coolidge HS	Basement floor hallway near Stairwell 4	3/1/16	< 1		
CHS-0301-14A	Coolidge HS	Basement floor inside Cafeteria	3/1/16	1.8		
CHS-0301-14B	Coolidge HS	Basement floor inside Cafeteria	3/1/16	< 1		
CHS-0301-15A	Coolidge HS	Inside bottom floor of Frank Williams Activity Center near Boy's Locker Room	3/1/16	< 1		
CHS-0301-15B	Coolidge HS	Inside bottom floor of Frank Williams Activity Center near Boy's Locker Room	3/1/16	< 1		
CHS-0301-16A	Coolidge HS	Inside Boy's Locker Room	3/1/16	< 1		
CHS-0301-16B	Coolidge HS	Inside Boy's Locker Room	3/1/16	< 1		
CHS-0301-17A	Coolidge HS	Inside bottom floor of Frank Williams Activity Center near Girl's Locker Room	3/1/16	< 1		
CHS-0301-17B	Coolidge HS	Inside bottom floor of Frank Williams Activity Center near Girl's Locker Room	3/1/16	< 1		
CHS-0301-18A	Coolidge HS	Inside Girl's Locker Room	3/1/16	< 1		
CHS-0301-18B	Coolidge HS	Inside Girl's Locker Room	3/1/16	< 1		
CHS-0301-19A	Coolidge HS	In bottom floor of Frank Williams Activity Center in Girls Team Locker Area	3/1/16	< 1		
CHS-0301-19B	Coolidge HS	In bottom floor of Frank Williams Activity Center in Girls Team Locker Area	3/1/16	< 1		
CHS-0301-20A	Coolidge HS	In bottom floor of Frank Williams Activity Center in Boys Team Locker Area	3/1/16	< 1		
CHS-0301-20B	Coolidge HS	In bottom floor of Frank Williams Activity Center in Boys Team Locker Area	3/1/16	< 1		
CHS-0301-21A	Coolidge HS	Inside top floor of Frank Williams Activity Center adjacent to Stairwell 1	3/1/16	1.2		
CHS-0301-21B	Coolidge HS	Inside top floor of Frank Williams Activity Center adjacent to Stairwell 1	3/1/16	2.2		
CHS-0301-22A	Coolidge HS	Inside top floor of Frank Williams Activity Center adjacent to Stairwell 1	3/1/16	7.5		
CHS-0301-22B	Coolidge HS	Inside top floor of Frank Williams Activity Center adjacent to Stairwell 1	3/1/16	4		
CHS-0301-23A	Coolidge HS	Inside top floor of Frank Williams Activity Center near Room 172	3/1/16	< 1		
CHS-0301-23B	Coolidge HS	Inside top floor of Frank Williams Activity Center near Room 172	3/1/16	< 1		
CHS-0301-24A	Coolidge HS	Inside top floor of Frank Williams Activity Center near Room 174	3/1/16	< 1		
CHS-0301-24B	Coolidge HS	Inside top floor of Frank Williams Activity Center near Room 174	3/1/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
DMS-0302-1A	Deal MS	3rd floor hallway adjacent to Girl's Room (high)	3/2/16	< 1		
DMS-0302-1B	Deal MS	3rd floor hallway adjacent to Girl's Room (high)	3/2/16	< 1		
DMS-0302-2A	Deal MS	3rd floor hallway adjacent to Girl's Room (low)	3/2/16	< 1		
DMS-0302-2B	Deal MS	3rd floor hallway adjacent to Girl's Room (low)	3/2/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
DMS-0302-3A	Deal MS	3rd floor hallway adjacent to Boy's Room (high)	3/2/16	< 1		
DMS-0302-3B	Deal MS	3rd floor hallway adjacent to Boy's Room (high)	3/2/16	< 1		
DMS-0302-4A	Deal MS	3rd floor hallway adjacent to Boy's Room (low)	3/2/16	< 1		
DMS-0302-4B	Deal MS	3rd floor hallway adjacent to Boy's Room (low)	3/2/16	< 1		
DMS-0302-5A	Deal MS	2nd floor hallway adjacent to Girl's Room (high)	3/2/16	< 1		
DMS-0302-5B	Deal MS	2nd floor hallway adjacent to Girl's Room (high)	3/2/16	< 1		
DMS-0302-6A	Deal MS	2nd floor hallway adjacent to Girl's Room (low)	3/2/16	< 1		
DMS-0302-6B	Deal MS	2nd floor hallway adjacent to Girl's Room (low)	3/2/16	< 1		
DMS-0302-7A	Deal MS	2nd floor hallway adjacent to Boy's Room (high)	3/2/16	< 1		
DMS-0302-7B	Deal MS	2nd floor hallway adjacent to Boy's Room (high)	3/2/16	< 1		
DMS-0302-8A	Deal MS	2nd floor hallway adjacent to Boy's Room (low)	3/2/16	< 1		
DMS-0302-8B	Deal MS	2nd floor hallway adjacent to Boy's Room (low)	3/2/16	< 1		
DMS-0302-9A	Deal MS	1st floor hallway adjacent to Girl's Room (high)	3/2/16	< 1		
DMS-0302-9B	Deal MS	1st floor hallway adjacent to Girl's Room (high)	3/2/16	< 1		
DMS-0302-10A	Deal MS	1st floor hallway adjacent to Girl's Room (low)	3/2/16	< 1		
DMS-0302-10B	Deal MS	1st floor hallway adjacent to Girl's Room (low)	3/2/16	< 1		
DMS-0302-11A	Deal MS	1st floor hallway adjacent to Boy's Room (high)	3/2/16	< 1		
DMS-0302-11B	Deal MS	1st floor hallway adjacent to Boy's Room (high)	3/2/16	< 1		
DMS-0302-12A	Deal MS	1st floor hallway adjacent to Boy's Room (low)	3/2/16	< 1		
DMS-0302-12B	Deal MS	1st floor hallway adjacent to Boy's Room (low)	3/2/16	< 1		
DMS-0302-13A	Deal MS	Ground floor hallway between Boy's and Girl's Rooms (low)	3/2/16	< 1		
DMS-0302-13B	Deal MS	Ground floor hallway between Boy's and Girl's Rooms (low)	3/2/16	< 1		
DMS-0302-14A	Deal MS	Ground floor hallway between Boy's and Girl's Locker Rooms (high)	3/2/16	< 1		
DMS-0302-14B	Deal MS	Ground floor hallway between Boy's and Girl's Locker Rooms (high)	3/2/16	< 1		
DMS-0302-15A	Deal MS	Ground floor hallway between Boy's and Girl's Locker Rooms (low)	3/2/16	< 1		
DMS-0302-15B	Deal MS	Ground floor hallway between Boy's and Girl's Locker Rooms (low)	3/2/16	< 1		
DMS-0302-16A	Deal MS	Ground floor inside Gym (low, left)	3/2/16	< 1		
DMS-0302-16B	Deal MS	Ground floor inside Gym (low, left)	3/2/16	< 1		
DMS-0302-17A	Deal MS	Ground floor inside Gym (high, right)	3/2/16	< 1		
DMS-0302-17B	Deal MS	Ground floor inside Gym (high, right)	3/2/16	< 1		
DMS-0302-18A	Deal MS	Ground floor inside Gym (low, right)	3/2/16	< 1		
DMS-0302-18B	Deal MS	Ground floor inside Gym (low, right)	3/2/16	< 1		
DMS-0302-19A	Deal MS	Ground floor hallway at entrance to Cafeteria (high)	3/2/16	< 1		
DMS-0302-19B	Deal MS	Ground floor hallway at entrance to Cafeteria (high)	3/2/16	< 1		
DMS-0302-20A	Deal MS	Ground floor hallway at entrance to Cafeteria (low)	3/2/16	< 1		
DMS-0302-20B	Deal MS	Ground floor hallway at entrance to Cafeteria (low)	3/2/16	< 1		
DMS-0302-21A	Deal MS	Ground floor inside Cafeteria (high)	3/2/16	< 1		
DMS-0302-21B	Deal MS	Ground floor inside Cafeteria (high)	3/2/16	< 1		
DMS-0302-22A	Deal MS	Ground floor inside Cafeteria (low)	3/2/16	< 1		
DMS-0302-22B	Deal MS	Ground floor inside Cafeteria (low)	3/2/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
			<b>Percentage of Passed Samples</b>			<b>100.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
DH-0217-1A	Dorothy Heights ES	2nd floor hallway across from Classroom 210 (high)	2/17/16	< 1		
DH-0217-1B	Dorothy Heights ES	2nd floor hallway across from Classroom 210 (high)	2/17/16	< 1		
DH-0217-2A	Dorothy Heights ES	2nd floor hallway across from Classroom 210 (low)	2/17/16	< 1		
DH-0217-2B	Dorothy Heights ES	2nd floor hallway across from Classroom 210 (low)	2/17/16	< 1		
DH-0217-3A	Dorothy Heights ES	1st floor hallway across from Main Office (high)	2/17/16	< 1		
DH-0217-3B	Dorothy Heights ES	1st floor hallway across from Main Office (high)	2/17/16	< 1		
DH-0217-4A	Dorothy Heights ES	1st floor hallway across from Main Office (low)	2/17/16	< 1		
DH-0217-4B	Dorothy Heights ES	1st floor hallway across from Main Office (low)	2/17/16	1.9		
DH-0217-5A	Dorothy Heights ES	1st floor hallway in Annex adjacent to Classroom 12	2/17/16	< 1		
DH-0217-5B	Dorothy Heights ES	1st floor hallway in Annex adjacent to Classroom 12	2/17/16	< 1		
			<b>Percentage of Passed Samples</b>			<b>100.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
DES-1006-1A	Drew ES	4th floor hallway adjacent to Classroom 407 (high)	10/5/15	< 1		
DES-1006-1B	Drew ES	4th floor hallway adjacent to Classroom 407 (high)	10/5/15	< 1		
DES-1006-2A	Drew ES	4th floor hallway adjacent to Classroom 407 (low)	10/5/15	< 1		
DES-1006-2B	Drew ES	4th floor hallway adjacent to Classroom 407 (low)	10/5/15	< 1		
DES-1006-3A	Drew ES	4th floor hallway across from Classroom 400 (high)	10/5/15	< 1		
DES-1006-3B	Drew ES	4th floor hallway across from Classroom 400 (high)	10/5/15	< 1		
DES-1006-4A	Drew ES	4th floor hallway across from Classroom 400 (low)	10/5/15	< 1		
DES-1006-4B	Drew ES	4th floor hallway across from Classroom 400 (low)	10/5/15	< 1		
DES-1006-5A	Drew ES	3rd floor hallway across from Classroom 300 (high)	10/5/15	< 1		
DES-1006-5B	Drew ES	3rd floor hallway across from Classroom 300 (high)	10/5/15	< 1		
DES-1006-6A	Drew ES	3rd floor hallway across from Classroom 300 (low)	10/5/15	< 1		
DES-1006-6B	Drew ES	3rd floor hallway across from Classroom 300 (low)	10/5/15	< 1		
DES-1006-7A	Drew ES	3rd floor hallway adjacent to Classroom 307 (high)	10/5/15	< 1		
DES-1006-7B	Drew ES	3rd floor hallway adjacent to Classroom 307 (high)	10/5/15	< 1		
DES-1006-8A	Drew ES	3rd floor hallway adjacent to Classroom 307 (low)	10/5/15	< 1		
DES-1006-8B	Drew ES	3rd floor hallway adjacent to Classroom 307 (low)	10/5/15	< 1		
DES-1006-9A	Drew ES	2nd floor hallway adjacent to Classroom 207 (high)	10/5/15	< 1		
DES-1006-9B	Drew ES	2nd floor hallway adjacent to Classroom 207 (high)	10/5/15	< 1		
DES-1006-10A	Drew ES	2nd floor hallway adjacent to Classroom 207 (low)	10/5/15	< 1		
DES-1006-10B	Drew ES	2nd floor hallway adjacent to Classroom 207 (low)	10/5/15	< 1		
DES-1006-11A	Drew ES	2nd floor inside Classroom 207	10/5/15	< 1		
DES-1006-11B	Drew ES	2nd floor inside Classroom 207	10/5/15	< 1		
DES-1006-12A	Drew ES	2nd floor inside Classroom 205	10/5/15	< 1		
DES-1006-12B	Drew ES	2nd floor inside Classroom 205	10/5/15	< 1		
DES-1006-13A	Drew ES	2nd floor inside Classroom 209	10/5/15	< 1		
DES-1006-13B	Drew ES	2nd floor inside Classroom 209	10/5/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
DES-1006-14A	Drew ES	2nd floor inside Teacher's Lounge	10/5/15	< 1		
DES-1006-14B	Drew ES	2nd floor inside Teacher's Lounge	10/5/15	< 1		
DES-1006-15A	Drew ES	2nd floor hallway across from Classroom 200 (high)	10/5/15	< 1		
DES-1006-15B	Drew ES	2nd floor hallway across from Classroom 200 (high)	10/5/15	< 1		
DES-1006-16A	Drew ES	1st floor hallway across from Health Suite (high)	10/5/15	< 1		
DES-1006-16B	Drew ES	1st floor hallway across from Health Suite (high)	10/5/15	< 1		
DES-1006-17A	Drew ES	1st floor hallway across from Health Suite (low)	10/5/15	< 1		
DES-1006-17B	Drew ES	1st floor hallway across from Health Suite (low)	10/5/15	< 1		
DES-1006-18A	Drew ES	1st floor inside Classroom 104	10/5/15	< 1		
DES-1006-18B	Drew ES	1st floor inside Classroom 104	10/5/15	< 1		
DES-1006-19A	Drew ES	1st floor inside Classroom 108	10/5/15	< 1		
DES-1006-19B	Drew ES	1st floor inside Classroom 108	10/5/15	< 1		
DES-1006-20A	Drew ES	1st floor inside Classroom 105	10/5/15	< 1		
DES-1006-20B	Drew ES	1st floor inside Classroom 105	10/5/15	< 1		
DES-1006-21A	Drew ES	1st floor inside Classroom 107	10/5/15	< 1		
DES-1006-21B	Drew ES	1st floor inside Classroom 107	10/5/15	< 1		
DES-1006-22A	Drew ES	1st floor inside Classroom 106	10/5/15	< 1		
DES-1006-22B	Drew ES	1st floor inside Classroom 106	10/5/15	< 1		
DES-1006-23A	Drew ES	1st floor hallway adjacent to Classroom 107 (high)	10/5/15	< 1		
DES-1006-23B	Drew ES	1st floor hallway adjacent to Classroom 107 (high)	10/5/15	< 1		
DES-1006-24A	Drew ES	1st floor hallway adjacent to Classroom 107 (low)	10/5/15	< 1		
DES-1006-24B	Drew ES	1st floor hallway adjacent to Classroom 107 (low)	10/5/15	< 1		
DES-1006-25A	Drew ES	1st floor inside Health Suite	10/5/15	< 1		
DES-1006-25B	Drew ES	1st floor inside Health Suite	10/5/15	< 1		
DES-1006-26A	Drew ES	1st floor inside Lobby @ entrance to Auditorium (high)	10/5/15	< 1		
DES-1006-26B	Drew ES	1st floor inside Lobby @ entrance to Auditorium (high)	10/5/15	< 1		
DES-1006-27A	Drew ES	1st floor inside Lobby @ entrance to Auditorium (low)	10/5/15	< 1		
DES-1006-27B	Drew ES	1st floor inside Lobby @ entrance to Auditorium (low)	10/5/15	< 1		
			<b>Percentage of Passed Samples</b>			<b>100.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
	Dunbar HS					
	Dunbar HS					
			<b>Percentage of Passed Samples</b>			<b>0.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
	Duke Ellington@Garnet Patterson					
	Duke Ellington@Garnet Patterson					
			<b>Percentage of Passed Samples</b>			<b>0.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
EHS-1016-1A	Eastern HS	4th floor hallway across from Classroom E415 (high)	10/16/15	< 1		
EHS-1016-1B	Eastern HS	4th floor hallway across from Classroom E415 (high)	10/16/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
EHS-1016-2A	Eastern HS	4th floor hallway across from Classroom E415 (low)	10/16/15	< 1		
EHS-1016-2B	Eastern HS	4th floor hallway across from Classroom E415 (low)	10/16/15	< 1		
EHS-1016-3A	Eastern HS	4th floor hallway across from Classroom W411 (high)	10/16/15	< 1		
EHS-1016-3B	Eastern HS	4th floor hallway across from Classroom W411 (high)	10/16/15	< 1		
EHS-1016-4A	Eastern HS	4th floor hallway across from Classroom W411 (low)	10/16/15	< 1		
EHS-1016-4B	Eastern HS	4th floor hallway across from Classroom W411 (low)	10/16/15	< 1		
EHS-1016-5A	Eastern HS	3rd floor hallway across from Classroom W311 (high)	10/16/15	< 1		
EHS-1016-5B	Eastern HS	3rd floor hallway across from Classroom W311 (high)	10/16/15	< 1		
EHS-1016-6A	Eastern HS	3rd floor hallway across from Classroom W311 (low)	10/16/15	< 1		
EHS-1016-6B	Eastern HS	3rd floor hallway across from Classroom W311 (low)	10/16/15	< 1		
EHS-1016-7A	Eastern HS	3rd floor hallway across from Classroom E316 (high)	10/16/15	< 1		
EHS-1016-7B	Eastern HS	3rd floor hallway across from Classroom E316 (high)	10/16/15	< 1		
EHS-1016-8A	Eastern HS	3rd floor hallway across from Classroom E316 (low)	10/16/15	< 1		
EHS-1016-8B	Eastern HS	3rd floor hallway across from Classroom E316 (low)	10/16/15	< 1		
EHS-1016-9A	Eastern HS	2nd floor hallway across from Classroom W212 (high)	10/16/15	< 1		
EHS-1016-9B	Eastern HS	2nd floor hallway across from Classroom W212 (high)	10/16/15	< 1		
EHS-1016-10A	Eastern HS	2nd floor hallway across from Classroom W212 (low)	10/16/15	< 1		
EHS-1016-10B	Eastern HS	2nd floor hallway across from Classroom W212 (low)	10/16/15	< 1		
EHS-1016-11A	Eastern HS	2nd floor hallway across from Classroom E218 (low)	10/16/15	< 1		
EHS-1016-11B	Eastern HS	2nd floor hallway across from Classroom E218 (low)	10/16/15	< 1		
EHS-1016-12A	Eastern HS	1st floor hallway across from Health Clinic W130 (low)	10/16/15	< 1		
EHS-1016-12B	Eastern HS	1st floor hallway across from Health Clinic W130 (low)	10/16/15	< 1		
EHS-1016-13A	Eastern HS	1st floor hallway across from Gym (high)	10/16/15	< 1		
EHS-1016-13B	Eastern HS	1st floor hallway across from Gym (high)	10/16/15	< 1		
EHS-1016-14A	Eastern HS	1st floor hallway across from Gym (low)	10/16/15	< 1		
EHS-1016-14B	Eastern HS	1st floor hallway across from Gym (low)	10/16/15	< 1		
EHS-1016-15A	Eastern HS	Basement floor inside Cafeteria (high)	10/16/15	< 1		
EHS-1016-15B	Eastern HS	Basement floor inside Cafeteria (high)	10/16/15	< 1		
EHS-1016-16A	Eastern HS	Basement floor inside Cafeteria (low)	10/16/15	< 1		
EHS-1016-16B	Eastern HS	Basement floor inside Cafeteria (low)	10/16/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
EES-0226-1A	Eaton ES	3rd floor hallway adjacent to Classroom 313	2/26/16	< 1		
EES-0226-1B	Eaton ES	3rd floor hallway adjacent to Classroom 313	2/26/16	< 1		
EES-0226-2A	Eaton ES	2nd floor hallway adjacent to Classroom 218	2/26/16	< 1		
EES-0226-2B	Eaton ES	2nd floor hallway adjacent to Classroom 218	2/26/16	< 1		
EES-0226-3A	Eaton ES	1st floor hallway across from Classroom 119	2/26/16	< 1		
EES-0226-3B	Eaton ES	1st floor hallway across from Classroom 119	2/26/16	< 1		
EES-0226-4A	Eaton ES	3rd floor hallway adjacent to Classroom 303	2/26/16	< 1		
EES-0226-4B	Eaton ES	3rd floor hallway adjacent to Classroom 303	2/26/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
EES-0226-5A	Eaton ES	2nd floor hallway across from Classroom 209	2/26/16	< 1		
EES-0226-5B	Eaton ES	2nd floor hallway across from Classroom 209	2/26/16	< 1		
EES-0226-6A	Eaton ES	2nd floor inside Music Room 209 B	2/26/16	< 1		
EES-0226-6B	Eaton ES	2nd floor inside Music Room 209 B	2/26/16	< 1		
EES-0226-7A	Eaton ES	1st floor inside Health Suite 102 D	2/26/16	< 1		
EES-0226-7B	Eaton ES	1st floor inside Health Suite 102 D	2/26/16	< 1		
EES-0226-8A	Eaton ES	1st floor hallway near Main Entrance (high)	2/26/16	< 1		
EES-0226-8B	Eaton ES	1st floor hallway near Main Entrance (high)	2/26/16	< 1		
EES-0226-9A	Eaton ES	1st floor hallway near Main Entrance (low)	2/26/16	< 1		
EES-0226-9B	Eaton ES	1st floor hallway near Main Entrance (low)	2/26/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
EH-1015-1A	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-266	10/15/15	< 1		
EH-1015-1B	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-266	10/15/15	< 1		
EH-1015-2A	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-277	10/15/15	< 1		
EH-1015-2B	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-277	10/15/15	< 1		
EH-1015-3A	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-262	10/15/15	< 1		
EH-1015-3B	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-262	10/15/15	< 1		
EH-1015-4A	Eliot-Hine MS	3rd floor hallway adjacent to Staff Resource Room 3-255	10/15/15	< 1		
EH-1015-4B	Eliot-Hine MS	3rd floor hallway adjacent to Staff Resource Room 3-255	10/15/15	< 1		
EH-1015-5A	Eliot-Hine MS	2nd floor hallway adjacent to Classroom 2-210	10/15/15	< 1		
EH-1015-5B	Eliot-Hine MS	2nd floor hallway adjacent to Classroom 2-210	10/15/15	< 1		
EH-1015-6A	Eliot-Hine MS	2nd floor hallway adjacent to Classroom 2-224	10/15/15	< 1		
EH-1015-6B	Eliot-Hine MS	2nd floor hallway adjacent to Classroom 2-224	10/15/15	< 1		
EH-1015-7A	Eliot-Hine MS	2nd floor hallway adjacent to Classroom 2-206	10/15/15	< 1		
EH-1015-7B	Eliot-Hine MS	2nd floor hallway adjacent to Classroom 2-206	10/15/15	< 1		
EH-1015-8A	Eliot-Hine MS	2nd floor hallway adjacent to Computer Lab 2-198	10/15/15	< 1		
EH-1015-8B	Eliot-Hine MS	2nd floor hallway adjacent to Computer Lab 2-198	10/15/15	< 1		
EH-1015-9A	Eliot-Hine MS	1st floor hallway adjacent to Office 1-152	10/15/15	< 1		
EH-1015-9B	Eliot-Hine MS	1st floor hallway adjacent to Office 1-152	10/15/15	< 1		
EH-1015-10A	Eliot-Hine MS	1st floor hallway adjacent to Classroom 1-166	10/15/15	< 1		
EH-1015-10B	Eliot-Hine MS	1st floor hallway adjacent to Classroom 1-166	10/15/15	< 1		
EH-1015-11A	Eliot-Hine MS	1st floor hallway across from Principal's Office 1-099	10/15/15	< 1		
EH-1015-11B	Eliot-Hine MS	1st floor hallway across from Principal's Office 1-099	10/15/15	< 1		
EH-1015-12A	Eliot-Hine MS	1st floor hallway across from Classroom 1-077	10/15/15	< 1		
EH-1015-12B	Eliot-Hine MS	1st floor hallway across from Classroom 1-077	10/15/15	< 1		
EH-1015-13A	Eliot-Hine MS	1st floor hallway adjacent to Classroom 1-070	10/15/15	< 1		
EH-1015-13B	Eliot-Hine MS	1st floor hallway adjacent to Classroom 1-070	10/15/15	< 1		
EH-1015-14A	Eliot-Hine MS	Basement floor inside Gym	10/15/15	< 1		
EH-1015-14B	Eliot-Hine MS	Basement floor inside Gym	10/15/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
EH-1015-15A	Eliot-Hine MS	Basement floor inside Cafeteria	10/15/15	< 1		
EH-1015-15B	Eliot-Hine MS	Basement floor inside Cafeteria	10/15/15	< 1		
EH-1015-16A	Eliot-Hine MS	Basement floor hallway adjacent to Storage Room B-48	10/15/15	< 1		
EH-1015-16B	Eliot-Hine MS	Basement floor hallway adjacent to Storage Room B-48	10/15/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
FAC-0315-1A	Fillmore EAC	3rd floor hallway across from Music Room 302 (high)	3/15/16	< 1		
FAC-0315-1B	Fillmore EAC	3rd floor hallway across from Music Room 302 (high)	3/15/16	< 1		
FAC-0315-2A	Fillmore EAC	3rd floor hallway across from Music Room 302 (low)	3/15/16	< 1		
FAC-0315-2B	Fillmore EAC	3rd floor hallway across from Music Room 302 (low)	3/15/16	< 1		
FAC-0315-3A	Fillmore EAC	3rd floor hallway across from Classroom 313 (high)	3/15/16	< 1		
FAC-0315-3B	Fillmore EAC	3rd floor hallway across from Classroom 313 (high)	3/15/16	< 1		
FAC-0315-4A	Fillmore EAC	3rd floor hallway across from Classroom 313 (low)	3/15/16	< 1		
FAC-0315-4B	Fillmore EAC	3rd floor hallway across from Classroom 313 (low)	3/15/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
FS-0308-1A	School Without Walls @ Francis-Stevens	3rd floor hallway adjacent to Classroom 309	3/8/16	< 1		
FS-0308-1B	School Without Walls @ Francis-Stevens	3rd floor hallway adjacent to Classroom 309	3/8/16	< 1		
FS-0308-2A	School Without Walls @ Francis-Stevens	3rd floor hallway adjacent to Classroom 305	3/8/16	< 1		
FS-0308-2B	School Without Walls @ Francis-Stevens	3rd floor hallway adjacent to Classroom 305	3/8/16	< 1		
FS-0308-3A	School Without Walls @ Francis-Stevens	2nd floor hallway adjacent to Classroom 206	3/8/16	< 1		
FS-0308-3B	School Without Walls @ Francis-Stevens	2nd floor hallway adjacent to Classroom 206	3/8/16	< 1		
FS-0308-4A	School Without Walls @ Francis-Stevens	2nd floor hallway adjacent to Classroom 210	3/8/16	< 1		
FS-0308-4B	School Without Walls @ Francis-Stevens	2nd floor hallway adjacent to Classroom 210	3/8/16	< 1		
FS-0308-5A	School Without Walls @ Francis-Stevens	1st floor inside Classroom 109	3/8/16	< 1		
FS-0308-5B	School Without Walls @ Francis-Stevens	1st floor inside Classroom 109	3/8/16	< 1		
FS-0308-6A	School Without Walls @ Francis-Stevens	1st floor inside Classroom 110	3/8/16	< 1		
FS-0308-6B	School Without Walls @ Francis-Stevens	1st floor inside Classroom 110	3/8/16	< 1		
FS-0308-7A	School Without Walls @ Francis-Stevens	1st floor inside Classroom 101	3/8/16	< 1		
FS-0308-7B	School Without Walls @ Francis-Stevens	1st floor inside Classroom 101	3/8/16	< 1		
FS-0308-8A	School Without Walls @ Francis-Stevens	1st floor inside Classroom 102	3/8/16	< 1		
FS-0308-8B	School Without Walls @ Francis-Stevens	1st floor inside Classroom 102	3/8/16	< 1		
FS-0308-9A	School Without Walls @ Francis-Stevens	1st floor inside Classroom 104	3/8/16	< 1		
FS-0308-9B	School Without Walls @ Francis-Stevens	1st floor inside Classroom 104	3/8/16	< 1		
FS-0308-10A	School Without Walls @ Francis-Stevens	1st floor hallway adjacent to Classroom 107	3/8/16	< 1		
FS-0308-10B	School Without Walls @ Francis-Stevens	1st floor hallway adjacent to Classroom 107	3/8/16	< 1		
FS-0308-11A	School Without Walls @ Francis-Stevens	1st floor inside Cafeteria (high)	3/8/16	< 1		
FS-0308-11B	School Without Walls @ Francis-Stevens	1st floor inside Cafeteria (high)	3/8/16	< 1		
FS-0308-12A	School Without Walls @ Francis-Stevens	1st floor inside Cafeteria (low)	3/8/16	< 1		
FS-0308-12B	School Without Walls @ Francis-Stevens	1st floor inside Cafeteria (low)	3/8/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
GES-1112-1A	Garfield ES	2nd floor hallway adjacent to Room 210 Teacher's Lounge	11/12/15	< 1		
GES-1112-1B	Garfield ES	2nd floor hallway adjacent to Room 210 Teacher's Lounge	11/12/15	< 1		
GES-1112-2A	Garfield ES	2nd floor hallway across from Stairwell 4	11/12/15	< 1		
GES-1112-2B	Garfield ES	2nd floor hallway across from Stairwell 4	11/12/15	< 1		
GES-1112-3A	Garfield ES	2nd floor hallway adjacent to Classroom 201	11/12/15	< 1		
GES-1112-3B	Garfield ES	2nd floor hallway adjacent to Classroom 201	11/12/15	< 1		
GES-1112-4A	Garfield ES	2nd floor hallway across from Room 206	11/12/15	< 1		
GES-1112-4B	Garfield ES	2nd floor hallway across from Room 206	11/12/15	< 1		
GES-1112-5A	Garfield ES	1st floor hallway across from Classroom 104	11/12/15	< 1		
GES-1112-5B	Garfield ES	1st floor hallway across from Classroom 104	11/12/15	< 1		
GES-1112-6A	Garfield ES	1st floor hallway adjacent to Main Office 101	11/12/15	< 1		
GES-1112-6B	Garfield ES	1st floor hallway adjacent to Main Office 101	11/12/15	< 1		
GES-1112-7A	Garfield ES	1st floor hallway across from Girl's Restroom	11/12/15	< 1		
GES-1112-7B	Garfield ES	1st floor hallway across from Girl's Restroom	11/12/15	< 1		
GES-1112-8A	Garfield ES	1st floor inside Classroom 110	11/12/15	< 1		
GES-1112-8B	Garfield ES	1st floor inside Classroom 110	11/12/15	< 1		
GES-1112-9A	Garfield ES	1st floor inside Classroom 111	11/12/15	< 1		
GES-1112-9B	Garfield ES	1st floor inside Classroom 111	11/12/15	< 1		
GES-1112-10A	Garfield ES	1st floor hallway across from Stairwell 4	11/12/15	< 1		
GES-1112-10B	Garfield ES	1st floor hallway across from Stairwell 4	11/12/15	< 1		
GES-1112-11A	Garfield ES	Basement floor inside Cafeteria adjacent to Kitchen	11/12/15	< 1		
GES-1112-11B	Garfield ES	Basement floor inside Cafeteria adjacent to Kitchen	11/12/15	< 1		
GES-1112-12A	Garfield ES	Basement floor inside Cafeteria near entrance	11/12/15	< 1		
GES-1112-12B	Garfield ES	Basement floor inside Cafeteria near entrance	11/12/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
GES-0316-1A	Garrison ES	2nd floor hallway across from Classroom 207	3/16/16	< 1		
GES-0316-1B	Garrison ES	2nd floor hallway across from Classroom 207	3/16/16	< 1		
GES-0316-2A	Garrison ES	2nd floor hallway adjacent to Music Rm 201	3/16/16	< 1		
GES-0316-2B	Garrison ES	2nd floor hallway adjacent to Music Rm 201	3/16/16	< 1		
GES-0316-3A	Garrison ES	1st floor hallway across from Classroom 108	3/16/16	< 1		
GES-0316-3B	Garrison ES	1st floor hallway across from Classroom 108	3/16/16	< 1		
GES-0316-4A	Garrison ES	1st floor inside Classroom 109 Kindergarten	3/16/16	< 1		
GES-0316-4B	Garrison ES	1st floor inside Classroom 109 Kindergarten	3/16/16	< 1		
GES-0316-5A	Garrison ES	1st floor inside Classroom 110 Kindergarten	3/16/16	< 1		
GES-0316-5B	Garrison ES	1st floor inside Classroom 110 Kindergarten	3/16/16	< 1		
GES-0316-6A	Garrison ES	1st floor hallway across from Classroom 111	3/16/16	< 1		
GES-0316-6B	Garrison ES	1st floor hallway across from Classroom 111	3/16/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
GES-0316-7A	Garrison ES	1st floor inside Health Suite	3/16/16	< 1		
GES-0316-7B	Garrison ES	1st floor inside Health Suite	3/16/16	< 1		
GES-0316-8A	Garrison ES	2nd floor hallway adjacent to Trash Chute	3/16/16	< 1		
GES-0316-8B	Garrison ES	2nd floor hallway adjacent to Trash Chute	3/16/16	< 1		
GES-0316-9A	Garrison ES	2nd floor hallway adjacent to Classroom 217	3/16/16	< 1		
GES-0316-9B	Garrison ES	2nd floor hallway adjacent to Classroom 217	3/16/16	< 1		
GES-0316-10A	Garrison ES	1st floor hallway adjacent to Rm 122 Intake and Assessment Center	3/16/16	< 1		
GES-0316-10B	Garrison ES	1st floor hallway adjacent to Rm 122 Intake and Assessment Center	3/16/16	< 1		
GES-0316-11A	Garrison ES	1st floor hallway across from Recreation Director Rm 128	3/16/16	< 1		
GES-0316-11B	Garrison ES	1st floor hallway across from Recreation Director Rm 128	3/16/16	< 1		
GES-0316-12A	Garrison ES	1st floor in Multi-Purpose Rm	3/16/16	< 1		
GES-0316-12B	Garrison ES	1st floor in Multi-Purpose Rm	3/16/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
	H.D. Cooke ES					
	H.D. Cooke ES					
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
HMS-0315-1A	Hardy MS	2nd floor hallway across from Computer Lab 212 (high)	3/15/16	< 1		
HMS-0315-1B	Hardy MS	2nd floor hallway across from Computer Lab 212 (high)	3/15/16	< 1		
HMS-0315-2A	Hardy MS	2nd floor hallway across from Computer Lab 212 (low)	3/15/16	< 1		
HMS-0315-2B	Hardy MS	2nd floor hallway across from Computer Lab 212 (low)	3/15/16	< 1		
HMS-0315-3A	Hardy MS	2nd floor hallway across from Production Center 205 (high)	3/15/16	< 1		
HMS-0315-3B	Hardy MS	2nd floor hallway across from Production Center 205 (high)	3/15/16	< 1		
HMS-0315-4A	Hardy MS	2nd floor hallway across from Production Center 205 (low)	3/15/16	< 1		
HMS-0315-4B	Hardy MS	2nd floor hallway across from Production Center 205 (low)	3/15/16	< 1		
HMS-0315-5A	Hardy MS	2nd floor inside Gym (high)	3/15/16	< 1		
HMS-0315-5B	Hardy MS	2nd floor inside Gym (high)	3/15/16	< 1		
HMS-0315-6A	Hardy MS	2nd floor inside Gym (low)	3/15/16	< 1		
HMS-0315-6B	Hardy MS	2nd floor inside Gym (low)	3/15/16	< 1		
HMS-0315-7A	Hardy MS	1st floor hallway adjacent to Guidance Suite 167 (high)	3/15/16	< 1		
HMS-0315-7B	Hardy MS	1st floor hallway adjacent to Guidance Suite 167 (high)	3/15/16	< 1		
HMS-0315-8A	Hardy MS	1st floor hallway adjacent to Guidance Suite 167 (low)	3/15/16	< 1		
HMS-0315-8B	Hardy MS	1st floor hallway adjacent to Guidance Suite 167 (low)	3/15/16	< 1		
HMS-0315-9A	Hardy MS	1st floor inside Cafeteria (high)	3/15/16	< 1		
HMS-0315-9B	Hardy MS	1st floor inside Cafeteria (high)	3/15/16	< 1		
HMS-0315-10A	Hardy MS	1st floor inside Cafeteria (low)	3/15/16	< 1		
HMS-0315-10B	Hardy MS	1st floor inside Cafeteria (low)	3/15/16	< 1		
HMS-0315-11A	Hardy MS	1st floor hallway across from Computer Lab 119 (high)	3/15/16	< 1		
HMS-0315-11B	Hardy MS	1st floor hallway across from Computer Lab 119 (high)	3/15/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
HMS-0315-12A	Hardy MS	1st floor hallway across from Computer Lab 119 (low)	3/15/16	< 1		
HMS-0315-12B	Hardy MS	1st floor hallway across from Computer Lab 119 (low)	3/15/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
HMS-1118-1A	Hart MS	3rd floor hallway across from Classroom 306	11/18/15	< 1		
HMS-1118-1B	Hart MS	3rd floor hallway across from Classroom 306	11/18/15	< 1		
HMS-1118-2A	Hart MS	3rd floor hallway adjacent to Classroom 321 (high)	11/18/15	< 1		
HMS-1118-2B	Hart MS	3rd floor hallway adjacent to Classroom 321 (high)	11/18/15	< 1		
HMS-1118-3A	Hart MS	3rd floor hallway adjacent to Classroom 321 (low)	11/18/15	< 1		
HMS-1118-3B	Hart MS	3rd floor hallway adjacent to Classroom 321 (low)	11/18/15	< 1		
HMS-1118-4A	Hart MS	2nd floor hallway adjacent to Classroom 226 (high)	11/18/15	< 1		
HMS-1118-4B	Hart MS	2nd floor hallway adjacent to Classroom 226 (high)	11/18/15	< 1		
HMS-1118-5A	Hart MS	2nd floor hallway adjacent to Classroom 226 (low)	11/18/15	< 1		
HMS-1118-5B	Hart MS	2nd floor hallway adjacent to Classroom 226 (low)	11/18/15	< 1		
HMS-1118-6A	Hart MS	2nd floor hallway adjacent to Classroom 232 (high)	11/18/15	< 1		
HMS-1118-6B	Hart MS	2nd floor hallway adjacent to Classroom 232 (high)	11/18/15	< 1		
HMS-1118-7A	Hart MS	2nd floor hallway adjacent to Classroom 232 (low)	11/18/15	< 1		
HMS-1118-7B	Hart MS	2nd floor hallway adjacent to Classroom 232 (low)	11/18/15	< 1		
HMS-1118-8A	Hart MS	2nd floor hallway across from Classroom 245 (high)	11/18/15	< 1		
HMS-1118-8B	Hart MS	2nd floor hallway across from Classroom 245 (high)	11/18/15	< 1		
HMS-1118-9A	Hart MS	2nd floor hallway across from Classroom 245 (low)	11/18/15	< 1		
HMS-1118-9B	Hart MS	2nd floor hallway across from Classroom 245 (low)	11/18/15	< 1		
HMS-1118-10A	Hart MS	1st floor hallway adjacent to Classroom 131	11/18/15	< 1		
HMS-1118-10B	Hart MS	1st floor hallway adjacent to Classroom 131	11/18/15	< 1		
HMS-1118-11A	Hart MS	1st floor hallway adjacent to Classroom 119	11/18/15	< 1		
HMS-1118-11B	Hart MS	1st floor hallway adjacent to Classroom 119	11/18/15	< 1		
HMS-1118-12A	Hart MS	2nd floor hallway adjacent to Classroom 206 (high)	11/18/15	< 1		
HMS-1118-12B	Hart MS	2nd floor hallway adjacent to Classroom 206 (high)	11/18/15	< 1		
HMS-1118-13A	Hart MS	2nd floor hallway adjacent to Classroom 206 (high)	11/18/15	< 1		
HMS-1118-13B	Hart MS	2nd floor hallway adjacent to Classroom 206 (high)	11/18/15	< 1		
HMS-1118-14A	Hart MS	Basement floor inside Cafeteria	11/18/15	< 1		
HMS-1118-14B	Hart MS	Basement floor inside Cafeteria	11/18/15	< 1		
HMS-1118-15A	Hart MS	1st floor in Gym inside Girl's Locker Room	11/18/15	< 1		
HMS-1118-15B	Hart MS	1st floor in Gym inside Girl's Locker Room	11/18/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
HES-0224-1A	Hearst ES	2nd floor in entrance way between Boy's and Girl's Restrooms (high)	2/24/16	< 1		
HES-0224-1B	Hearst ES	2nd floor in entrance way between Boy's and Girl's Restrooms (high)	2/24/16	< 1		
HES-0224-2A	Hearst ES	2nd floor in entrance way between Boy's and Girl's Restrooms (low)	2/24/16	< 1		
HES-0224-2B	Hearst ES	2nd floor in entrance way between Boy's and Girl's Restrooms (low)	2/24/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
HES-0224-3A	Hearst ES	2nd floor inside Classroom 218	2/24/16	< 1		
HES-0224-3B	Hearst ES	2nd floor inside Classroom 218	2/24/16	< 1		
HES-0224-4A	Hearst ES	2nd floor inside Classroom 219	2/24/16	< 1		
HES-0224-4B	Hearst ES	2nd floor inside Classroom 219	2/24/16	< 1		
HES-0224-5A	Hearst ES	2nd floor inside Classroom 210	2/24/16	1.7		
HES-0224-5B	Hearst ES	2nd floor inside Classroom 210	2/24/16	< 1		
HES-0224-6A	Hearst ES	2nd floor inside Classroom 214	2/24/16	< 1		
HES-0224-6B	Hearst ES	2nd floor inside Classroom 214	2/24/16	< 1		
HES-0224-7A	Hearst ES	1st floor inside Classroom 110	2/24/16	< 1		
HES-0224-7B	Hearst ES	1st floor inside Classroom 110	2/24/16	< 1		
HES-0224-8A	Hearst ES	1st floor inside Classroom 114	2/24/16	< 1		
HES-0224-8B	Hearst ES	1st floor inside Classroom 114	2/24/16	< 1		
HES-0224-9A	Hearst ES	1st floor inside Classroom 118	2/24/16	< 1		
HES-0224-9B	Hearst ES	1st floor inside Classroom 118	2/24/16	< 1		
HES-0224-10A	Hearst ES	1st floor inside Classroom 122	2/24/16	< 1		
HES-0224-10B	Hearst ES	1st floor inside Classroom 122	2/24/16	< 1		
HES-0224-11A	Hearst ES	1st floor inside Nurse's Office 126	2/24/16	< 1		
HES-0224-11B	Hearst ES	1st floor inside Nurse's Office 126	2/24/16	< 1		
HES-0224-12A	Hearst ES	1st floor inside Nurse's Office 126 in Exam Room 2	2/24/16	3.9		
HES-0224-12B	Hearst ES	1st floor inside Nurse's Office 126 in Exam Room 2	2/24/16	< 1		
HES-0224-13A	Hearst ES	1st floor in entrance way between Boy's and Girl's Restrooms (high)	2/24/16	< 1		
HES-0224-13B	Hearst ES	1st floor in entrance way between Boy's and Girl's Restrooms (high)	2/24/16	< 1		
HES-0224-14A	Hearst ES	1st floor in entrance way between Boy's and Girl's Restrooms (low)	2/24/16	< 1		
HES-0224-14B	Hearst ES	1st floor in entrance way between Boy's and Girl's Restrooms (low)	2/24/16	< 1		
HES-0224-15A	Hearst ES	Lower level inside Gym (high)	2/24/16	< 1		
HES-0224-15B	Hearst ES	Lower level inside Gym (high)	2/24/16	< 1		
HES-0224-16A	Hearst ES	Lower level inside Gym (low)	2/24/16	< 1		
HES-0224-16B	Hearst ES	Lower level inside Gym (low)	2/24/16	< 1		
HES-0224-17A	Hearst ES	1st floor inside Classroom 166	2/24/16	< 1		
HES-0224-17B	Hearst ES	1st floor inside Classroom 166	2/24/16	< 1		
HES-0224-18A	Hearst ES	1st floor inside Classroom 167	2/24/16	< 1		
HES-0224-18B	Hearst ES	1st floor inside Classroom 167	2/24/16	< 1		
HES-0224-19A	Hearst ES	1st floor hallway adjacent to Classroom 167 (high)	2/24/16	< 1		
HES-0224-19B	Hearst ES	1st floor hallway adjacent to Classroom 167 (high)	2/24/16	< 1		
HES-0224-20A	Hearst ES	1st floor hallway adjacent to Classroom 167 (low)	2/24/16	< 1		
HES-0224-20B	Hearst ES	1st floor hallway adjacent to Classroom 167 (low)	2/24/16	< 1		
HES-0224-21A	Hearst ES	2nd floor inside Classroom 265	2/24/16	< 1		
HES-0224-21B	Hearst ES	2nd floor inside Classroom 265	2/24/16	< 1		
HES-0224-22A	Hearst ES	2nd floor inside Classroom 264	2/24/16	< 1		
HES-0224-22B	Hearst ES	2nd floor inside Classroom 264	2/24/16	< 1		
HES-0224-23A	Hearst ES	2nd floor inside Classroom 261	2/24/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
HES-0224-23B	Hearst ES	2nd floor inside Classroom 261	2/24/16	< 1		
HES-0224-24A	Hearst ES	2nd floor inside Classroom 260	2/24/16	< 1		
HES-0224-24B	Hearst ES	2nd floor inside Classroom 260	2/24/16	< 1		
HES-0224-25A	Hearst ES	1st floor inside Classroom 160	2/24/16	< 1		
HES-0224-25B	Hearst ES	1st floor inside Classroom 160	2/24/16	< 1		
HES-0224-26A	Hearst ES	1st floor inside Classroom 161	2/24/16	< 1		
HES-0224-26B	Hearst ES	1st floor inside Classroom 161	2/24/16	< 1		
HES-0224-27A	Hearst ES	1st floor inside Classroom 164	2/24/16	< 1		
HES-0224-27B	Hearst ES	1st floor inside Classroom 164	2/24/16	< 1		
HES-0224-28A	Hearst ES	1st floor inside Classroom 165	2/24/16	< 1		
HES-0224-28B	Hearst ES	1st floor inside Classroom 165	2/24/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
HES-0106-1A	Hendley ES	3rd floor hallway adjacent to Boy's Room (high)	1/6/16	< 1		
HES-0106-1B	Hendley ES	3rd floor hallway adjacent to Boy's Room (high)	1/6/16	< 1		
HES-0106-2A	Hendley ES	3rd floor hallway adjacent to Boy's Room (low)	1/6/16	< 1		
HES-0106-2B	Hendley ES	3rd floor hallway adjacent to Boy's Room (low)	1/6/16	< 1		
HES-0106-3A	Hendley ES	3rd floor hallway adjacent to Girl's Room (high)	1/6/16	< 1		
HES-0106-3B	Hendley ES	3rd floor hallway adjacent to Girl's Room (high)	1/6/16	< 1		
HES-0106-4A	Hendley ES	3rd floor hallway adjacent to Girl's Room (low)	1/6/16	< 1		
HES-0106-4B	Hendley ES	3rd floor hallway adjacent to Girl's Room (low)	1/6/16	< 1		
HES-0106-5A	Hendley ES	2nd floor hallway adjacent to Girl's Room (high)	1/6/16	< 1		
HES-0106-5B	Hendley ES	2nd floor hallway adjacent to Girl's Room (high)	1/6/16	< 1		
HES-0106-6A	Hendley ES	2nd floor hallway adjacent to Girl's Room (low)	1/6/16	< 1		
HES-0106-6B	Hendley ES	2nd floor hallway adjacent to Girl's Room (low)	1/6/16	< 1		
HES-0106-7A	Hendley ES	2nd floor hallway adjacent to Boy's Room (low)	1/6/16	< 1		
HES-0106-7B	Hendley ES	2nd floor hallway adjacent to Boy's Room (low)	1/6/16	< 1		
HES-0106-8A	Hendley ES	1st floor hallway adjacent to Resource Room 109	1/6/16	< 1		
HES-0106-8B	Hendley ES	1st floor hallway adjacent to Resource Room 109	1/6/16	< 1		
HES-0106-9A	Hendley ES	1st floor inside Classroom 110	1/6/16	< 1		
HES-0106-9B	Hendley ES	1st floor inside Classroom 110	1/6/16	< 1		
HES-0106-10A	Hendley ES	1st floor inside Classroom 107	1/6/16	< 1		
HES-0106-10B	Hendley ES	1st floor inside Classroom 107	1/6/16	< 1		
HES-0106-11A	Hendley ES	1st floor inside Classroom 108	1/6/16	< 1		
HES-0106-11B	Hendley ES	1st floor inside Classroom 108	1/6/16	< 1		
HES-0106-12A	Hendley ES	Ground floor hallway adjacent to Book Storage Room G10	1/6/16	< 1		
HES-0106-12B	Hendley ES	Ground floor hallway adjacent to Book Storage Room G10	1/6/16	< 1		
HES-0106-13A	Hendley ES	Ground floor inside Classroom G13	1/6/16	< 1		
HES-0106-13B	Hendley ES	Ground floor inside Classroom G13	1/6/16	< 1		
HES-0106-14A	Hendley ES	Ground floor inside Classroom G11	1/6/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
HES-0106-14B	Hendley ES	Ground floor inside Classroom G11	1/6/16	< 1		
HES-0106-15A	Hendley ES	Ground floor inside Cafeteria	1/6/16	< 1		
HES-0106-15B	Hendley ES	Ground floor inside Cafeteria	1/6/16	< 1		
HES-0106-16A	Hendley ES	Ground floor hallway adjacent to Music Room G15	1/6/16	< 1		
HES-0106-16B	Hendley ES	Ground floor hallway adjacent to Music Room G15	1/6/16	< 1		
HES-0106-17A	Hendley ES	Ground floor inside Classroom G15	1/6/16	3.5		
HES-0106-17B	Hendley ES	Ground floor inside Classroom G15	1/6/16	< 1		
HES-0106-18A	Hendley ES	Ground floor inside Classroom G14	1/6/16	< 1		
HES-0106-18B	Hendley ES	Ground floor inside Classroom G14	1/6/16	< 1		
HES-0106-19A	Hendley ES	Ground floor inside Classroom G16	1/6/16	< 1		
HES-0106-19B	Hendley ES	Ground floor inside Classroom G16	1/6/16	< 1		
HES-0106-20A	Hendley ES	Ground floor inside Classroom G17	1/6/16	< 1		
HES-0106-20B	Hendley ES	Ground floor inside Classroom G17	1/6/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
HES-1005-1A	Houston ES	2nd floor hallway across from Classroom 209	10/5/15	< 1		
HES-1005-1B	Houston ES	2nd floor hallway across from Classroom 209	10/5/15	< 1		
HES-1005-2A	Houston ES	2nd floor hallway adjacent to Girl's Room	10/5/15	< 1		
HES-1005-2B	Houston ES	2nd floor hallway adjacent to Girl's Room	10/5/15	< 1		
HES-1005-3A	Houston ES	1st floor hallway across from Classroom 109	10/5/15	< 1		
HES-1005-3B	Houston ES	1st floor hallway across from Classroom 109	10/5/15	< 1		
HES-1005-4A	Houston ES	1st floor hallway adjacent to Girl's Room	10/5/15	< 1		
HES-1005-4B	Houston ES	1st floor hallway adjacent to Girl's Room	10/5/15	< 1		
HES-1005-5A	Houston ES	1st floor inside Multi-Purpose Room	10/5/15	< 1		
HES-1005-5B	Houston ES	1st floor inside Multi-Purpose Room	10/5/15	< 1		
HES-1005-6A	Houston ES	1st floor across from Teacher's Lounge	10/5/15	< 1		
HES-1005-6B	Houston ES	1st floor across from Teacher's Lounge	10/5/15	< 1		
HES-1005-7A	Houston ES	1st floor inside Teacher's Lounge	10/5/15	< 1		
HES-1005-7B	Houston ES	1st floor inside Teacher's Lounge	10/5/15	< 1		
HES-1005-8A	Houston ES	1st floor hallway adjacent to Classroom 156	10/5/15	< 1		
HES-1005-8B	Houston ES	1st floor hallway adjacent to Classroom 156	10/5/15	< 1		
HES-1005-9A	Houston ES	1st floor inside Classroom 148	10/5/15	< 1		
HES-1005-9B	Houston ES	1st floor inside Classroom 148	10/5/15	< 1		
HES-1005-10A	Houston ES	1st floor inside Classroom 147	10/5/15	< 1		
HES-1005-10B	Houston ES	1st floor inside Classroom 147	10/5/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
HA-0317-1A	Hyde/Addison ES	3rd floor Hyde building inside Classroom 301	3/17/16	< 1		
HA-0317-1B	Hyde/Addison ES	3rd floor Hyde building inside Classroom 301	3/17/16	< 1		
HA-0317-2A	Hyde/Addison ES	3rd floor Hyde building inside Classroom 302	3/17/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
HA-0317-2B	Hyde/Addison ES	3rd floor Hyde building inside Classroom 302	3/17/16	< 1		
HA-0317-3A	Hyde/Addison ES	3rd floor Hyde building inside Classroom 304	3/17/16	1		
HA-0317-3B	Hyde/Addison ES	3rd floor Hyde building inside Classroom 304	3/17/16	< 1		
HA-0317-4A	Hyde/Addison ES	3rd floor Hyde building inside Classroom 305	3/17/16	< 1		
HA-0317-4B	Hyde/Addison ES	3rd floor Hyde building inside Classroom 305	3/17/16	< 1		
HA-0317-5A	Hyde/Addison ES	2nd floor Hyde building inside Classroom 201	3/17/16	1.5		
HA-0317-5B	Hyde/Addison ES	2nd floor Hyde building inside Classroom 201	3/17/16	< 1		
HA-0317-6A	Hyde/Addison ES	2nd floor Hyde building inside Classroom 202	3/17/16	< 1		
HA-0317-6B	Hyde/Addison ES	2nd floor Hyde building inside Classroom 202	3/17/16	< 1		
HA-0317-7A	Hyde/Addison ES	2nd floor Hyde building inside Classroom 205	3/17/16	< 1		
HA-0317-7B	Hyde/Addison ES	2nd floor Hyde building inside Classroom 205	3/17/16	< 1		
HA-0317-8A	Hyde/Addison ES	2nd floor hallway Addison building adjacent to Janitor's Closet 204 (high)	3/17/16	< 1		
HA-0317-8B	Hyde/Addison ES	2nd floor hallway Addison building adjacent to Janitor's Closet 204 (high)	3/17/16	< 1		
HA-0317-9A	Hyde/Addison ES	2nd floor hallway Addison building adjacent to Janitor's Closet 204 (low)	3/17/16	< 1		
HA-0317-9B	Hyde/Addison ES	2nd floor hallway Addison building adjacent to Janitor's Closet 204 (low)	3/17/16	< 1		
HA-0317-10A	Hyde/Addison ES	1st floor hallway Addison building adjacent to Electric Room 113 (high)	3/17/16	< 1		
HA-0317-10B	Hyde/Addison ES	1st floor hallway Addison building adjacent to Electric Room 113 (high)	3/17/16	< 1		
HA-0317-11A	Hyde/Addison ES	1st floor hallway Addison building adjacent to Electric Room 113 (low)	3/17/16	< 1		
HA-0317-11B	Hyde/Addison ES	1st floor hallway Addison building adjacent to Electric Room 113 (low)	3/17/16	< 1		
HA-0317-12A	Hyde/Addison ES	Basement floor hallway Addison adjacent to Student Services B03 (high)	3/17/16	< 1		
HA-0317-12B	Hyde/Addison ES	Basement floor hallway Addison adjacent to Student Services B03 (high)	3/17/16	< 1		
HA-0317-13A	Hyde/Addison ES	Basement floor hallway Addison adjacent to Student Services B03 (low)	3/17/16	< 1		
HA-0317-13B	Hyde/Addison ES	Basement floor hallway Addison adjacent to Student Services B03 (low)	3/17/16	< 1		
HA-0317-14A	Hyde/Addison ES	Basement floor Addison inside Multi-Purpose Room (high)	3/17/16	< 1		
HA-0317-14B	Hyde/Addison ES	Basement floor Addison inside Multi-Purpose Room (high)	3/17/16	< 1		
HA-0317-15A	Hyde/Addison ES	Basement floor Addison inside Multi-Purpose Room (low)	3/17/16	< 1		
HA-0317-15B	Hyde/Addison ES	Basement floor Addison inside Multi-Purpose Room (low)	3/17/16	< 1		
HA-0317-16A	Hyde/Addison ES	Basement floor Hyde inside Library	3/17/16	1.4		
HA-0317-16B	Hyde/Addison ES	Basement floor Hyde inside Library	3/17/16	< 1		
				<b>Percentage of Passed Samples</b>		<b>100.00%</b>
				<b>Percentage of Failed Samples</b>		<b>0.00%</b>
	Incarcerated Youth Program					
	Incarcerated Youth Program					
				<b>Percentage of Passed Samples</b>		<b>0.00%</b>
				<b>Percentage of Failed Samples</b>		<b>0.00%</b>
JO-0115-1A	J.O. Wilson ES	3rd floor hallway adjacent to Girl's Room near Classroom 328	1/15/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
JO-0115-1B	J.O. Wilson ES	3rd floor hallway adjacent to Girl's Room near Classroom 328	1/15/16	< 1		
JO-0115-2A	J.O. Wilson ES	3rd floor hallway adjacent to Staff Restroom near Classroom 329	1/15/16	< 1		
JO-0115-2B	J.O. Wilson ES	3rd floor hallway adjacent to Staff Restroom near Classroom 329	1/15/16	< 1		
JO-0115-3A	J.O. Wilson ES	3rd floor hallway adjacent to Staff Restroom near Classroom 321	1/15/16	< 1		
JO-0115-3B	J.O. Wilson ES	3rd floor hallway adjacent to Staff Restroom near Classroom 321	1/15/16	< 1		
JO-0115-4A	J.O. Wilson ES	3rd floor inside Classroom 322	1/15/16	< 1		
JO-0115-4B	J.O. Wilson ES	3rd floor inside Classroom 322	1/15/16	< 1		
JO-0115-5A	J.O. Wilson ES	3rd floor hallway across from North Stairwell	1/15/16	< 1		
JO-0115-5B	J.O. Wilson ES	3rd floor hallway across from North Stairwell	1/15/16	< 1		
JO-0115-6A	J.O. Wilson ES	3rd floor hallway adjacent to Custodian Closet 312	1/15/16	< 1		
JO-0115-6B	J.O. Wilson ES	3rd floor hallway adjacent to Custodian Closet 312	1/15/16	< 1		
JO-0115-7A	J.O. Wilson ES	3rd floor hallway across from Classroom 309	1/15/16	< 1		
JO-0115-7B	J.O. Wilson ES	3rd floor hallway across from Classroom 309	1/15/16	< 1		
JO-0115-8A	J.O. Wilson ES	2nd floor hallway adjacent to Classroom 208	1/15/16	< 1		
JO-0115-8B	J.O. Wilson ES	2nd floor hallway adjacent to Classroom 208	1/15/16	< 1		
JO-0115-9A	J.O. Wilson ES	2nd floor hallway adjacent to Custodian Closet 214	1/15/16	< 1		
JO-0115-9B	J.O. Wilson ES	2nd floor hallway adjacent to Custodian Closet 214	1/15/16	< 1		
JO-0115-10A	J.O. Wilson ES	2nd floor hallway across from North Stairwell	1/15/16	< 1		
JO-0115-10B	J.O. Wilson ES	2nd floor hallway across from North Stairwell	1/15/16	< 1		
JO-0115-11A	J.O. Wilson ES	2nd floor hallway adjacent to Staff Restroom near Classroom 223	1/15/16	< 1		
JO-0115-11B	J.O. Wilson ES	2nd floor hallway adjacent to Staff Restroom near Classroom 223	1/15/16	< 1		
JO-0115-12A	J.O. Wilson ES	2nd floor hallway adjacent to Boy's Room near Classroom 220	1/15/16	< 1		
JO-0115-12B	J.O. Wilson ES	2nd floor hallway adjacent to Boy's Room near Classroom 220	1/15/16	< 1		
JO-0115-13A	J.O. Wilson ES	2nd floor inside Classroom 220	1/15/16	< 1		
JO-0115-13B	J.O. Wilson ES	2nd floor inside Classroom 220	1/15/16	< 1		
JO-0115-14A	J.O. Wilson ES	2nd floor inside Classroom 221	1/15/16	< 1		
JO-0115-14B	J.O. Wilson ES	2nd floor inside Classroom 221	1/15/16	< 1		
JO-0115-15A	J.O. Wilson ES	2nd floor inside Classroom 221	1/15/16	< 1		
JO-0115-15B	J.O. Wilson ES	2nd floor inside Classroom 221	1/15/16	< 1		
JO-0115-16A	J.O. Wilson ES	2nd floor inside Classroom 222	1/15/16	< 1		
JO-0115-16B	J.O. Wilson ES	2nd floor inside Classroom 222	1/15/16	< 1		
JO-0115-17A	J.O. Wilson ES	2nd floor inside Classroom 222	1/15/16	< 1		
JO-0115-17B	J.O. Wilson ES	2nd floor inside Classroom 222	1/15/16	< 1		
JO-0115-18A	J.O. Wilson ES	1st floor hallway adjacent to Classroom 110	1/15/16	< 1		
JO-0115-18B	J.O. Wilson ES	1st floor hallway adjacent to Classroom 110	1/15/16	< 1		
JO-0115-19A	J.O. Wilson ES	1st floor inside Classroom 110	1/15/16	< 1		
JO-0115-19B	J.O. Wilson ES	1st floor inside Classroom 110	1/15/16	< 1		
JO-0115-20A	J.O. Wilson ES	1st floor inside Classroom 111	1/15/16	< 1		
JO-0115-20B	J.O. Wilson ES	1st floor inside Classroom 111	1/15/16	< 1		
JO-0115-21A	J.O. Wilson ES	1st floor inside Classroom 109	1/15/16	< 1		
JO-0115-21B	J.O. Wilson ES	1st floor inside Classroom 109	1/15/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
JO-0115-22A	J.O. Wilson ES	1st floor inside Classroom 112	1/15/16	< 1		
JO-0115-22B	J.O. Wilson ES	1st floor inside Classroom 112	1/15/16	< 1		
JO-0115-23A	J.O. Wilson ES	1st floor hallway adjacent to Custodian Closet 114	1/15/16	< 1		
JO-0115-23B	J.O. Wilson ES	1st floor hallway adjacent to Custodian Closet 114	1/15/16	< 1		
JO-0115-24A	J.O. Wilson ES	1st floor inside Classroom 108	1/15/16	< 1		
JO-0115-24B	J.O. Wilson ES	1st floor inside Classroom 108	1/15/16	< 1		
JO-0115-25A	J.O. Wilson ES	1st floor hallway adjacent to Classroom 121	1/15/16	< 1		
JO-0115-25B	J.O. Wilson ES	1st floor hallway adjacent to Classroom 121	1/15/16	< 1		
JO-0115-26A	J.O. Wilson ES	1st floor inside Classroom 121	1/15/16	< 1		
JO-0115-26B	J.O. Wilson ES	1st floor inside Classroom 121	1/15/16	< 1		
JO-0115-27A	J.O. Wilson ES	1st floor inside Classroom 123	1/15/16	< 1		
JO-0115-27B	J.O. Wilson ES	1st floor inside Classroom 123	1/15/16	< 1		
JO-0115-28A	J.O. Wilson ES	1st floor hallway across from North Stairwell	1/15/16	< 1		
JO-0115-28B	J.O. Wilson ES	1st floor hallway across from North Stairwell	1/15/16	< 1		
JO-0115-29A	J.O. Wilson ES	1st floor inside Multi-Purpose Room	1/15/16	< 1		
JO-0115-29B	J.O. Wilson ES	1st floor inside Multi-Purpose Room	1/15/16	< 1		
JO-0115-30A	J.O. Wilson ES	1st floor hallway adjacent to Custodian Office	1/15/16	< 1		
JO-0115-30B	J.O. Wilson ES	1st floor hallway adjacent to Custodian Office	1/15/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
	Janney ES					
	Janney ES					
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
JMS-0114-1A	Jefferson MS	3rd floor hallway adjacent to Girl's Room	1/14/16	< 1		
JMS-0114-1B	Jefferson MS	3rd floor hallway adjacent to Girl's Room	1/14/16	< 1		
JMS-0114-2A	Jefferson MS	3rd floor hallway adjacent to Boy's Room	1/14/16	< 1		
JMS-0114-2B	Jefferson MS	3rd floor hallway adjacent to Boy's Room	1/14/16	< 1		
JMS-0114-3A	Jefferson MS	2nd floor hallway adjacent to Men's Room	1/14/16	< 1		
JMS-0114-3B	Jefferson MS	2nd floor hallway adjacent to Men's Room	1/14/16	< 1		
JMS-0114-4A	Jefferson MS	2nd floor hallway adjacent to Classroom 207	1/14/16	< 1		
JMS-0114-4B	Jefferson MS	2nd floor hallway adjacent to Classroom 207	1/14/16	< 1		
JMS-0114-5A	Jefferson MS	1st floor hallway adjacent to Boy's Room	1/14/16	< 1		
JMS-0114-5B	Jefferson MS	1st floor hallway adjacent to Boy's Room	1/14/16	< 1		
JMS-0114-6A	Jefferson MS	1st floor hallway adjacent to Girl's Room	1/14/16	< 1		
JMS-0114-6B	Jefferson MS	1st floor hallway adjacent to Girl's Room	1/14/16	< 1		
JMS-0114-7A	Jefferson MS	Basement floor hallway adjacent to Room 004	1/14/16	< 1		
JMS-0114-7B	Jefferson MS	Basement floor hallway adjacent to Room 004	1/14/16	< 1		
JMS-0114-8A	Jefferson MS	Basement floor hallway adjacent to Boiler Room B20	1/14/16	< 1		
JMS-0114-8B	Jefferson MS	Basement floor hallway adjacent to Boiler Room B20	1/14/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
JMS-0114-9A	Jefferson MS	Basement floor inside Boy's Locker Room	1/14/16	< 1		
JMS-0114-9B	Jefferson MS	Basement floor inside Boy's Locker Room	1/14/16	< 1		
JMS-0114-10A	Jefferson MS	Basement floor inside Girl's Locker Room	1/14/16	< 1		
JMS-0114-10B	Jefferson MS	Basement floor inside Girl's Locker Room	1/14/16	< 1		
JMS-0114-11A	Jefferson MS	Basement floor inside Cafeteria	1/14/16	< 1		
JMS-0114-11B	Jefferson MS	Basement floor inside Cafeteria	1/14/16	< 1		
JMS-0114-12A	Jefferson MS	Basement floor hallway adjacent to Room B01	1/14/16	< 1		
JMS-0114-12B	Jefferson MS	Basement floor hallway adjacent to Room B01	1/14/16	< 1		
JMS-0114-13A	Jefferson MS	Basement floor hallway between Restroom and Storage near Coach's Office	1/14/16	< 1		
JMS-0114-13B	Jefferson MS	Basement floor hallway between Restroom and Storage near Coach's Office	1/14/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
JMS-1113-1A	Johnson MS	4th floor hallway adjacent to Room 416	11/13/15	< 1		
JMS-1113-1B	Johnson MS	4th floor hallway adjacent to Room 416	11/13/15	< 1		
JMS-1113-2A	Johnson MS	4th floor hallway across from Classroom 420	11/13/15	< 1		
JMS-1113-2B	Johnson MS	4th floor hallway across from Classroom 420	11/13/15	< 1		
JMS-1113-3A	Johnson MS	3rd floor hallway adjacent to Elevator	11/13/15	< 1		
JMS-1113-3B	Johnson MS	3rd floor hallway adjacent to Elevator	11/13/15	< 1		
JMS-1113-4A	Johnson MS	3rd floor hallway adjacent to Girl's Room (high)	11/13/15	< 1		
JMS-1113-4B	Johnson MS	3rd floor hallway adjacent to Girl's Room (high)	11/13/15	< 1		
JMS-1113-5A	Johnson MS	3rd floor hallway adjacent to Girl's Room (low)	11/13/15	< 1		
JMS-1113-5B	Johnson MS	3rd floor hallway adjacent to Girl's Room (low)	11/13/15	< 1		
JMS-1113-6A	Johnson MS	3rd floor hallway across from Mechanical Room 315 A (high)	11/13/15	< 1		
JMS-1113-6B	Johnson MS	3rd floor hallway across from Mechanical Room 315 A (high)	11/13/15	< 1		
JMS-1113-7A	Johnson MS	3rd floor hallway across from Mechanical Room 315 A (low)	11/13/15	< 1		
JMS-1113-7B	Johnson MS	3rd floor hallway across from Mechanical Room 315 A (low)	11/13/15	< 1		
JMS-1113-8A	Johnson MS	2nd floor hallway adjacent to Girl's Room (high)	11/13/15	< 1		
JMS-1113-8B	Johnson MS	2nd floor hallway adjacent to Girl's Room (high)	11/13/15	< 1		
JMS-1113-9A	Johnson MS	2nd floor hallway adjacent to Girl's Room (low)	11/13/15	< 1		
JMS-1113-9B	Johnson MS	2nd floor hallway adjacent to Girl's Room (low)	11/13/15	< 1		
JMS-1113-10A	Johnson MS	2nd floor hallway adjacent to Science Lab 220 (high)	11/13/15	< 1		
JMS-1113-10B	Johnson MS	2nd floor hallway adjacent to Science Lab 220 (high)	11/13/15	< 1		
JMS-1113-11A	Johnson MS	2nd floor hallway adjacent to Science Lab 220 (low)	11/13/15	< 1		
JMS-1113-11B	Johnson MS	2nd floor hallway adjacent to Science Lab 220 (low)	11/13/15	< 1		
JMS-1113-12A	Johnson MS	1st floor hallway adjacent to Girl's Room	11/13/15	< 1		
JMS-1113-12B	Johnson MS	1st floor hallway adjacent to Girl's Room	11/13/15	< 1		
JMS-1113-13A	Johnson MS	Basement floor inside Cafeteria adjacent to Janitor's Closet	11/13/15	< 1		
JMS-1113-13B	Johnson MS	Basement floor inside Cafeteria adjacent to Janitor's Closet	11/13/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
JMS-1113-14A	Johnson MS	Basement floor inside Cafeteria adjacent to Weight Room	11/13/15	< 1		
JMS-1113-14B	Johnson MS	Basement floor inside Cafeteria adjacent to Weight Room	11/13/15	< 1		
JMS-1113-15A	Johnson MS	2nd floor B-wing hallway adjacent to Men's Room	11/13/15	< 1		
JMS-1113-15B	Johnson MS	2nd floor B-wing hallway adjacent to Men's Room	11/13/15	< 1		
JMS-1113-16A	Johnson MS	1st floor B-wing hallway adjacent to Men's Room	11/13/15	< 1		
JMS-1113-16B	Johnson MS	1st floor B-wing hallway adjacent to Men's Room	11/13/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
KM-1215-1A	Kelly Miller MS	3rd floor hallway adjacent to Boy's Room (high)	12/15/15	< 1		
KM-1215-1B	Kelly Miller MS	3rd floor hallway adjacent to Boy's Room (high)	12/15/15	< 1		
KM-1215-2A	Kelly Miller MS	3rd floor hallway adjacent to Boy's Room (low)	12/15/15	< 1		
KM-1215-2B	Kelly Miller MS	3rd floor hallway adjacent to Boy's Room (low)	12/15/15	< 1		
KM-1215-3A	Kelly Miller MS	3rd floor hallway adjacent to Girl's Room (high)	12/15/15	< 1		
KM-1215-3B	Kelly Miller MS	3rd floor hallway adjacent to Girl's Room (high)	12/15/15	< 1		
KM-1215-4A	Kelly Miller MS	3rd floor hallway adjacent to Girl's Room (low)	12/15/15	< 1		
KM-1215-4B	Kelly Miller MS	3rd floor hallway adjacent to Girl's Room (low)	12/15/15	< 1		
KM-1215-5A	Kelly Miller MS	2nd floor hallway adjacent to Boy's Room (high)	12/15/15	< 1		
KM-1215-5B	Kelly Miller MS	2nd floor hallway adjacent to Boy's Room (high)	12/15/15	< 1		
KM-1215-6A	Kelly Miller MS	2nd floor hallway adjacent to Boy's Room (low)	12/15/15	< 1		
KM-1215-6B	Kelly Miller MS	2nd floor hallway adjacent to Boy's Room (low)	12/15/15	< 1		
KM-1215-7A	Kelly Miller MS	2nd floor hallway adjacent to Girl's Room (high)	12/15/15	< 1		
KM-1215-7B	Kelly Miller MS	2nd floor hallway adjacent to Girl's Room (high)	12/15/15	< 1		
KM-1215-8A	Kelly Miller MS	2nd floor hallway adjacent to Girl's Room (low)	12/15/15	< 1		
KM-1215-8B	Kelly Miller MS	2nd floor hallway adjacent to Girl's Room (low)	12/15/15	< 1		
KM-1215-9A	Kelly Miller MS	1st floor hallway adjacent to Boy's Room (high)	12/15/15	< 1		
KM-1215-9B	Kelly Miller MS	1st floor hallway adjacent to Boy's Room (high)	12/15/15	< 1		
KM-1215-10A	Kelly Miller MS	1st floor hallway adjacent to Boy's Room (low)	12/15/15	< 1		
KM-1215-10B	Kelly Miller MS	1st floor hallway adjacent to Boy's Room (low)	12/15/15	< 1		
KM-1215-11A	Kelly Miller MS	1st floor hallway adjacent to Girl's Room (high)	12/15/15	< 1		
KM-1215-11B	Kelly Miller MS	1st floor hallway adjacent to Girl's Room (high)	12/15/15	< 1		
KM-1215-12A	Kelly Miller MS	1st floor hallway adjacent to Girl's Room (low)	12/15/15	< 1		
KM-1215-12B	Kelly Miller MS	1st floor hallway adjacent to Girl's Room (low)	12/15/15	< 1		
KM-1215-13A	Kelly Miller MS	1st floor inside Cafeteria (high)	12/15/15	< 1		
KM-1215-13B	Kelly Miller MS	1st floor inside Cafeteria (high)	12/15/15	< 1		
KM-1215-14A	Kelly Miller MS	1st floor inside Cafeteria (low)	12/15/15	< 1		
KM-1215-14B	Kelly Miller MS	1st floor inside Cafeteria (low)	12/15/15	< 1		
KM-1215-15A	Kelly Miller MS	1st floor inside Room B135	12/15/15	2		
KM-1215-15B	Kelly Miller MS	1st floor inside Room B135	12/15/15	1.3		
KM-1215-16A	Kelly Miller MS	1st floor inside Gym adjacent to Electric Room D122	12/15/15	< 1		
KM-1215-16B	Kelly Miller MS	1st floor inside Gym adjacent to Electric Room D122	12/15/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
KM-1215-17A	Kelly Miller MS	1st floor inside Gym adjacent to Girl's Locker Room	12/15/15	< 1		
KM-1215-17B	Kelly Miller MS	1st floor inside Gym adjacent to Girl's Locker Room	12/15/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
KES-1109-1A	Ketcham ES	3rd floor hallway between Boy's and Girl's Rooms	11/9/15	< 1		
KES-1109-1B	Ketcham ES	3rd floor hallway between Boy's and Girl's Rooms	11/9/15	< 1		
KES-1109-2A	Ketcham ES	2nd floor hallway between Boy's and Girl's Rooms	11/9/15	7.5		
KES-1109-2B	Ketcham ES	2nd floor hallway between Boy's and Girl's Rooms	11/9/15	10		
KES-1109-3A	Ketcham ES	1st floor hallway between Boy's and Girl's Rooms	11/9/15	4.5		
KES-1109-3B	Ketcham ES	1st floor hallway between Boy's and Girl's Rooms	11/9/15	11		
KES-1109-4A	Ketcham ES	1st floor inside Classroom B116 Pre-K	11/9/15	1.4		
KES-1109-4B	Ketcham ES	1st floor inside Classroom B116 Pre-K	11/9/15	< 1		
KES-1109-5A	Ketcham ES	1st floor inside Classroom B114 Pre-K	11/9/15	2.5		
KES-1109-5B	Ketcham ES	1st floor inside Classroom B114 Pre-K	11/9/15	< 1		
KES-1109-6A	Ketcham ES	1st floor inside Classroom B113 Pre-K	11/9/15	2.7		
KES-1109-6B	Ketcham ES	1st floor inside Classroom B113 Pre-K	11/9/15	< 1		
KES-1109-7A	Ketcham ES	1st floor inside vestibule between Classrooms B112 and B109	11/9/15	2.7		
KES-1109-7B	Ketcham ES	1st floor inside vestibule between Classrooms B112 and B109	11/9/15	1		
KES-1109-8A	Ketcham ES	1st floor inside Classroom A101 Kindergarten	11/9/15	2.2		
KES-1109-8B	Ketcham ES	1st floor inside Classroom A101 Kindergarten	11/9/15	< 1		
KES-1109-9A	Ketcham ES	1st floor hallway adjacent to Music Room A102	11/9/15	< 1		
KES-1109-9B	Ketcham ES	1st floor hallway adjacent to Music Room A102	11/9/15	< 1		
KES-1109-10A	Ketcham ES	Basement floor hallway adjacent to Girl's Room	11/9/15	< 1		
KES-1109-10	Ketcham ES	Basement floor hallway adjacent to Girl's Room	11/9/15	< 1		
KES-1109-11A	Ketcham ES	Basement inside Cafeteria	11/9/15	< 1		
KES-1109-11B	Ketcham ES	Basement inside Cafeteria	11/9/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
KES-0407-1A	Key ES	2nd floor inside Classroom 208	4/7/16	< 1		
KES-0407-1B	Key ES	2nd floor inside Classroom 208	4/7/16	< 1		
KES-0407-2A	Key ES	2nd floor adjacent to Classroom 209	4/7/16	< 1		
KES-0407-2B	Key ES	2nd floor adjacent to Classroom 209	4/7/16	< 1		
KES-0407-3A	Key ES	2nd floor inside Classroom 209	4/7/16	< 1		
KES-0407-3B	Key ES	2nd floor inside Classroom 209	4/7/16	< 1		
KES-0407-4A	Key ES	2nd floor inside Classroom 210	4/7/16	< 1		
KES-0407-4B	Key ES	2nd floor inside Classroom 210	4/7/16	< 1		
KES-0407-5A	Key ES	2nd floor inside Classroom 207	4/7/16	< 1		
KES-0407-5B	Key ES	2nd floor inside Classroom 207	4/7/16	< 1		
KES-0407-6A	Key ES	2nd floor inside Classroom 212	4/7/16	< 1		
KES-0407-6B	Key ES	2nd floor inside Classroom 212	4/7/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
KES-0407-7A	Key ES	2nd floor inside Classroom 211	4/7/16	< 1		
KES-0407-7B	Key ES	2nd floor inside Classroom 211	4/7/16	< 1		
KES-0407-8A	Key ES	2nd floor inside Classroom 205	4/7/16	< 1		
KES-0407-8B	Key ES	2nd floor inside Classroom 205	4/7/16	< 1		
KES-0407-9A	Key ES	2nd floor inside Classroom 206 (left)	4/7/16	< 1		
KES-0407-9B	Key ES	2nd floor inside Classroom 206 (left)	4/7/16	< 1		
KES-0407-10A	Key ES	2nd floor inside Classroom 206 (right)	4/7/16	< 1		
KES-0407-10B	Key ES	2nd floor inside Classroom 206 (right)	4/7/16	< 1		
KES-0407-11A	Key ES	2nd floor hallway adjacent to Classroom 204	4/7/16	< 1		
KES-0407-11B	Key ES	2nd floor hallway adjacent to Classroom 204	4/7/16	< 1		
KES-0407-12A	Key ES	2nd floor inside Classroom 204	4/7/16	< 1		
KES-0407-12B	Key ES	2nd floor inside Classroom 204	4/7/16	< 1		
KES-0407-13A	Key ES	2nd floor inside Classroom 203	4/7/16	< 1		
KES-0407-13B	Key ES	2nd floor inside Classroom 203	4/7/16	< 1		
KES-0407-14A	Key ES	2nd floor inside Classroom 202	4/7/16	< 1		
KES-0407-14B	Key ES	2nd floor inside Classroom 202	4/7/16	< 1		
KES-0407-15A	Key ES	2nd floor inside Classroom 201	4/7/16	< 1		
KES-0407-15B	Key ES	2nd floor inside Classroom 201	4/7/16	< 1		
KES-0407-16A	Key ES	1st floor inside Classroom 101	4/7/16	< 1		
KES-0407-16B	Key ES	1st floor inside Classroom 101	4/7/16	< 1		
KES-0407-17A	Key ES	1st floor inside Classroom 102	4/7/16	< 1		
KES-0407-17B	Key ES	1st floor inside Classroom 102	4/7/16	< 1		
KES-0407-18A	Key ES	1st floor inside Classroom 103	4/7/16	< 1		
KES-0407-18B	Key ES	1st floor inside Classroom 103	4/7/16	< 1		
KES-0407-19A	Key ES	1st floor inside Classroom 104	4/7/16	< 1		
KES-0407-19B	Key ES	1st floor inside Classroom 104	4/7/16	< 1		
KES-0407-20A	Key ES	1st floor hallway adjacent to Classroom 104	4/7/16	< 1		
KES-0407-20B	Key ES	1st floor hallway adjacent to Classroom 104	4/7/16		16	Device has been turned off. Filter installation pending.
KES-0407-21A	Key ES	1st floor hallway adjacent to Classroom 103	4/7/16	< 1		
KES-0407-21B	Key ES	1st floor hallway adjacent to Classroom 103	4/7/16	< 1		
KES-0407-22A	Key ES	1st floor inside Classroom 105	4/7/16	< 1		
KES-0407-22B	Key ES	1st floor inside Classroom 105	4/7/16	< 1		
KES-0407-23A	Key ES	1st floor inside Classroom 106	4/7/16	< 1		
KES-0407-23B	Key ES	1st floor inside Classroom 106	4/7/16	< 1		
KES-0407-24A	Key ES	Basement floor hallway between Boy's and Girl's Restrooms	4/7/16	< 1		
KES-0407-24B	Key ES	Basement floor hallway between Boy's and Girl's Restrooms	4/7/16	< 1		
<b>Percentage of Passed Samples</b>					<b>97.92%</b>	
<b>Percentage of Failed Samples</b>					<b>2.08%</b>	

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
KES-0104-1A	Kimball ES	2nd floor hallway South Wing between Teacher's Restroom and Custodian Closet	1/4/16	< 1		
KES-0104-1B	Kimball ES	2nd floor hallway South Wing between Teacher's Restroom and Custodian Closet	1/4/16	< 1		
KES-0104-2A	Kimball ES	1st floor inside Classroom 109	1/4/16	1.6		
KES-0104-2B	Kimball ES	1st floor inside Classroom 109	1/4/16	< 1		
KES-0104-3A	Kimball ES	1st floor hallway across from Classroom 109	1/4/16	< 1		
KES-0104-3B	Kimball ES	1st floor hallway across from Classroom 109	1/4/16	< 1		
KES-0104-4A	Kimball ES	1st floor hallway adjacent to Conference Room 108	1/4/16	< 1		
KES-0104-4B	Kimball ES	1st floor hallway adjacent to Conference Room 108	1/4/16	< 1		
KES-0104-5A	Kimball ES	2nd floor hallway Middle Wing adjacent to Teacher's Lounge	1/4/16	< 1		
KES-0104-5B	Kimball ES	2nd floor hallway Middle Wing adjacent to Teacher's Lounge	1/4/16	< 1		
KES-0104-6A	Kimball ES	2nd floor hallway Middle Wing adjacent to Classroom 212	1/4/16	< 1		
KES-0104-6B	Kimball ES	2nd floor hallway Middle Wing adjacent to Classroom 212	1/4/16	< 1		
KES-0104-7A	Kimball ES	Basement floor @ exit to Cafeteria across from Kitchen	1/4/16	< 1		
KES-0104-7B	Kimball ES	Basement floor @ exit to Cafeteria across from Kitchen	1/4/16	< 1		
KES-0104-8A	Kimball ES	1st floor hallway adjacent to Auditorium	1/4/16	< 1		
KES-0104-8B	Kimball ES	1st floor hallway adjacent to Auditorium	1/4/16	< 1		
KES-0104-9A	Kimball ES	1st floor inside Classroom 102	1/4/16	< 1		
KES-0104-9B	Kimball ES	1st floor inside Classroom 102	1/4/16	< 1		
KES-0104-10A	Kimball ES	1st floor hallway North Wing across from Classroom 102	1/4/16	< 1		
KES-0104-10B	Kimball ES	1st floor hallway North Wing across from Classroom 102	1/4/16	4.1		
KES-0104-11A	Kimball ES	1st floor hallway North Wing across from Classroom 104	1/4/16	< 1		
KES-0104-11B	Kimball ES	1st floor hallway North Wing across from Classroom 104	1/4/16	< 1		
KES-0104-12A	Kimball ES	2nd floor hallway North Wing adjacent to Classroom 200	1/4/16	1.1		
KES-0104-12B	Kimball ES	2nd floor hallway North Wing adjacent to Classroom 200	1/4/16	1.8		
KES-0104-13A	Kimball ES	2nd floor hallway North Wing adjacent to Science Lab 203	1/4/16	< 1		
KES-0104-13B	Kimball ES	2nd floor hallway North Wing adjacent to Science Lab 203	1/4/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
KMS-1110-1A	Kramer MS	3rd floor hallway adjacent to Classroom 306 (high)	11/10/15	< 1		
KMS-1110-1B	Kramer MS	3rd floor hallway adjacent to Classroom 306 (high)	11/10/15	< 1		
KMS-1110-2A	Kramer MS	3rd floor hallway adjacent to Classroom 301 (high)	11/10/15	< 1		
KMS-1110-2B	Kramer MS	3rd floor hallway adjacent to Classroom 301 (high)	11/10/15	< 1		
KMS-1110-3A	Kramer MS	3rd floor hallway adjacent to Classroom 301 (low)	11/10/15	< 1		
KMS-1110-3B	Kramer MS	3rd floor hallway adjacent to Classroom 301 (low)	11/10/15	< 1		
KMS-1110-4A	Kramer MS	3rd floor hallway near Stairwell C (high)	11/10/15	< 1		
KMS-1110-4B	Kramer MS	3rd floor hallway near Stairwell C (high)	11/10/15	< 1		
KMS-1110-5A	Kramer MS	3rd floor hallway near Stairwell C (low)	11/10/15	< 1		
KMS-1110-5B	Kramer MS	3rd floor hallway near Stairwell C (low)	11/10/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
KMS-1110-6A	Kramer MS	2nd floor hallway adjacent to Classroom 204 (high)	11/10/15	< 1		
KMS-1110-6B	Kramer MS	2nd floor hallway adjacent to Classroom 204 (high)	11/10/15	< 1		
KMS-1110-7A	Kramer MS	2nd floor hallway adjacent to Classroom 204 (low)	11/10/15	< 1		
KMS-1110-7B	Kramer MS	2nd floor hallway adjacent to Classroom 204 (low)	11/10/15	< 1		
KMS-1110-8A	Kramer MS	2nd floor hallway near Stairwell C (high)	11/10/15	< 1		
KMS-1110-8B	Kramer MS	2nd floor hallway near Stairwell C (high)	11/10/15	< 1		
KMS-1110-9A	Kramer MS	2nd floor hallway near Stairwell C (low)	11/10/15	< 1		
KMS-1110-9B	Kramer MS	2nd floor hallway near Stairwell C (low)	11/10/15	< 1		
KMS-1110-10A	Kramer MS	2nd floor hallway adjacent to Electric Closet 200 (high)	11/10/15	< 1		
KMS-1110-10B	Kramer MS	2nd floor hallway adjacent to Electric Closet 200 (high)	11/10/15	< 1		
KMS-1110-11A	Kramer MS	2nd floor hallway adjacent to Electric Closet 200 (low)	11/10/15	< 1		
KMS-1110-11B	Kramer MS	2nd floor hallway adjacent to Electric Closet 200 (low)	11/10/15	< 1		
KMS-1110-12A	Kramer MS	1st floor hallway adjacent to Classroom 129 (high)	11/10/15	< 1		
KMS-1110-12B	Kramer MS	1st floor hallway adjacent to Classroom 129 (high)	11/10/15	< 1		
KMS-1110-13A	Kramer MS	1st floor hallway adjacent to Classroom 129 (low)	11/10/15	< 1		
KMS-1110-13B	Kramer MS	1st floor hallway adjacent to Classroom 129 (low)	11/10/15	11		
KMS-1110-14A	Kramer MS	1st floor hallway near Stairwell C (high)	11/10/15	< 1		
KMS-1110-14B	Kramer MS	1st floor hallway near Stairwell C (high)	11/10/15	< 1		
KMS-1110-15A	Kramer MS	1st floor hallway near Stairwell C (low)	11/10/15	< 1		
KMS-1110-15B	Kramer MS	1st floor hallway near Stairwell C (low)	11/10/15	< 1		
KMS-1110-16A	Kramer MS	1st floor hallway adjacent to Principal's Office 104 (high)	11/10/15	< 1		
KMS-1110-16B	Kramer MS	1st floor hallway adjacent to Principal's Office 104 (high)	11/10/15	< 1		
KMS-1110-17A	Kramer MS	1st floor hallway adjacent to Principal's Office 104 (low)	11/10/15	< 1		
KMS-1110-17B	Kramer MS	1st floor hallway adjacent to Principal's Office 104 (low)	11/10/15	< 1		
KMS-1110-18A	Kramer MS	Basement floor hallway adjacent to Custodian's Office 003 (high)	11/10/15	< 1		
KMS-1110-18B	Kramer MS	Basement floor hallway adjacent to Custodian's Office 003 (high)	11/10/15	< 1		
KMS-1110-19A	Kramer MS	Basement floor hallway near Stairwell C (high)	11/10/15	< 1		
KMS-1110-19B	Kramer MS	Basement floor hallway near Stairwell C (high)	11/10/15	< 1		
KMS-1110-20A	Kramer MS	Basement floor hallway near Stairwell C (low)	11/10/15	< 1		
KMS-1110-20B	Kramer MS	Basement floor hallway near Stairwell C (low)	11/10/15	< 1		
KMS-1110-21A	Kramer MS	Basement floor hallway adjacent to Electric Closet 019 (high)	11/10/15	< 1		
KMS-1110-21B	Kramer MS	Basement floor hallway adjacent to Electric Closet 019 (high)	11/10/15	< 1		
KMS-1110-22A	Kramer MS	Basement floor hallway adjacent to Electric Closet 019 (low)	11/10/15	< 1		
KMS-1110-22B	Kramer MS	Basement floor hallway adjacent to Electric Closet 019 (low)	11/10/15	< 1		
			<b>Percentage of Passed Samples</b>			<b>100.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
LES-0303-1A	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (high, left)	3/3/16	< 1		
LES-0303-1B	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (high, left)	3/3/16	< 1		
LES-0303-2A	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (low, left)	3/3/16	< 1		
LES-0303-2B	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (low, left)	3/3/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
LES-0303-3A	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (high, right)	3/3/16	< 1		
LES-0303-3B	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (high, right)	3/3/16	< 1		
LES-0303-4A	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (low, right)	3/3/16	< 1		
LES-0303-4B	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (low, right)	3/3/16	< 1		
LES-0303-5A	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room F110 (high, left)	3/3/16	< 1		
LES-0303-5B	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room G102 (high, left)	3/3/16	< 1		
LES-0303-6A	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room G102 (low, left)	3/3/16	< 1		
LES-0303-6B	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room G102 (low, left)	3/3/16	< 1		
LES-0303-7A	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room G102 (high, right)	3/3/16	< 1		
LES-0303-7B	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room G102 (high, right)	3/3/16	< 1		
LES-0303-8A	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room G102 (low, right)	3/3/16	< 1		
LES-0303-8B	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room G102 (low, right)	3/3/16	< 1		
LES-0303-9A	Lafayette ES (Trailers F,G&H)	Trailer H hallway across from Room H102 (high, left)	3/3/16	< 1		
LES-0303-9B	Lafayette ES (Trailers F,G&H)	Trailer H hallway across from Room H102 (high, left)	3/3/16	< 1		
LES-0303-10A	Lafayette ES (Trailers F,G&H)	Trailer H hallway across from Room H102 (low, left)	3/3/16	< 1		
LES-0303-10B	Lafayette ES (Trailers F,G&H)	Trailer H hallway across from Room H102 (low, left)	3/3/16	< 1		
LES-0303-11A	Lafayette ES (Trailers F,G&H)	Trailer H hallway across from Room H102 (high, right)	3/3/16	< 1		
LES-0303-11B	Lafayette ES (Trailers F,G&H)	Trailer H hallway across from Room H102 (high, right)	3/3/16	< 1		
LES-0303-12A	Lafayette ES (Trailers F,G&H)	Trailer H hallway across from Room H102 (low, right)	3/3/16	< 1		
LES-0303-12B	Lafayette ES (Trailers F,G&H)	Trailer H hallway across from Room H102 (low, right)	3/3/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LES-1027-1A	Langdon ES	2nd floor hallway across from Classroom 212 (high)	10/27/15	< 1		
LES-1027-1B	Langdon ES	2nd floor hallway across from Classroom 212 (high)	10/27/15	< 1		
LES-1027-2A	Langdon ES	2nd floor hallway across from Classroom 212 (low)	10/27/15	< 1		
LES-1027-2B	Langdon ES	2nd floor hallway across from Classroom 212 (low)	10/27/15	< 1		
LES-1027-3A	Langdon ES	2nd floor hallway adjacent to Classroom 204 (high)	10/27/15	< 1		
LES-1027-3B	Langdon ES	2nd floor hallway adjacent to Classroom 204 (high)	10/27/15	< 1		
LES-1027-4A	Langdon ES	2nd floor hallway adjacent to Classroom 204 (low)	10/27/15	< 1		
LES-1027-4B	Langdon ES	2nd floor hallway adjacent to Classroom 204 (low)	10/27/15	< 1		
LES-1027-5A	Langdon ES	2nd floor hallway adjacent to Classroom 253 (high)	10/27/15	< 1		
LES-1027-5B	Langdon ES	2nd floor hallway adjacent to Classroom 253 (high)	10/27/15	< 1		
LES-1027-6A	Langdon ES	2nd floor hallway adjacent to Classroom 253 (low)	10/27/15	< 1		
LES-1027-6B	Langdon ES	2nd floor hallway adjacent to Classroom 253 (low)	10/27/15	< 1		
LES-1027-7A	Langdon ES	2nd floor inside Science Room 247	10/27/15	< 1		
LES-1027-7B	Langdon ES	2nd floor inside Science Room 247	10/27/15	< 1		
LES-1027-8A	Langdon ES	1st floor hallway adjacent to Classroom 153 (high)	10/27/15	< 1		
LES-1027-8B	Langdon ES	1st floor hallway adjacent to Classroom 153 (high)	10/27/15	< 1		
LES-1027-9A	Langdon ES	1st floor hallway adjacent to Classroom 153 (low)	10/27/15	< 1		
LES-1027-9B	Langdon ES	1st floor hallway adjacent to Classroom 153 (low)	10/27/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
LES-1027-10A	Langdon ES	1st floor hallway adjacent to Classroom 104 (high)	10/27/15	< 1		
LES-1027-10B	Langdon ES	1st floor hallway adjacent to Classroom 104 (high)	10/27/15	< 1		
LES-1027-11A	Langdon ES	1st floor hallway adjacent to Classroom 104 (low)	10/27/15	< 1		
LES-1027-11B	Langdon ES	1st floor hallway adjacent to Classroom 104 (low)	10/27/15	< 1		
LES-1027-12A	Langdon ES	1st floor inside Classroom 101	10/27/15	< 1		
LES-1027-12B	Langdon ES	1st floor inside Classroom 101	10/27/15	< 1		
LES-1027-13A	Langdon ES	1st floor inside Classroom 102	10/27/15	< 1		
LES-1027-13B	Langdon ES	1st floor inside Classroom 102	10/27/15	< 1		
LES-1027-14A	Langdon ES	1st floor inside Classroom 104	10/27/15	1.8		
LES-1027-14B	Langdon ES	1st floor inside Classroom 104	10/27/15	< 1		
LES-1027-15A	Langdon ES	1st floor inside Classroom 106	10/27/15	< 1		
LES-1027-15B	Langdon ES	1st floor inside Classroom 106	10/27/15	< 1		
LES-1027-16A	Langdon ES	1st floor inside Classroom 107	10/27/15	< 1		
LES-1027-16B	Langdon ES	1st floor inside Classroom 107	10/27/15	< 1		
LES-1027-17A	Langdon ES	1st floor inside Classroom 108	10/27/15	< 1		
LES-1027-17B	Langdon ES	1st floor inside Classroom 108	10/27/15	< 1		
LES-1027-18A	Langdon ES	1st floor inside Classroom 109	10/27/15	< 1		
LES-1027-18B	Langdon ES	1st floor inside Classroom 109	10/27/15	< 1		
LES-1027-19A	Langdon ES	1st floor inside Classroom 110	10/27/15	< 1		
LES-1027-19B	Langdon ES	1st floor inside Classroom 110	10/27/15	< 1		
LES-1027-20A	Langdon ES	1st floor hallway adjacent to Classroom 107 (high)	10/27/15	< 1		
LES-1027-20B	Langdon ES	1st floor hallway adjacent to Classroom 107 (high)	10/27/15	< 1		
LES-1027-21A	Langdon ES	1st floor hallway adjacent to Classroom 107 (low)	10/27/15	< 1		
LES-1027-21B	Langdon ES	1st floor hallway adjacent to Classroom 107 (low)	10/27/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LES-1023-1A	Langley ES	3rd floor hallway adjacent to Classroom 301	10/23/15	< 1		
LES-1023-1B	Langley ES	3rd floor hallway adjacent to Classroom 301	10/23/15	< 1		
LES-1023-2A	Langley ES	3rd floor hallway adjacent to Classroom 304	10/23/15	< 1		
LES-1023-2B	Langley ES	3rd floor hallway adjacent to Classroom 304	10/23/15	< 1		
LES-1023-3A	Langley ES	3rd floor inside Music Room	10/23/15	< 1		
LES-1023-3B	Langley ES	3rd floor inside Music Room	10/23/15	< 1		
LES-1023-4A	Langley ES	2nd floor hallway adjacent to Classroom 204	10/23/15	< 1		
LES-1023-4B	Langley ES	2nd floor hallway adjacent to Classroom 204	10/23/15	< 1		
LES-1023-5A	Langley ES	2nd floor inside Classroom 211	10/23/15	1.4		
LES-1023-5B	Langley ES	2nd floor inside Classroom 211	10/23/15	< 1		
LES-1023-6A	Langley ES	2nd floor inside Classroom 208	10/23/15	< 1		
LES-1023-6B	Langley ES	2nd floor inside Classroom 208	10/23/15	< 1		
LES-1023-7A	Langley ES	2nd floor inside Classroom 217	10/23/15	< 1		
LES-1023-7B	Langley ES	2nd floor inside Classroom 217	10/23/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
LES-1023-8A	Langley ES	2nd floor hallway adjacent to Classroom 201	10/23/15	< 1		
LES-1023-8B	Langley ES	2nd floor hallway adjacent to Classroom 201	10/23/15	< 1		
LES-1023-9A	Langley ES	1st floor hallway adjacent to Principal's Office 155	10/23/15	< 1		
LES-1023-9B	Langley ES	1st floor hallway adjacent to Principal's Office 155	10/23/15	< 1		
LES-1023-10A	Langley ES	1st floor hallway adjacent to Electric Room 104	10/23/15	< 1		
LES-1023-10B	Langley ES	1st floor hallway adjacent to Electric Room 104	10/23/15	< 1		
LES-1023-11A	Langley ES	1st floor inside Classroom 113	10/23/15	< 1		
LES-1023-11B	Langley ES	1st floor inside Classroom 113	10/23/15	< 1		
LES-1023-12A	Langley ES	1st floor inside Classroom 122	10/23/15	1.6		
LES-1023-12B	Langley ES	1st floor inside Classroom 122	10/23/15	< 1		
LES-1023-13A	Langley ES	1st floor inside Classroom 125	10/23/15	< 1		
LES-1023-13B	Langley ES	1st floor inside Classroom 125	10/23/15	< 1		
LES-1023-14A	Langley ES	1st floor inside Staff Room	10/23/15	< 1		
LES-1023-14B	Langley ES	1st floor inside Staff Room	10/23/15	< 1		
LES-1023-15A	Langley ES	1st floor inside Classroom 133	10/23/15	< 1		
LES-1023-15B	Langley ES	1st floor inside Classroom 133	10/23/15	< 1		
LES-1023-16A	Langley ES	1st floor inside Classroom 143	10/23/15	< 1		
LES-1023-16B	Langley ES	1st floor inside Classroom 143	10/23/15	< 1		
LES-1023-17A	Langley ES	1st floor inside Classroom 149	10/23/15	1.7		
LES-1023-17B	Langley ES	1st floor inside Classroom 149	10/23/15	< 1		
LES-1023-18A	Langley ES	1st floor inside Classroom 137	10/23/15	< 1		
LES-1023-18B	Langley ES	1st floor inside Classroom 137	10/23/15	< 1		
LES-1023-19A	Langley ES	Basement floor hallway adjacent to Gym B02	10/23/15	< 1		
LES-1023-19B	Langley ES	Basement floor hallway adjacent to Gym B02	10/23/15	< 1		
LES-1023-20A	Langley ES	Sub-basement floor hallway near Equipment Storage SB34	10/23/15	< 1		
LES-1023-20B	Langley ES	Sub-basement floor hallway near Equipment Storage SB34	10/23/15	< 1		
LES-1023-21A	Langley ES	Sub-basement floor hallway at entrance to Cafeteria	10/23/15	< 1		
LES-1023-21B	Langley ES	Sub-basement floor hallway at entrance to Cafeteria	10/23/15	< 1		
LES-1023-22A	Langley ES	Basement floor hallway adjacent to Gym B01	10/23/15	< 1		
LES-1023-22B	Langley ES	Basement floor hallway adjacent to Gym B01	10/23/15	< 1		
			<b>Percentage of Passed Samples</b>			<b>100.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
LB-0229-1A	Lasalle-Backus EC	3rd floor hallway across from Classroom 307	2/29/16	< 1		
LB-0229-1B	Lasalle-Backus EC	3rd floor hallway across from Classroom 307	2/29/16	< 1		
LB-0229-2A	Lasalle-Backus EC	3rd floor hallway across from Classroom 315	2/29/16	< 1		
LB-0229-2B	Lasalle-Backus EC	3rd floor hallway across from Classroom 315	2/29/16	< 1		
LB-0229-3A	Lasalle-Backus EC	2nd floor hallway across from Classroom 207	2/29/16	< 1		
LB-0229-3B	Lasalle-Backus EC	2nd floor hallway across from Classroom 207	2/29/16	< 1		
LB-0229-4A	Lasalle-Backus EC	2nd floor hallway adjacent to Classroom 208	2/29/16	< 1		
LB-0229-4B	Lasalle-Backus EC	2nd floor hallway adjacent to Classroom 208	2/29/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
LB-0229-5A	Lasalle-Backus EC	1st floor hallway adjacent to Classroom 110	2/29/16	< 1		
LB-0229-5B	Lasalle-Backus EC	1st floor hallway adjacent to Classroom 110	2/29/16	< 1		
LB-0229-6A	Lasalle-Backus EC	1st floor hallway across from Media Center 105	2/29/16	< 1		
LB-0229-6B	Lasalle-Backus EC	1st floor hallway across from Media Center 105	2/29/16	< 1		
LB-0229-7A	Lasalle-Backus EC	1st floor hallway adjacent to Principal's Office 113	2/29/16	< 1		
LB-0229-7B	Lasalle-Backus EC	1st floor hallway adjacent to Principal's Office 113	2/29/16	< 1		
LB-0229-8A	Lasalle-Backus EC	1st floor hallway adjacent to Boy's Room	2/29/16	< 1		
LB-0229-8B	Lasalle-Backus EC	1st floor hallway adjacent to Boy's Room	2/29/16	< 1		
LB-0229-9A	Lasalle-Backus EC	Ground floor hallway across from Classroom G007	2/29/16	< 1		
LB-0229-9B	Lasalle-Backus EC	Ground floor hallway across from Classroom G007	2/29/16	< 1		
LB-0229-10A	Lasalle-Backus EC	Ground floor inside Classroom G011	2/29/16	< 1		
LB-0229-10B	Lasalle-Backus EC	Ground floor inside Classroom G011	2/29/16	< 1		
LB-0229-11A	Lasalle-Backus EC	Ground floor inside Classroom G009	2/29/16	< 1		
LB-0229-11B	Lasalle-Backus EC	Ground floor inside Classroom G009	2/29/16	< 1		
LB-0229-12A	Lasalle-Backus EC	Ground floor inside Classroom G007	2/29/16	< 1		
LB-0229-12B	Lasalle-Backus EC	Ground floor inside Classroom G007	2/29/16	< 1		
LB-0229-13A	Lasalle-Backus EC	Ground floor inside Classroom G010	2/29/16	< 1		
LB-0229-13B	Lasalle-Backus EC	Ground floor inside Classroom G010	2/29/16	< 1		
LB-0229-14A	Lasalle-Backus EC	Ground floor inside Counselor's Office G012	2/29/16	3.8		
LB-0229-14B	Lasalle-Backus EC	Ground floor inside Counselor's Office G012	2/29/16	< 1		
LB-0229-15A	Lasalle-Backus EC	Ground floor inside Classroom G005	2/29/16	< 1		
LB-0229-15B	Lasalle-Backus EC	Ground floor inside Classroom G005	2/29/16	< 1		
LB-0229-16A	Lasalle-Backus EC	Ground floor inside Cafeteria	2/29/16	< 1		
LB-0229-16B	Lasalle-Backus EC	Ground floor inside Cafeteria	2/29/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LES-1230-1A	Leckie ES	1st floor across from Classroom 122 (high)	12/30/15	< 1		
LES-1230-1B	Leckie ES	1st floor across from Classroom 122 (high)	12/30/15	< 1		
LES-1230-2A	Leckie ES	1st floor across from Classroom 122 (low)	12/30/15	< 1		
LES-1230-2B	Leckie ES	1st floor across from Classroom 122 (low)	12/30/15	< 1		
LES-1230-3A	Leckie ES	1st floor inside Classroom 122	12/30/15	< 1		
LES-1230-3B	Leckie ES	1st floor inside Classroom 122	12/30/15	< 1		
LES-1230-4A	Leckie ES	1st floor inside Classroom 115	12/30/15	< 1		
LES-1230-4B	Leckie ES	1st floor inside Classroom 115	12/30/15	< 1		
LES-1230-5A	Leckie ES	1st floor inside Classroom 120	12/30/15	< 1		
LES-1230-5B	Leckie ES	1st floor inside Classroom 120	12/30/15	< 1		
LES-1230-6A	Leckie ES	1st floor inside Classroom 113	12/30/15	< 1		
LES-1230-6B	Leckie ES	1st floor inside Classroom 113	12/30/15	< 1		
LES-1230-7A	Leckie ES	1st floor inside Classroom 111	12/30/15	1.7		
LES-1230-7B	Leckie ES	1st floor inside Classroom 111	12/30/15	1.3		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
LES-1230-8A	Leckie ES	1st floor hallway adjacent to Custodian Closet 104 (high)	12/30/15		68	Filter Installed
LES-1230-8B	Leckie ES	1st floor hallway adjacent to Custodian Closet 104 (high)	12/30/15	< 1		
LES-0211-2A	Leckie ES	1st floor hallway adjacent to Custodian Closet 104 (high) (Retest)	2/11/16	1.6		
LES-0211-2B	Leckie ES	1st floor hallway adjacent to Custodian Closet 104 (high) (Retest)	2/11/16	< 1		
LES-1230-9A	Leckie ES	1st floor hallway adjacent to Custodian Closet 104 (low)	12/30/15	1.2		
LES-1230-9B	Leckie ES	1st floor hallway adjacent to Custodian Closet 104 (low)	12/30/15	1.9		
LES-1230-10A	Leckie ES	Basement floor inside Classroom 018	12/30/15	< 1		
LES-1230-10B	Leckie ES	Basement floor inside Classroom 018	12/30/15	< 1		
LES-1230-11A	Leckie ES	Basement floor inside Classroom 016	12/30/15	3.3		
LES-1230-11B	Leckie ES	Basement floor inside Classroom 016	12/30/15	< 1		
LES-1230-12A	Leckie ES	Basement floor inside Classroom 014	12/30/15	1.5		
LES-1230-12B	Leckie ES	Basement floor inside Classroom 014	12/30/15	< 1		
LES-1230-13A	Leckie ES	Basement floor inside Classroom 012	12/30/15		54	Filter Installed
LES-1230-13B	Leckie ES	Basement floor inside Classroom 012	12/30/15	1.9		
LES-0211-1A	Leckie ES	Basement floor inside Classroom 012 (Retest)	2/11/16	< 1		
LES-0211-1B	Leckie ES	Basement floor inside Classroom 012 (Retest)	2/11/16	< 1		
LES-1230-14A	Leckie ES	Basement floor hallway adjacent to Custodian Closet 008 (high)	12/30/15	< 1		
LES-1230-14B	Leckie ES	Basement floor hallway adjacent to Custodian Closet 008 (high)	12/30/15	< 1		
LES-1230-15A	Leckie ES	Basement floor hallway adjacent to Custodian Closet 008 (low)	12/30/15	3.2		
LES-1230-15B	Leckie ES	Basement floor hallway adjacent to Custodian Closet 008 (low)	12/30/15	6.7		
LES-1230-16A	Leckie ES	3rd floor hallway adjacent to Custodian Closet 303	12/30/15	< 1		
LES-1230-16B	Leckie ES	3rd floor hallway adjacent to Custodian Closet 303	12/30/15	< 1		
LES-1230-17A	Leckie ES	3rd floor hallway across from Classroom 309 Art Room	12/30/15	2.2		
LES-1230-17B	Leckie ES	3rd floor hallway across from Classroom 309 Art Room	12/30/15	< 1		
LES-1230-18A	Leckie ES	2nd floor hallway across from Music Room 212	12/30/15	< 1		
LES-1230-18B	Leckie ES	2nd floor hallway across from Music Room 212	12/30/15	< 1		
LES-1230-19A	Leckie ES	2nd floor hallway adjacent to Custodian Closet	12/30/15	< 1		
LES-1230-19B	Leckie ES	2nd floor hallway adjacent to Custodian Closet	12/30/15	< 1		
					<b>Percentage of Passed Samples</b>	<b>95.24%</b>
					<b>Percentage of Failed Samples</b>	<b>5.00%</b>
LA-0205-1A	Leckie Annex (Trailer)	1st floor hallway in trailer (high)	2/5/16	< 1		
LA-0205-1B	Leckie Annex (Trailer)	1st floor hallway in trailer (high)	2/5/16	< 1		
LA-0205-2A	Leckie Annex (Trailer)	1st floor hallway in trailer (low)	2/5/16	< 1		
LA-0205-2B	Leckie Annex (Trailer)	1st floor hallway in trailer (low)	2/5/16	< 1		
					<b>Percentage of Passed Samples</b>	<b>100.00%</b>
					<b>Percentage of Failed Samples</b>	<b>0.00%</b>
LES-0328-1A	Capitol Hill Montessori @ Logan	1st floor hallway adjacent to Classroom 109	3/28/16	< 1		
LES-0328-1B	Capitol Hill Montessori @ Logan	1st floor hallway adjacent to Classroom 109	3/28/16	< 1		
LES-0328-2A	Capitol Hill Montessori @ Logan	1st floor hallway adjacent to Classroom 101	3/28/16	< 1		
LES-0328-2B	Capitol Hill Montessori @ Logan	1st floor hallway adjacent to Classroom 101	3/28/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
LES-0328-3A	Capitol Hill Montessori @ Logan	Basement floor inside Cafeteria	3/28/16	< 1		
LES-0328-3B	Capitol Hill Montessori @ Logan	Basement floor inside Cafeteria	3/28/16	< 1		
LES-0328-4A	Capitol Hill Montessori @ Logan	1st floor hallway in Annex Building adjacent to Women's room (left, high)	3/28/16	< 1		
LES-0328-4B	Capitol Hill Montessori @ Logan	1st floor hallway in Annex Building adjacent to Women's room (left, high)	3/28/16	< 1		
LES-0328-5A	Capitol Hill Montessori @ Logan	1st floor hallway in Annex Building adjacent to Women's room (middle, low)	3/28/16	< 1		
LES-0328-5B	Capitol Hill Montessori @ Logan	1st floor hallway in Annex Building adjacent to Women's room (middle, low)	3/28/16	< 1		
LES-0328-6A	Capitol Hill Montessori @ Logan	1st floor hallway in Annex Building adjacent to Women's room (right, high)	3/28/16	< 1		
LES-0328-6B	Capitol Hill Montessori @ Logan	1st floor hallway in Annex Building adjacent to Women's room (right, high)	3/28/16	< 1		
LES-0414-03A	Capitol Hill Montessori @ Logan	2nd floor hallway adjacent to 212 Library	4/14/16	< 1		Test after device was repaired.
LES-0414-03B	Capitol Hill Montessori @ Logan	2nd floor hallway adjacent to 212 Library	4/14/16	< 1		Test after device was repaired.
LES-0414-01A	Capitol Hill Montessori @ Logan	2nd floor hallway adjacent to Classroom 202 (high)	4/14/16	< 1		Test after device was repaired.
LES-0414-01B	Capitol Hill Montessori @ Logan	2nd floor hallway adjacent to Classroom 202 (high)	4/14/16	< 1		Test after device was repaired.
LES-0414-02A	Capitol Hill Montessori @ Logan	2nd floor hallway adjacent to Classroom 202 (low)	4/14/16	< 1		Test after device was repaired.
LES-0414-02B	Capitol Hill Montessori @ Logan	2nd floor hallway adjacent to Classroom 202 (low)	4/14/16	< 1		Test after device was repaired.
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LES-0414-1A	Capitol Hill Montessori @ Logan (sinks)	2nd floor in Men's Room adjacent to 212 Library (high)	4/14/16			
LES-0414-1B	Capitol Hill Montessori @ Logan	2nd floor in Men's Room adjacent to 212 Library (high)	4/14/16			
LES-0414-2A	Capitol Hill Montessori @ Logan	2nd floor in Men's Room adjacent to 212 Library (low)	4/14/16			
LES-0414-2B	Capitol Hill Montessori @ Logan	2nd floor in Men's Room adjacent to 212 Library (low)	4/14/16			
LES-0414-3A	Capitol Hill Montessori @ Logan	2nd floor in Art Room 213 (left)	4/14/16			
LES-0414-3B	Capitol Hill Montessori @ Logan	2nd floor in Art Room 213 (left)	4/14/16			
LES-0414-4A	Capitol Hill Montessori @ Logan	2nd floor in Art Room 213 (right)	4/14/16			
LES-0414-4B	Capitol Hill Montessori @ Logan	2nd floor in Art Room 213 (right)	4/14/16			
LES-0414-5A	Capitol Hill Montessori @ Logan	2nd floor in Women's Room adjacent to 214 (left)	4/14/16			
LES-0414-5B	Capitol Hill Montessori @ Logan	2nd floor in Women's Room adjacent to 214 (left)	4/14/16			
LES-0414-6A	Capitol Hill Montessori @ Logan	2nd floor in Women's Room adjacent to 214 (right)	4/14/16			
LES-0414-6B	Capitol Hill Montessori @ Logan	2nd floor in Women's Room adjacent to 214 (right)	4/14/16			
LES-0414-7A	Capitol Hill Montessori @ Logan	2nd floor in Classroom 214	4/14/16			
LES-0414-7B	Capitol Hill Montessori @ Logan	2nd floor in Classroom 214	4/14/16			
LES-0414-8A	Capitol Hill Montessori @ Logan	2nd floor in Classroom 203	4/14/16			
LES-0414-8B	Capitol Hill Montessori @ Logan	2nd floor in Classroom 203	4/14/16			
LES-0414-9A	Capitol Hill Montessori @ Logan	2nd floor in Men's Room adjacent to 202 (left)	4/14/16			
LES-0414-9B	Capitol Hill Montessori @ Logan	2nd floor in Men's Room adjacent to 202 (left)	4/14/16			
LES-0414-10A	Capitol Hill Montessori @ Logan	2nd floor in Men's Room adjacent to 202 (right)	4/14/16			
LES-0414-10B	Capitol Hill Montessori @ Logan	2nd floor in Men's Room adjacent to 202 (right)	4/14/16			

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
LES-0414-11A	Capitol Hill Montessori @ Logan	2nd floor in Classroom 202	4/14/16			
LES-0414-11B	Capitol Hill Montessori @ Logan	2nd floor in Classroom 202	4/14/16			
LES-0414-12A	Capitol Hill Montessori @ Logan	2nd floor in Women's Room adjacent to 202 (left)	4/14/16			
LES-0414-12B	Capitol Hill Montessori @ Logan	2nd floor in Women's Room adjacent to 202 (left)	4/14/16			
LES-0414-13A	Capitol Hill Montessori @ Logan	2nd floor in Women's Room adjacent to 202 (right)	4/14/16			
LES-0414-13B	Capitol Hill Montessori @ Logan	2nd floor in Women's Room adjacent to 202 (right)	4/14/16			
LES-0414-14A	Capitol Hill Montessori @ Logan	1st floor in Nurse's Office 100	4/14/16			
LES-0414-14B	Capitol Hill Montessori @ Logan	1st floor in Nurse's Office 100	4/14/16			
LES-0414-15A	Capitol Hill Montessori @ Logan	1st floor in Nurse's Office 100 in Restroom	4/14/16			
LES-0414-15B	Capitol Hill Montessori @ Logan	1st floor in Nurse's Office 100 in Restroom	4/14/16			
LES-0414-16A	Capitol Hill Montessori @ Logan	1st floor in Women's Room adjacent to 101 (high)	4/14/16			
LES-0414-16B	Capitol Hill Montessori @ Logan	1st floor in Women's Room adjacent to 101 (high)	4/14/16			
LES-0414-17A	Capitol Hill Montessori @ Logan	1st floor in Classroom 105 (high)	4/14/16			
LES-0414-17B	Capitol Hill Montessori @ Logan	1st floor in Classroom 105 (high)	4/14/16			
LES-0414-18A	Capitol Hill Montessori @ Logan	1st floor in Classroom 105 (low)	4/14/16			
LES-0414-18B	Capitol Hill Montessori @ Logan	1st floor in Classroom 105 (low)	4/14/16			
LES-0414-19A	Capitol Hill Montessori @ Logan	1st floor in Classroom 104	4/14/16			
LES-0414-19B	Capitol Hill Montessori @ Logan	1st floor in Classroom 104	4/14/16			
LES-0414-20A	Capitol Hill Montessori @ Logan	1st floor in Boy's Room adjacent to 101 (high)	4/14/16			
LES-0414-20B	Capitol Hill Montessori @ Logan	1st floor in Boy's Room adjacent to 101 (high)	4/14/16			
LES-0414-21A	Capitol Hill Montessori @ Logan	1st floor in Boy's Room adjacent to 101 (low)	4/14/16			
LES-0414-21B	Capitol Hill Montessori @ Logan	1st floor in Boy's Room adjacent to 101 (low)	4/14/16			
LES-0414-22A	Capitol Hill Montessori @ Logan	1st floor in Classroom 101	4/14/16			
LES-0414-22B	Capitol Hill Montessori @ Logan	1st floor in Classroom 101	4/14/16			
LES-0414-23A	Capitol Hill Montessori @ Logan	1st floor in Classroom 102	4/14/16			
LES-0414-23B	Capitol Hill Montessori @ Logan	1st floor in Classroom 102	4/14/16			
LES-0414-24A	Capitol Hill Montessori @ Logan	1st floor in Classroom 103	4/14/16			
LES-0414-24B	Capitol Hill Montessori @ Logan	1st floor in Classroom 103	4/14/16			
LES-0414-25A	Capitol Hill Montessori @ Logan	1st floor in Classroom 108	4/14/16			
LES-0414-25B	Capitol Hill Montessori @ Logan	1st floor in Classroom 108	4/14/16			
LES-0414-26A	Capitol Hill Montessori @ Logan	1st floor in Classroom 108 in Restroom (high)	4/14/16			
LES-0414-26B	Capitol Hill Montessori @ Logan	1st floor in Classroom 108 in Restroom (high)	4/14/16			
LES-0414-27A	Capitol Hill Montessori @ Logan	1st floor in Classroom 108 in Restroom (low)	4/14/16			
LES-0414-27B	Capitol Hill Montessori @ Logan	1st floor in Classroom 108 in Restroom (low)	4/14/16			
LES-0414-28A	Capitol Hill Montessori @ Logan	1st floor in Classroom 109	4/14/16			
LES-0414-28B	Capitol Hill Montessori @ Logan	1st floor in Classroom 109	4/14/16			
LES-0414-29A	Capitol Hill Montessori @ Logan	1st floor in Boy's Room adjacent to 110 (high)	4/14/16			
LES-0414-29B	Capitol Hill Montessori @ Logan	1st floor in Boy's Room adjacent to 110 (high)	4/14/16			
LES-0414-30A	Capitol Hill Montessori @ Logan	1st floor in Boy's Room adjacent to 110 (low)	4/14/16			
LES-0414-30B	Capitol Hill Montessori @ Logan	1st floor in Boy's Room adjacent to 110 (low)	4/14/16			
LES-0414-31A	Capitol Hill Montessori @ Logan	1st floor in Classroom 107	4/14/16			

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
LES-0414-31B	Capitol Hill Montessori @ Logan	1st floor in Classroom 107	4/14/16			
LES-0414-32A	Capitol Hill Montessori @ Logan	1st floor in Classroom 110	4/14/16			
LES-0414-32B	Capitol Hill Montessori @ Logan	1st floor in Classroom 110	4/14/16			
LES-0414-33A	Capitol Hill Montessori @ Logan	1st floor in Girl's Room adjacent to 110 (high)	4/14/16			
LES-0414-33B	Capitol Hill Montessori @ Logan	1st floor in Girl's Room adjacent to 110 (high)	4/14/16			
LES-0414-34A	Capitol Hill Montessori @ Logan	1st floor in Girl's Room adjacent to 110 (low)	4/14/16			
LES-0414-34B	Capitol Hill Montessori @ Logan	1st floor in Girl's Room adjacent to 110 (low)	4/14/16			
LES-0414-35A	Capitol Hill Montessori @ Logan	1st floor in Classroom 111	4/14/16			
LES-0414-35B	Capitol Hill Montessori @ Logan	1st floor in Classroom 111	4/14/16			
LES-0414-36A	Capitol Hill Montessori @ Logan	1st floor in Main Office	4/14/16			
LES-0414-36B	Capitol Hill Montessori @ Logan	1st floor in Main Office	4/14/16			
LES-0414-37A	Capitol Hill Montessori @ Logan	1st floor in Main Office in Restroom	4/14/16			
LES-0414-37B	Capitol Hill Montessori @ Logan	1st floor in Main Office in Restroom	4/14/16			
LES-0414-38A	Capitol Hill Montessori @ Logan	Basement floor in Custodian's Office	4/14/16			
LES-0414-38B	Capitol Hill Montessori @ Logan	Basement floor in Custodian's Office	4/14/16			
LES-0414-39A	Capitol Hill Montessori @ Logan	Basement floor in Head Custodian's Office	4/14/16			
LES-0414-39B	Capitol Hill Montessori @ Logan	Basement floor in Head Custodian's Office	4/14/16			
LES-0414-40A	Capitol Hill Montessori @ Logan	Basement floor in Kitchen (left)	4/14/16			
LES-0414-40B	Capitol Hill Montessori @ Logan	Basement floor in Kitchen (left)	4/14/16			
LES-0414-41A	Capitol Hill Montessori @ Logan	Basement floor in Kitchen (mid)	4/14/16			
LES-0414-41B	Capitol Hill Montessori @ Logan	Basement floor in Kitchen (mid)	4/14/16			
LES-0414-42A	Capitol Hill Montessori @ Logan	Basement floor in Kitchen (right)	4/14/16			
LES-0414-42B	Capitol Hill Montessori @ Logan	Basement floor in Kitchen (right)	4/14/16			
LES-0414-43A	Capitol Hill Montessori @ Logan	Basement floor in Kitchen adjacent to Locker Area	4/14/16			
LES-0414-43B	Capitol Hill Montessori @ Logan	Basement floor in Kitchen adjacent to Locker Area	4/14/16			
LES-0414-44A	Capitol Hill Montessori @ Logan	Basement floor in Kitchen in Restroom	4/14/16			
LES-0414-44B	Capitol Hill Montessori @ Logan	Basement floor in Kitchen in Restroom	4/14/16			
LES-0414-45A	Capitol Hill Montessori @ Logan	Inside Annex building in Staff Lounge Area	4/14/16			
LES-0414-45B	Capitol Hill Montessori @ Logan	Inside Annex building in Staff Lounge Area	4/14/16			
LES-0414-46A	Capitol Hill Montessori @ Logan	Inside Annex building in Women's Restroom (left)	4/14/16			
LES-0414-46B	Capitol Hill Montessori @ Logan	Inside Annex building in Women's Restroom (left)	4/14/16			
LES-0414-47A	Capitol Hill Montessori @ Logan	Inside Annex building in Women's Restroom (mid)	4/14/16			
LES-0414-47B	Capitol Hill Montessori @ Logan	Inside Annex building in Women's Restroom (mid)	4/14/16			
LES-0414-48A	Capitol Hill Montessori @ Logan	Inside Annex building in Women's Restroom (right)	4/14/16			
LES-0414-48B	Capitol Hill Montessori @ Logan	Inside Annex building in Women's Restroom (right)	4/14/16			
LES-0414-49A	Capitol Hill Montessori @ Logan	Inside Annex building in Men's Restroom (mid)	4/14/16			
LES-0414-49B	Capitol Hill Montessori @ Logan	Inside Annex building in Men's Restroom (mid)	4/14/16			
LES-0414-50A	Capitol Hill Montessori @ Logan	Inside Annex building in Men's Restroom (right)	4/14/16			
LES-0414-50B	Capitol Hill Montessori @ Logan	Inside Annex building in Men's Restroom (right)	4/14/16			
LES-0414-51A	Capitol Hill Montessori @ Logan	Inside Annex building in Staff Restroom	4/14/16			
LES-0414-51B	Capitol Hill Montessori @ Logan	Inside Annex building in Staff Restroom	4/14/16			

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
LES-0414-52A	Capitol Hill Montessori @ Logan	Inside Annex building in Science Lab (1) (counter clockwise from west door)	4/14/16			
LES-0414-52B	Capitol Hill Montessori @ Logan	Inside Annex building in Science Lab (1)	4/14/16			
LES-0414-53A	Capitol Hill Montessori @ Logan	Inside Annex building in Science Lab (2)	4/14/16			
LES-0414-53B	Capitol Hill Montessori @ Logan	Inside Annex building in Science Lab (2)	4/14/16			
LES-0414-54A	Capitol Hill Montessori @ Logan	Inside Annex building in Science Lab (3)	4/14/16			
LES-0414-54B	Capitol Hill Montessori @ Logan	Inside Annex building in Science Lab (3)	4/14/16			
LES-0414-55A	Capitol Hill Montessori @ Logan	Inside Annex building in Science Lab (4)	4/14/16			
LES-0414-55B	Capitol Hill Montessori @ Logan	Inside Annex building in Science Lab (4)	4/14/16			
LES-0414-56A	Capitol Hill Montessori @ Logan	Inside Annex building in Science Lab (5)	4/14/16			
LES-0414-56B	Capitol Hill Montessori @ Logan	Inside Annex building in Science Lab (5)	4/14/16			
LES-0414-57A	Capitol Hill Montessori @ Logan	Outside Annex @ face of building	4/14/16			
LES-0414-57B	Capitol Hill Montessori @ Logan	Outside Annex @ face of building	4/14/16			
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LT-1106-1A	Ludlow Taylor ES	3rd floor inside Classroom 314	11/6/15	< 1		
LT-1106-1B	Ludlow Taylor ES	3rd floor inside Classroom 314	11/6/15	< 1		
LT-1106-2A	Ludlow Taylor ES	3rd floor inside Classroom 325	11/6/15	< 1		
LT-1106-2B	Ludlow Taylor ES	3rd floor inside Classroom 325	11/6/15	< 1		
LT-1106-3A	Ludlow Taylor ES	3rd floor hallway across from Classroom 323 (high)	11/6/15	< 1		
LT-1106-3B	Ludlow Taylor ES	3rd floor hallway across from Classroom 323 (high)	11/6/15	< 1		
LT-1106-4A	Ludlow Taylor ES	3rd floor hallway across from Classroom 323 (low)	11/6/15	< 1		
LT-1106-4B	Ludlow Taylor ES	3rd floor hallway across from Classroom 323 (low)	11/6/15	< 1		
LT-1106-5A	Ludlow Taylor ES	3rd floor inside Classroom 323	11/6/15	< 1		
LT-1106-5B	Ludlow Taylor ES	3rd floor inside Classroom 323	11/6/15	< 1		
LT-1106-6A	Ludlow Taylor ES	3rd floor inside Classroom 321	11/6/15	< 1		
LT-1106-6B	Ludlow Taylor ES	3rd floor inside Classroom 321	11/6/15	< 1		
LT-1106-7A	Ludlow Taylor ES	3rd floor inside Classroom 317	11/6/15	1.3		
LT-1106-7B	Ludlow Taylor ES	3rd floor inside Classroom 317	11/6/15	< 1		
LT-1106-8A	Ludlow Taylor ES	3rd floor inside Classroom 306	11/6/15	< 1		
LT-1106-8B	Ludlow Taylor ES	3rd floor inside Classroom 306	11/6/15	< 1		
LT-1106-9A	Ludlow Taylor ES	3rd floor inside Classroom 304	11/6/15	< 1		
LT-1106-9B	Ludlow Taylor ES	3rd floor inside Classroom 304	11/6/15	< 1		
LT-1106-10A	Ludlow Taylor ES	3rd floor inside Classroom 307	11/6/15	< 1		
LT-1106-10B	Ludlow Taylor ES	3rd floor inside Classroom 307	11/6/15	< 1		
LT-1106-11A	Ludlow Taylor ES	3rd floor inside Classroom 301	11/6/15	1.1		
LT-1106-11B	Ludlow Taylor ES	3rd floor inside Classroom 301	11/6/15	< 1		
LT-1106-12A	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell B (high)	11/6/15	< 1		
LT-1106-12B	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell B (high)	11/6/15	< 1		
LT-1106-13A	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell B (low)	11/6/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
LT-1106-13B	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell B (low)	11/6/15	< 1		
LT-1106-14A	Ludlow Taylor ES	2nd floor inside Classroom 216	11/6/15	< 1		
LT-1106-14B	Ludlow Taylor ES	2nd floor inside Classroom 216	11/6/15	< 1		
LT-1106-15A	Ludlow Taylor ES	2nd floor inside Classroom 223	11/6/15	< 1		
LT-1106-15B	Ludlow Taylor ES	2nd floor inside Classroom 223	11/6/15	< 1		
LT-1106-16A	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell A (high)	11/6/15	< 1		
LT-1106-16B	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell A (high)	11/6/15	< 1		
LT-1106-17A	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell A (low)	11/6/15	< 1		
LT-1106-17B	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell A (low)	11/6/15	< 1		
LT-1106-18A	Ludlow Taylor ES	2nd floor inside Classroom 217	11/6/15	< 1		
LT-1106-18B	Ludlow Taylor ES	2nd floor inside Classroom 217	11/6/15	< 1		
LT-1106-19A	Ludlow Taylor ES	2nd floor inside Classroom 212	11/6/15	< 1		
LT-1106-19B	Ludlow Taylor ES	2nd floor inside Classroom 212	11/6/15	< 1		
LT-1106-20A	Ludlow Taylor ES	2nd floor inside Teacher's Lounge 215	11/6/15	3.7		
LT-1106-20B	Ludlow Taylor ES	2nd floor inside Teacher's Lounge 215	11/6/15	< 1		
LT-1106-21A	Ludlow Taylor ES	2nd floor inside Classroom 210	11/6/15	< 1		
LT-1106-21B	Ludlow Taylor ES	2nd floor inside Classroom 210	11/6/15	< 1		
LT-1106-22A	Ludlow Taylor ES	2nd floor inside Classroom 206	11/6/15	< 1		
LT-1106-22B	Ludlow Taylor ES	2nd floor inside Classroom 206	11/6/15	< 1		
LT-1106-23A	Ludlow Taylor ES	2nd floor inside Classroom 204	11/6/15	< 1		
LT-1106-23B	Ludlow Taylor ES	2nd floor inside Classroom 204	11/6/15	< 1		
LT-1106-24A	Ludlow Taylor ES	2nd floor inside Classroom 207	11/6/15	< 1		
LT-1106-24B	Ludlow Taylor ES	2nd floor inside Classroom 207	11/6/15	< 1		
LT-1106-25A	Ludlow Taylor ES	2nd floor inside Classroom 201	11/6/15	< 1		
LT-1106-25B	Ludlow Taylor ES	2nd floor inside Classroom 201	11/6/15	< 1		
LT-1106-26A	Ludlow Taylor ES	2nd floor inside Classroom 200 (left)	11/6/15	< 1		
LT-1106-26B	Ludlow Taylor ES	2nd floor inside Classroom 200 (left)	11/6/15	< 1		
LT-1106-27A	Ludlow Taylor ES	2nd floor inside Classroom 200 (right)	11/6/15	< 1		
LT-1106-27B	Ludlow Taylor ES	2nd floor inside Classroom 200 (right)	11/6/15	< 1		
LT-1106-28A	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell B (high)	11/6/15	< 1		
LT-1106-28B	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell B (high)	11/6/15	< 1		
LT-1106-29A	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell B (low)	11/6/15	< 1		
LT-1106-29B	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell B (low)	11/6/15	< 1		
LT-1106-30A	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell B (high)	11/6/15	< 1		
LT-1106-30B	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell B (high)	11/6/15	< 1		
LT-1106-31A	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell B (low)	11/6/15	< 1		
LT-1106-31B	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell B (low)	11/6/15	< 1		
LT-1106-32A	Ludlow Taylor ES	1st floor inside Classroom 101	11/6/15	1.1		
LT-1106-32B	Ludlow Taylor ES	1st floor inside Classroom 101	11/6/15	1.1		
LT-1106-33A	Ludlow Taylor ES	1st floor inside Classroom 100	11/6/15	1.4		
LT-1106-33B	Ludlow Taylor ES	1st floor inside Classroom 100	11/6/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
LT-1106-34A	Ludlow Taylor ES	1st floor inside Classroom 105	11/6/15	< 1		
LT-1106-34B	Ludlow Taylor ES	1st floor inside Classroom 105	11/6/15	< 1		
LT-1106-35A	Ludlow Taylor ES	1st floor inside Classroom 102	11/6/15	< 1		
LT-1106-35B	Ludlow Taylor ES	1st floor inside Classroom 102	11/6/15	< 1		
LT-1106-36A	Ludlow Taylor ES	1st floor inside Classroom 104	11/6/15	< 1		
LT-1106-36B	Ludlow Taylor ES	1st floor inside Classroom 104	11/6/15	< 1		
LT-1106-37A	Ludlow Taylor ES	1st floor inside Classroom 106	11/6/15	< 1		
LT-1106-37B	Ludlow Taylor ES	1st floor inside Classroom 106	11/6/15	< 1		
LT-1106-38A	Ludlow Taylor ES	1st floor inside Classroom 108 in restroom	11/6/15	< 1		
LT-1106-38B	Ludlow Taylor ES	1st floor inside Classroom 108 in restroom	11/6/15	< 1		
LT-1106-39A	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell A (high)	11/6/15	< 1		
LT-1106-39B	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell A (high)	11/6/15	< 1		
LT-1106-40A	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell A (low)	11/6/15	< 1		
LT-1106-40B	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell A (low)	11/6/15	< 1		
LT-1106-41A	Ludlow Taylor ES	1st floor inside Parent Center	11/6/15	< 1		
LT-1106-41B	Ludlow Taylor ES	1st floor inside Parent Center	11/6/15	< 1		
LT-1106-42A	Ludlow Taylor ES	1st floor inside Health Suite 112	11/6/15	< 1		
LT-1106-42B	Ludlow Taylor ES	1st floor inside Health Suite 112	11/6/15	< 1		
LT-1106-43A	Ludlow Taylor ES	1st floor hallway near Janitor's Closet 120	11/6/15	< 1		
LT-1106-43B	Ludlow Taylor ES	1st floor hallway near Janitor's Closet 120	11/6/15	< 1		
LT-1106-44A	Ludlow Taylor ES	1st floor inside Multi-Purpose Room	11/6/15	1.7		
LT-1106-44B	Ludlow Taylor ES	1st floor inside Multi-Purpose Room	11/6/15	2.2		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LM-0113-1A	Luke C. Moore HS	2nd floor hallway adjacent to Men's Room	1/13/16	< 1		
LM-0113-1B	Luke C. Moore HS	2nd floor hallway adjacent to Men's Room	1/13/16	< 1		
LM-0113-2A	Luke C. Moore HS	2nd floor hallway adjacent to Women's Room	1/13/16	< 1		
LM-0113-2B	Luke C. Moore HS	2nd floor hallway adjacent to Women's Room	1/13/16	< 1		
LM-0113-3A	Luke C. Moore HS	1st floor hallway adjacent to Women's Room (high)	1/13/16	< 1		
LM-0113-3B	Luke C. Moore HS	1st floor hallway adjacent to Women's Room (high)	1/13/16	< 1		
LM-0113-4A	Luke C. Moore HS	1st floor hallway adjacent to Women's Room (low)	1/13/16	< 1		
LM-0113-4B	Luke C. Moore HS	1st floor hallway adjacent to Women's Room (low)	1/13/16	< 1		
LM-0113-5A	Luke C. Moore HS	Basement floor hallway near elevator (high)	1/13/16	< 1		
LM-0113-5B	Luke C. Moore HS	Basement floor hallway near elevator (high)	1/13/16	< 1		
LM-0113-6A	Luke C. Moore HS	Basement floor hallway near elevator (low)	1/13/16	< 1		
LM-0113-6B	Luke C. Moore HS	Basement floor hallway near elevator (low)	1/13/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MLK-1203-1A	M.L. King ES	3rd floor hallway adjacent to Girl's Room (high)	12/3/15	< 1		
MLK-1203-1B	M.L. King ES	3rd floor hallway adjacent to Girl's Room (high)	12/3/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
MLK-1203-2A	M.L. King ES	3rd floor hallway adjacent to Girl's Room (low)	12/3/15	< 1		
MLK-1203-2B	M.L. King ES	3rd floor hallway adjacent to Girl's Room (low)	12/3/15	< 1		
MLK-1203-3A	M.L. King ES	2nd floor hallway adjacent to Boy's Room (high)	12/3/15	< 1		
MLK-1203-3B	M.L. King ES	2nd floor hallway adjacent to Boy's Room (high)	12/3/15	< 1		
MLK-1203-4A	M.L. King ES	2nd floor hallway adjacent to Boy's Room (low)	12/3/15	< 1		
MLK-1203-4B	M.L. King ES	2nd floor hallway adjacent to Boy's Room (low)	12/3/15	< 1		
MLK-1203-5A	M.L. King ES	2nd floor hallway adjacent to Girl's Room (high)	12/3/15	< 1		
MLK-1203-5B	M.L. King ES	2nd floor hallway adjacent to Girl's Room (high)	12/3/15	< 1		
MLK-1203-6A	M.L. King ES	2nd floor hallway adjacent to Girl's Room (low)	12/3/15	< 1		
MLK-1203-6B	M.L. King ES	2nd floor hallway adjacent to Girl's Room (low)	12/3/15	< 1		
MLK-1203-7A	M.L. King ES	1st floor hallway adjacent to Boy's Room (high)	12/3/15	< 1		
MLK-1203-7B	M.L. King ES	1st floor hallway adjacent to Boy's Room (high)	12/3/15	< 1		
MLK-1203-8A	M.L. King ES	1st floor hallway adjacent to Boy's Room (low)	12/3/15	< 1		
MLK-1203-8B	M.L. King ES	1st floor hallway adjacent to Boy's Room (low)	12/3/15	< 1		
MLK-1203-9A	M.L. King ES	1st floor hallway adjacent to Girl's Room (high)	12/3/15	< 1		
MLK-1203-9B	M.L. King ES	1st floor hallway adjacent to Girl's Room (high)	12/3/15	< 1		
MLK-1203-10A	M.L. King ES	1st floor hallway adjacent to Girl's Room (low)	12/3/15	< 1		
MLK-1203-10B	M.L. King ES	1st floor hallway adjacent to Girl's Room (low)	12/3/15	< 1		
MLK-1203-11A	M.L. King ES	1st floor inside Multi-Purpose Room	12/3/15	< 1		
MLK-1203-11B	M.L. King ES	1st floor inside Multi-Purpose Room	12/3/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MJH-0216-1A	Roosevelt SHS @ MacFarland JHS	3rd floor hallway adjacent to Classroom 300 (now 306)	2/16/16	< 1		
MJH-0216-1B	Roosevelt SHS @ MacFarland JHS	3rd floor hallway adjacent to Classroom 300 (now 306)	2/16/16	< 1		
MJH-0216-2A	Roosevelt SHS @ MacFarland JHS	3rd floor hallway adjacent to Classroom 302 (now 303)	2/16/16	< 1		
MJH-0216-2B	Roosevelt SHS @ MacFarland JHS	3rd floor hallway adjacent to Classroom 302 (now 303)	2/16/16	< 1		
MJH-0216-3A	Roosevelt SHS @ MacFarland JHS	2nd floor hallway adjacent to Classroom 203 (now 213)	2/16/16	< 1		
MJH-0216-3B	Roosevelt SHS @ MacFarland JHS	2nd floor hallway adjacent to Classroom 203 (now 213)	2/16/16	< 1		
MJH-0216-4A	Roosevelt SHS @ MacFarland JHS	2nd floor hallway adjacent to Classroom 252 (now 204)	2/16/16	< 1		
MJH-0216-4B	Roosevelt SHS @ MacFarland JHS	2nd floor hallway adjacent to Classroom 252 (now 204)	2/16/16	< 1		
MJH-0216-5A	Roosevelt SHS @ MacFarland JHS	1st floor hallway adjacent to Classroom 152	2/16/16	< 1		
MJH-0216-5B	Roosevelt SHS @ MacFarland JHS	1st floor hallway adjacent to Classroom 152	2/16/16	< 1		
MJH-0216-6A	Roosevelt SHS @ MacFarland JHS	1st floor hallway adjacent to Supply Closet	2/16/16	< 1		
MJH-0216-6B	Roosevelt SHS @ MacFarland JHS	1st floor hallway adjacent to Supply Closet	2/16/16	< 1		
MJH-0216-7A	Roosevelt SHS @ MacFarland JHS	Basement floor inside Cafeteria	2/16/16	< 1		
MJH-0216-7B	Roosevelt SHS @ MacFarland JHS	Basement floor inside Cafeteria	2/16/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
XES-0107-1A	Malcolm X ES @ Green	3rd floor hallway adjacent to Classroom 315	1/7/16	< 1		
XES-0107-1B	Malcolm X ES @ Green	3rd floor hallway adjacent to Classroom 315	1/7/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
XES-0107-2A	Malcolm X ES @ Green	3rd floor hallway adjacent to Classroom 308	1/7/16	< 1		
XES-0107-2B	Malcolm X ES @ Green	3rd floor hallway adjacent to Classroom 308	1/7/16	< 1		
XES-0107-3A	Malcolm X ES @ Green	2nd floor hallway adjacent to Classroom 208	1/7/16	< 1		
XES-0107-3B	Malcolm X ES @ Green	2nd floor hallway adjacent to Classroom 208	1/7/16	< 1		
XES-0107-4A	Malcolm X ES @ Green	2nd floor hallway across from Classroom 202	1/7/16	< 1		
XES-0107-4B	Malcolm X ES @ Green	2nd floor hallway across from Classroom 202	1/7/16	< 1		
XES-0107-5A	Malcolm X ES @ Green	1st floor hallway adjacent to Classroom 109	1/7/16	< 1		
XES-0107-5B	Malcolm X ES @ Green	1st floor hallway adjacent to Classroom 109	1/7/16	< 1		
XES-0107-6A	Malcolm X ES @ Green	1st floor hallway across from Health Suite 104	1/7/16	< 1		
XES-0107-6B	Malcolm X ES @ Green	1st floor hallway across from Health Suite 104	1/7/16	< 1		
XES-0107-7A	Malcolm X ES @ Green	1st floor inside Multi-Purpose Room	1/7/16	< 1		
XES-0107-7B	Malcolm X ES @ Green	1st floor inside Multi-Purpose Room	1/7/16	< 1		
XES-0107-8A	Malcolm X ES @ Green	1st floor hallway adjacent to Classroom 125	1/7/16	< 1		
XES-0107-8B	Malcolm X ES @ Green	1st floor hallway adjacent to Classroom 125	1/7/16	< 1		
XES-0107-9A	Malcolm X ES @ Green	1st floor inside Classroom 131	1/7/16	< 1		
XES-0107-9B	Malcolm X ES @ Green	1st floor inside Classroom 131	1/7/16	< 1		
XES-0107-10A	Malcolm X ES @ Green	1st floor inside Classroom 130	1/7/16	< 1		
XES-0107-10B	Malcolm X ES @ Green	1st floor inside Classroom 130	1/7/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MES-0408-1A	Mann ES	3rd floor hallway adjacent to Elevator Machine Room 317	4/8/16	< 1		
MES-0408-1B	Mann ES	3rd floor hallway adjacent to Elevator Machine Room 317	4/8/16	< 1		
MES-0408-2A	Mann ES	3rd floor hallway adjacent to Multi-Purpose Lab 302	4/8/16	< 1		
MES-0408-2B	Mann ES	3rd floor hallway adjacent to Multi-Purpose Lab 302	4/8/16	< 1		
MES-0408-3A	Mann ES	2nd floor hallway near Instructional Coach Office 216	4/8/16	< 1		
MES-0408-3B	Mann ES	2nd floor hallway near Instructional Coach Office 216	4/8/16	< 1		
MES-0408-4A	Mann ES	2nd floor hallway near elevator	4/8/16	< 1		
MES-0408-4B	Mann ES	2nd floor hallway near elevator	4/8/16	< 1		
MES-0408-5A	Mann ES	2nd floor hallway adjacent to Classroom 229	4/8/16	< 1		
MES-0408-5B	Mann ES	2nd floor hallway adjacent to Classroom 229	4/8/16	< 1		
MES-0408-6A	Mann ES	2nd floor hallway adjacent to Classroom 235	4/8/16	< 1		
MES-0408-6B	Mann ES	2nd floor hallway adjacent to Classroom 235	4/8/16	< 1		
MES-0408-7A	Mann ES	1st floor inside Classroom 146	4/8/16	< 1		
MES-0408-7B	Mann ES	1st floor inside Classroom 146	4/8/16	< 1		
MES-0408-8A	Mann ES	1st floor inside Classroom 150	4/8/16	< 1		
MES-0408-8B	Mann ES	1st floor inside Classroom 150	4/8/16	< 1		
MES-0408-9A	Mann ES	1st floor hallway adjacent to Classroom 150	4/8/16	< 1		
MES-0408-9B	Mann ES	1st floor hallway adjacent to Classroom 150	4/8/16	< 1		
MES-0408-10A	Mann ES	1st floor inside Classroom 154	4/8/16	< 1		
MES-0408-10B	Mann ES	1st floor inside Classroom 154	4/8/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
MES-0408-11A	Mann ES	1st floor inside Classroom 142	4/8/16	< 1		
MES-0408-11B	Mann ES	1st floor inside Classroom 142	4/8/16	< 1		
MES-0408-12A	Mann ES	1st floor hallway across from Classroom 138	4/8/16	< 1		
MES-0408-12B	Mann ES	1st floor hallway across from Classroom 138	4/8/16	< 1		
MES-0408-13A	Mann ES	1st floor inside Classroom 138	4/8/16	< 1		
MES-0408-13B	Mann ES	1st floor inside Classroom 138	4/8/16	< 1		
MES-0408-14A	Mann ES	1st floor hallway near Principal's Office 134	4/8/16	< 1		
MES-0408-14B	Mann ES	1st floor hallway near Principal's Office 134	4/8/16	< 1		
MES-0408-15A	Mann ES	1st floor inside Multi-Purpose Room	4/8/16	< 1		
MES-0408-15B	Mann ES	1st floor inside Multi-Purpose Room	4/8/16	< 1		
					<b>Percentage of Passed Samples</b>	<b>100.00%</b>
					<b>Percentage of Failed Samples</b>	<b>0.00%</b>
MR-0128-1A	Marie Reed ES	1st floor adjacent to Boy's Room	1/28/16	< 1		
MR-0128-1B	Marie Reed ES	1st floor adjacent to Boy's Room	1/28/16	< 1		
MR-0128-2A	Marie Reed ES	1st floor adjacent to Girl's Room	1/28/16	< 1		
MR-0128-2B	Marie Reed ES	1st floor adjacent to Girl's Room	1/28/16	< 1		
MR-0128-3A	Marie Reed ES	1st floor inside Main Office adjacent to Principal's Office	1/28/16	4.5		
MR-0128-3B	Marie Reed ES	1st floor inside Main Office adjacent to Principal's Office	1/28/16		15	Device has been turned off. Unit to be replaced during upcoming summer renovation.
MR-0128-4A	Marie Reed ES	1st floor inside small Cafeteria	1/28/16	2.7		
MR-0128-4B	Marie Reed ES	1st floor inside small Cafeteria	1/28/16	1.7		
MR-0128-5A	Marie Reed ES	1st floor adjacent to Stair 8	1/28/16	1.5		
MR-0128-5B	Marie Reed ES	1st floor adjacent to Stair 8	1/28/16	1.3		
MR-0128-6A	Marie Reed ES	1st floor adjacent to Stair 6	1/28/16	< 1		
MR-0128-6B	Marie Reed ES	1st floor adjacent to Stair 6	1/28/16	< 1		
MR-0128-7A	Marie Reed ES	1st floor adjacent to Stair 7	1/28/16	< 1		
MR-0128-7B	Marie Reed ES	1st floor adjacent to Stair 7	1/28/16	< 1		
MR-0128-8A	Marie Reed ES	2nd floor adjacent to Stair 8	1/28/16	1.5		
MR-0128-8B	Marie Reed ES	2nd floor adjacent to Stair 8	1/28/16	2.4		
MR-0128-9A	Marie Reed ES	2nd floor adjacent to Stair 7	1/28/16	< 1		
MR-0128-9B	Marie Reed ES	2nd floor adjacent to Stair 7	1/28/16	< 1		
MR-0128-10A	Marie Reed ES	2nd floor adjacent to Stair 6	1/28/16	< 1		
MR-0128-10B	Marie Reed ES	2nd floor adjacent to Stair 6	1/28/16	< 1		
MR-0128-11A	Marie Reed ES	2nd floor adjacent to Stair 5	1/28/16	6.2		
MR-0128-11B	Marie Reed ES	2nd floor adjacent to Stair 5	1/28/16		15	Device has been turned off. Filter installation pending.
MR-0128-12A	Marie Reed ES	2nd floor adjacent to Stair 4	1/28/16	< 1		
MR-0128-12B	Marie Reed ES	2nd floor adjacent to Stair 4	1/28/16	< 1		
MR-0128-13A	Marie Reed ES	2nd floor adjacent to Stair 3	1/28/16	1.2		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
MR-0128-13B	Marie Reed ES	2nd floor adjacent to Stair 3	1/28/16	< 1		
MR-0128-14A	Marie Reed ES	2nd floor adjacent to Stair 2	1/28/16	< 1		
MR-0128-14B	Marie Reed ES	2nd floor adjacent to Stair 2	1/28/16	< 1		
MR-0128-15A	Marie Reed ES	2nd floor adjacent to Stair 1	1/28/16	1		
MR-0128-15B	Marie Reed ES	2nd floor adjacent to Stair 1	1/28/16	1.1		
MR-0128-16A	Marie Reed ES	Basement floor adjacent to Boy's Room	1/28/16	1.2		
MR-0128-16B	Marie Reed ES	Basement floor adjacent to Boy's Room	1/28/16	1.7		
MR-0128-17A	Marie Reed ES	Basement floor adjacent to Girl's Room	1/28/16	< 1		
MR-0128-17B	Marie Reed ES	Basement floor adjacent to Girl's Room	1/28/16	< 1		
MR-0128-18A	Marie Reed ES	Basement floor inside Gym	1/28/16	< 1		
MR-0128-18B	Marie Reed ES	Basement floor inside Gym	1/28/16	< 1		
MR-0128-19A	Marie Reed ES	Basement floor inside Auditorium	1/28/16	2.8		
MR-0128-19B	Marie Reed ES	Basement floor inside Auditorium	1/28/16	3.1		
MR-0128-20A	Marie Reed ES	Inside Pool Area	1/28/16	< 1		
MR-0128-20B	Marie Reed ES	Inside Pool Area	1/28/16	< 1		
MR-0128-21A	Marie Reed ES	Inside Pool Area in Women's Locker Room	1/28/16	< 1		
MR-0128-21B	Marie Reed ES	Inside Pool Area in Women's Locker Room	1/28/16	< 1		
MR-0128-22A	Marie Reed ES	Inside Pool Area in Men's Locker Room	1/28/16	8.4		
MR-0128-22B	Marie Reed ES	Inside Pool Area in Men's Locker Room	1/28/16	5.3		
MR-0128-23A	Marie Reed ES	Inside Pool Area @ entrance to Men's Room	1/28/16	2.6		
MR-0128-23B	Marie Reed ES	Inside Pool Area @ entrance to Men's Room	1/28/16	2.8		
						<b>95.65%</b>
<b>Percentage of Failed Samples</b>						<b>4.35%</b>
UPO-0211-1A	Marie Reed ES (UPO Room)	1st floor in UPO Room	2/11/16	4.7		
UPO-0211-1B	Marie Reed ES (UPO Room)	1st floor in UPO Room	2/11/16	6.8		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MES-1014-1A	Maury ES	2nd floor hallway adjacent to Book Storage E213	10/14/15	< 1		
MES-1014-1B	Maury ES	2nd floor hallway adjacent to Book Storage E213	10/14/15	< 1		
MES-1014-2A	Maury ES	2nd floor inside Classroom E230	10/14/15	< 1		
MES-1014-2B	Maury ES	2nd floor inside Classroom E230	10/14/15	< 1		
MES-1014-3A	Maury ES	2nd floor inside Classroom E240	10/14/15	< 1		
MES-1014-3B	Maury ES	2nd floor inside Classroom E240	10/14/15	< 1		
MES-1014-4A	Maury ES	2nd floor in Stairwell ST4	10/14/15	< 1		
MES-1014-4B	Maury ES	2nd floor in Stairwell ST4	10/14/15	< 1		
MES-1014-5A	Maury ES	1st floor in Stairwell ST4	10/14/15	< 1		
MES-1014-5B	Maury ES	1st floor in Stairwell ST4	10/14/15	< 1		
MES-1014-6A	Maury ES	1st floor inside Classroom E140	10/14/15	< 1		
MES-1014-6B	Maury ES	1st floor inside Classroom E140	10/14/15	< 1		
MES-1014-7A	Maury ES	1st floor inside Classroom E135	10/14/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
MES-1014-7B	Maury ES	1st floor inside Classroom E135	10/14/15	< 1		
MES-1014-8A	Maury ES	1st floor inside Classroom E125	10/14/15	< 1		
MES-1014-8B	Maury ES	1st floor inside Classroom E125	10/14/15	< 1		
MES-1014-9A	Maury ES	1st floor hallway adjacent to Boy's Room E121	10/14/15	< 1		
MES-1014-9B	Maury ES	1st floor hallway adjacent to Boy's Room E121	10/14/15	< 1		
MES-1014-10A	Maury ES	1st floor inside Multi-Purpose Room E110	10/14/15	< 1		
MES-1014-10B	Maury ES	1st floor inside Multi-Purpose Room E110	10/14/15	< 1		
MES-1014-11A	Maury ES	1st floor hallway adjacent to Storage Room W022 (low)	10/14/15	< 1		
MES-1014-11B	Maury ES	1st floor hallway adjacent to Storage Room W022 (low)	10/14/15	< 1		
MES-1014-12A	Maury ES	Basement floor inside Classroom W030	10/14/15	< 1		
MES-1014-12B	Maury ES	Basement floor inside Classroom W030	10/14/15	< 1		
MES-1014-13A	Maury ES	Basement floor inside Classroom W010	10/14/15	< 1		
MES-1014-13B	Maury ES	Basement floor inside Classroom W010	10/14/15	< 1		
				<b>Percentage of Passed Samples</b>		<b>100.00%</b>
				<b>Percentage of Failed Samples</b>		<b>0.00%</b>
MT-1022-1A	McKinley Tech HS	3rd floor in entranceway to Girl's Room	10/22/15	< 1		
MT-1022-1B	McKinley Tech HS	3rd floor in entranceway to Girl's Room	10/22/15	< 1		
MT-1022-2A	McKinley Tech HS	3rd floor in entranceway to Boy's Room	10/22/15	< 1		
MT-1022-2B	McKinley Tech HS	3rd floor in entranceway to Boy's Room	10/22/15	< 1		
MT-1024-3A	McKinley Tech HS	2nd floor in entranceway to Women's Room	10/22/15	< 1		
MT-1022-3B	McKinley Tech HS	2nd floor in entranceway to Women's Room	10/22/15	< 1		
MT-1022-4A	McKinley Tech HS	2nd floor in entranceway to Men's Room	10/22/15	< 1		
MT-1022-4B	McKinley Tech HS	2nd floor in entranceway to Men's Room	10/22/15	< 1		
MT-1022-5A	McKinley Tech HS	1st floor in entranceway to Women's Room	10/22/15	< 1		
MT-1022-5B	McKinley Tech HS	1st floor in entranceway to Women's Room	10/22/15	< 1		
MT-1022-6A	McKinley Tech HS	1st floor in entranceway to Men's Room	10/22/15	< 1		
MT-1022-6B	McKinley Tech HS	1st floor in entranceway to Men's Room	10/22/15	< 1		
MT-1022-7A	McKinley Tech HS	2nd floor (G-wing) inside Gym-top tier (low)	10/22/15	< 1		
MT-1022-7B	McKinley Tech HS	2nd floor (G-wing) inside Gym-top tier (low)	10/22/15	< 1		
MT-1022-8A	McKinley Tech HS	1st floor (G-wing) inside Gym-bottom tier (high)	10/22/15	< 1		
MT-1022-8B	McKinley Tech HS	1st floor (G-wing) inside Gym-bottom tier (high)	10/22/15	< 1		
MT-1022-9A	McKinley Tech HS	1st floor (G-wing) inside Gym-bottom tier (low)	10/22/15	< 1		
MT-1022-9B	McKinley Tech HS	1st floor (G-wing) inside Gym-bottom tier (low)	10/22/15	< 1		
MT-1022-10A	McKinley Tech HS	1st floor (G-wing) outside Gym across from Electric Closet G103 (high)	10/22/15	< 1		
MT-1022-10B	McKinley Tech HS	1st floor (G-wing) outside Gym across from Electric Closet G103 (high)	10/22/15	< 1		
MT-1022-11A	McKinley Tech HS	1st floor (G-wing) outside Gym across from Electric Closet G103 (low)	10/22/15	< 1		
MT-1022-11B	McKinley Tech HS	1st floor (G-wing) outside Gym across from Electric Closet G103 (low)	10/22/15	< 1		
				<b>Percentage of Passed Samples</b>		<b>100.00%</b>
				<b>Percentage of Failed Samples</b>		<b>0.00%</b>
MMS-1021-1A	McKinley MS	3rd floor hallway adjacent to Room 302 (high)	10/21/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
MMS-1021-1B	McKinley MS	3rd floor hallway adjacent to Room 302 (high)	10/21/15	< 1		
MMS-1021-2A	McKinley MS	3rd floor hallway adjacent to Room 302 (low)	10/21/15	< 1		
MMS-1021-2B	McKinley MS	3rd floor hallway adjacent to Room 302 (low)	10/21/15	< 1		
MMS-1021-3A	McKinley MS	2nd floor hallway adjacent to Room 202 (high)	10/21/15	< 1		
MMS-1021-3B	McKinley MS	2nd floor hallway adjacent to Room 202 (high)	10/21/15	< 1		
MMS-1021-4A	McKinley MS	2nd floor hallway adjacent to Room 202 (low)	10/21/15	< 1		
MMS-1021-4B	McKinley MS	2nd floor hallway adjacent to Room 202 (low)	10/21/15	< 1		
MMS-1021-5A	McKinley MS	1st floor hallway across from Room 115F (high)	10/21/15	< 1		
MMS-1021-5B	McKinley MS	1st floor hallway across from Room 115F (high)	10/21/15	< 1		
MMS-1021-6A	McKinley MS	1st floor hallway across from Room 115F (low)	10/21/15	< 1		
MMS-1021-6B	McKinley MS	1st floor hallway across from Room 115F (low)	10/21/15	< 1		
MMS-1021-7A	McKinley MS	1st floor inside Multi-Purpose Room adjacent to 114B (high)	10/21/15	< 1		
MMS-1021-7B	McKinley MS	1st floor inside Multi-Purpose Room adjacent to 114B (high)	10/21/15	< 1		
MMS-1021-8A	McKinley MS	1st floor inside Multi-Purpose Room adjacent to 114B (low)	10/21/15	< 1		
MMS-1021-8B	McKinley MS	1st floor inside Multi-Purpose Room adjacent to 114B (low)	10/21/15	< 1		
MMS-1021-9A	McKinley MS	1st floor inside Multi-Purpose Room adjacent to 114F (high)	10/21/15	< 1		
MMS-1021-9B	McKinley MS	1st floor inside Multi-Purpose Room adjacent to 114F (high)	10/21/15	< 1		
MMS-1021-10A	McKinley MS	1st floor inside Multi-Purpose Room adjacent to 114F (low)	10/21/15	< 1		
MMS-1021-10B	McKinley MS	1st floor inside Multi-Purpose Room adjacent to 114F (low)	10/21/15	< 1		
						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
	Duke Ellington @ Meyer					
	Duke Ellington @ Meyer					
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MES-1028-1A	Miner ES	2nd floor hallway across from Room 211 (high)	10/28/15	< 1		
MES-1028-1B	Miner ES	2nd floor hallway across from Room 211 (high)	10/28/15	< 1		
MES-1028-2A	Miner ES	2nd floor hallway across from Room 209 (low)	10/28/15	< 1		
MES-1028-2B	Miner ES	2nd floor hallway across from Room 209 (low)	10/28/15	< 1		
MES-1028-3A	Miner ES	2nd floor hallway across from Room 253 (high)	10/28/15	< 1		
MES-1028-3B	Miner ES	2nd floor hallway across from Room 253 (high)	10/28/15	< 1		
MES-1-28-4A	Miner ES	2nd floor hallway across from Room 253 (low)	10/28/15	< 1		
MES-1028-4B	Miner ES	2nd floor hallway across from Room 253 (low)	10/28/15	< 1		
MES-1028-5A	Miner ES	2nd floor inside Classroom 253	10/28/15	< 1		
MES-1028-5B	Miner ES	2nd floor inside Classroom 253	10/28/15	< 1		
MES-1028-6A	Miner ES	2nd floor hallway adjacent to Room 228 Planning, in open area	10/28/15	< 1		
MES-1028-6B	Miner ES	2nd floor hallway adjacent to Room 228 Planning, in open area	10/28/15	< 1		
MES-1028-7A	Miner ES	2nd floor inside Classroom 251	10/28/15	< 1		
MES-1028-7B	Miner ES	2nd floor inside Classroom 251	10/28/15	< 1		
MES-1028-8A	Miner ES	2nd floor inside Classroom 249	10/28/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
MES-1028-8B	Miner ES	2nd floor inside Classroom 249	10/28/15	< 1		
MES-1028-9A	Miner ES	2nd floor inside Classroom 243	10/28/15	< 1		
MES-1028-9B	Miner ES	2nd floor inside Classroom 243	10/28/15	< 1		
MES-1028-10A	Miner ES	2nd floor inside Classroom 241	10/28/15	< 1		
MES-1028-10B	Miner ES	2nd floor inside Classroom 241	10/28/15	< 1		
MES-1028-11A	Miner ES	2nd floor inside Classroom 233	10/28/15	< 1		
MES-1028-11B	Miner ES	2nd floor inside Classroom 233	10/28/15	< 1		
MES-1028-12A	Miner ES	2nd floor inside Classroom 231	10/28/15	< 1		
MES-1028-12B	Miner ES	2nd floor inside Classroom 231	10/28/15	< 1		
MES-1028-13A	Miner ES	2nd floor inside Classroom 227	10/28/15	< 1		
MES-1028-13B	Miner ES	2nd floor inside Classroom 227	10/28/15	< 1		
MES-1028-14A	Miner ES	2nd floor inside Classroom 225	10/28/15	< 1		
MES-1028-14B	Miner ES	2nd floor inside Classroom 225	10/28/15	< 1		
MES-1028-15A	Miner ES	2nd floor inside Classroom 213	10/28/15	< 1		
MES-1028-15B	Miner ES	2nd floor inside Classroom 213	10/28/15	< 1		
MES-1028-16A	Miner ES	2nd floor inside Classroom 215	10/28/15	< 1		
MES-1028-16B	Miner ES	2nd floor inside Classroom 215	10/28/15	< 1		
MES-1028-17A	Miner ES	2nd floor inside Classroom 219	10/28/15	< 1		
MES-1028-17B	Miner ES	2nd floor inside Classroom 219	10/28/15	< 1		
MES-1028-18A	Miner ES	2nd floor inside Classroom 217	10/28/15	< 1		
MES-1028-18B	Miner ES	2nd floor inside Classroom 217	10/28/15	< 1		
MES-1028-19A	Miner ES	2nd floor inside Classroom 211	10/28/15	< 1		
MES-1028-19B	Miner ES	2nd floor inside Classroom 211	10/28/15	< 1		
MES-1028-20A	Miner ES	2nd floor inside Classroom 209	10/28/15	< 1		
MES-1028-20B	Miner ES	2nd floor inside Classroom 209	10/28/15	< 1		
MES-1028-21A	Miner ES	1st floor inside Classroom 101	10/28/15	< 1		
MES-1028-21B	Miner ES	1st floor inside Classroom 101	10/28/15	< 1		
MES-1028-22A	Miner ES	1st floor inside Classroom 103	10/28/15	< 1		
MES-1028-22B	Miner ES	1st floor inside Classroom 103	10/28/15	< 1		
MES-1028-23A	Miner ES	1st floor hallway adjacent to Room 112 Kitchen/Laundry, in open area	10/28/15	< 1		
MES-1028-23B	Miner ES	1st floor hallway adjacent to Room 112 Kitchen/Laundry, in open area	10/28/15	< 1		
MES-1028-24A	Miner ES	1st floor inside Classroom 105	10/28/15	< 1		
MES-1028-24B	Miner ES	1st floor inside Classroom 105	10/28/15	< 1		
MES-1028-25A	Miner ES	1st floor inside Classroom 107	10/28/15	< 1		
MES-1028-25B	Miner ES	1st floor inside Classroom 107	10/28/15	< 1		
MES-1028-26A	Miner ES	1st floor inside Classroom 109	10/28/15	< 1		
MES-1028-26B	Miner ES	1st floor inside Classroom 109	10/28/15	< 1		
MES-1028-27A	Miner ES	1st floor inside Classroom 111	10/28/15	< 1		
MES-1028-27B	Miner ES	1st floor inside Classroom 111	10/28/15	< 1		
MES-1028-28A	Miner ES	1st floor inside Classroom 115	10/28/15	< 1		
MES-1028-28B	Miner ES	1st floor inside Classroom 115	10/28/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
MES-1028-29A	Miner ES	1st floor inside Classroom 117	10/28/15	< 1		
MES-1028-29B	Miner ES	1st floor inside Classroom 117	10/28/15	< 1		
MES-1028-30A	Miner ES	1st floor inside Classroom 119	10/28/15	< 1		
MES-1028-30B	Miner ES	1st floor inside Classroom 119	10/28/15	< 1		
MES-1028-31A	Miner ES	1st floor inside Classroom 123	10/28/15	< 1		
MES-1028-31B	Miner ES	1st floor inside Classroom 123	10/28/15	< 1		
MES-1028-32A	Miner ES	1st floor inside Classroom 127	10/28/15	< 1		
MES-1028-32B	Miner ES	1st floor inside Classroom 127	10/28/15	< 1		
MES-1028-33A	Miner ES	1st floor inside Classroom 129	10/28/15	< 1		
MES-1028-33B	Miner ES	1st floor inside Classroom 129	10/28/15	< 1		
MES-1028-34A	Miner ES	1st floor inside Classroom 133	10/28/15	3.6		
MES-1028-34B	Miner ES	1st floor inside Classroom 133	10/28/15	< 1		
MES-1028-35A	Miner ES	1st floor inside Classroom 135	10/28/15	< 1		
MES-1028-35B	Miner ES	1st floor inside Classroom 135	10/28/15	< 1		
MES-1028-36A	Miner ES	1st floor inside Classroom 137	10/28/15	< 1		
MES-1028-36B	Miner ES	1st floor inside Classroom 137	10/28/15	< 1		
MES-1028-37A	Miner ES	1st floor hallway adjacent to Resource Room 136 (high)	10/28/15	< 1		
MES-1028-37B	Miner ES	1st floor hallway adjacent to Resource Room 136 (high)	10/28/15	< 1		
MES-1028-38A	Miner ES	1st floor hallway adjacent to Resource Room 136 (low)	10/28/15	< 1		
MES-1028-38B	Miner ES	1st floor hallway adjacent to Resource Room 136 (low)	10/28/15	< 1		
MES-1028-39A	Miner ES	2nd floor inside Classroom 234	10/28/15	< 1		
MES-1028-39B	Miner ES	2nd floor inside Classroom 234	10/28/15	< 1		
MES-1028-40A	Miner ES	2nd floor inside Classroom 238	10/28/15	< 1		
MES-1028-40B	Miner ES	2nd floor inside Classroom 238	10/28/15	< 1		
MES-1028-41A	Miner ES	1st floor inside Classroom 130	10/28/15	< 1		
MES-1028-41B	Miner ES	1st floor inside Classroom 130	10/28/15	< 1		
MES-1028-42A	Miner ES	1st floor inside Classroom 132	10/28/15	< 1		
MES-1028-42B	Miner ES	1st floor inside Classroom 132	10/28/15	< 1		
MES-1028-43A	Miner ES	1st floor inside Classroom 131	10/28/15	< 1		
MES-1028-43B	Miner ES	1st floor inside Classroom 131	10/28/15	< 1		
MES-1028-44A	Miner ES	1st floor inside Classroom 121	10/28/15	< 1		
MES-1028-44B	Miner ES	1st floor inside Classroom 121	10/28/15	< 1		
MES-1028-45A	Miner ES	1st floor inside Playroom 106	10/28/15		20	Filter Installed.
MES-1028-45B	Miner ES	1st floor inside Playroom 106	10/28/15		19	
MES-0205-1A	Miner ES	1st floor inside Playroom 106 (Retest)	2/5/16	< 1		
MES-0205-1B	Miner ES	1st floor inside Playroom 106 (Retest)	2/5/16	< 1		
						<b>97.83%</b>
<b>Percentage of Failed Samples</b>						<b>2.17%</b>
MES-1117-1A	Moten ES	3rd floor hallway adjacent to Janitor's Closet 319	11/17/15	< 1		
MES-1117-1B	Moten ES	3rd floor hallway adjacent to Janitor's Closet 319	11/17/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
MES-1117-2A	Moten ES	3rd floor hallway adjacent to Classroom 327	11/17/15	< 1		
MES-1117-2B	Moten ES	3rd floor hallway adjacent to Classroom 327	11/17/15	< 1		
MES-1117-3A	Moten ES	3rd floor hallway adjacent to Boy's Room 314 (high)	11/17/15	< 1		
MES-1117-3B	Moten ES	3rd floor hallway adjacent to Boy's Room 314 (high)	11/17/15	< 1		
MES-1117-4A	Moten ES	3rd floor hallway adjacent to Boy's Room 314 (low)	11/17/15	< 1		
MES-1117-4B	Moten ES	3rd floor hallway adjacent to Boy's Room 314 (low)	11/17/15	< 1		
MES-1117-5A	Moten ES	3rd floor hallway adjacent to Girl's Room 301 (high)	11/17/15	< 1		
MES-1117-5B	Moten ES	3rd floor hallway adjacent to Girl's Room 301 (high)	11/17/15	< 1		
MES-1117-6A	Moten ES	3rd floor hallway adjacent to Girl's Room 301 (low)	11/17/15	< 1		
MES-1117-6B	Moten ES	3rd floor hallway adjacent to Girl's Room 301 (low)	11/17/15	< 1		
MES-1117-7A	Moten ES	2nd floor hallway adjacent to Girl's Room 202 (high)	11/17/15	< 1		
MES-1117-7B	Moten ES	2nd floor hallway adjacent to Girl's Room 202 (high)	11/17/15	< 1		
MES-1117-8A	Moten ES	2nd floor hallway adjacent to Girl's Room 202 (low)	11/17/15	< 1		
MES-1117-8B	Moten ES	2nd floor hallway adjacent to Girl's Room 202 (low)	11/17/15	< 1		
MES-1117-9A	Moten ES	2nd floor hallway adjacent to Boy's Room 211 (high)	11/17/15	< 1		
MES-1117-9B	Moten ES	2nd floor hallway adjacent to Boy's Room 211 (high)	11/17/15	< 1		
MES-1117-10A	Moten ES	2nd floor hallway adjacent to Boy's Room 211 (low)	11/17/15	< 1		
MES-1117-10B	Moten ES	2nd floor hallway adjacent to Boy's Room 211 (low)	11/17/15	< 1		
MES-1117-11A	Moten ES	2nd floor hallway adjacent to Janitor's Closet 219	11/17/15	< 1		
MES-1117-11B	Moten ES	2nd floor hallway adjacent to Janitor's Closet 219	11/17/15	< 1		
MES-1117-12A	Moten ES	2nd floor hallway adjacent to Stairwell C	11/17/15	< 1		
MES-1117-12B	Moten ES	2nd floor hallway adjacent to Stairwell C	11/17/15	< 1		
MES-1117-13A	Moten ES	1st floor hallway adjacent to Stairwell C	11/17/15	< 1		
MES-1117-13B	Moten ES	1st floor hallway adjacent to Stairwell C	11/17/15	< 1		
MES-1117-14A	Moten ES	1st floor hallway adjacent to Janitor's Closet 127	11/17/15	< 1		
MES-1117-14B	Moten ES	1st floor hallway adjacent to Janitor's Closet 127	11/17/15	< 1		
MES-1117-15A	Moten ES	1st floor hallway adjacent to Boy's Room 119 (high)	11/17/15	< 1		
MES-1117-15B	Moten ES	1st floor hallway adjacent to Boy's Room 119 (high)	11/17/15	< 1		
MES-1117-16A	Moten ES	1st floor hallway adjacent to Boy's Room 119 (low)	11/17/15	< 1		
MES-1117-16B	Moten ES	1st floor hallway adjacent to Boy's Room 119 (low)	11/17/15	< 1		
MES-1117-17A	Moten ES	1st floor hallway adjacent to Girl's Room 103 (high)	11/17/15	< 1		
MES-1117-17B	Moten ES	1st floor hallway adjacent to Girl's Room 103 (high)	11/17/15	< 1		
MES-1117-18A	Moten ES	1st floor hallway adjacent to Girl's Room 103 (low)	11/17/15	< 1		
MES-1117-18B	Moten ES	1st floor hallway adjacent to Girl's Room 103 (low)	11/17/15	< 1		
MES-1117-19A	Moten ES	Ground floor hallway adjacent to Girl's Room G06 (high)	11/17/15	< 1		
MES-1117-19B	Moten ES	Ground floor hallway adjacent to Girl's Room G06 (high)	11/17/15	< 1		
MES-1117-20A	Moten ES	Ground floor hallway adjacent to Girl's Room G06 (low)	11/17/15	< 1		
MES-1117-20B	Moten ES	Ground floor hallway adjacent to Girl's Room G06 (low)	11/17/15	< 1		
MES-1117-21A	Moten ES	Ground floor hallway adjacent to Records Room G10 (high)	11/17/15	< 1		
MES-1117-21B	Moten ES	Ground floor hallway adjacent to Records Room G10 (high)	11/17/15	< 1		
MES-1117-22A	Moten ES	Ground floor hallway adjacent to Records Room G10 (low)	11/17/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
MES-1117-22B	Moten ES	Ground floor hallway adjacent to Records Room G10 (low)	11/17/15	< 1		
MES-1117-23A	Moten ES	Ground floor hallway adjacent to Janitor's Closet G26	11/17/15	< 1		
MES-1117-23B	Moten ES	Ground floor hallway adjacent to Janitor's Closet G26	11/17/15	< 1		
MES-1117-24A	Moten ES	Ground floor hallway adjacent to Stairwell C	11/17/15	< 1		
MES-1117-24B	Moten ES	Ground floor hallway adjacent to Stairwell C	11/17/15	< 1		
MES-1117-25A	Moten ES	Basement floor hallway adjacent to Stairwell C	11/17/15	< 1		
MES-1117-25B	Moten ES	Basement floor hallway adjacent to Stairwell C	11/17/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MES-0223-1A	Murch ES	2nd floor hallway across from Classroom 205	2/23/16	< 1		
MES-0223-1B	Murch ES	2nd floor hallway across from Classroom 205	2/23/16	< 1		
MES-0223-2A	Murch ES	2nd floor hallway adjacent to Classroom 208	2/23/16	< 1		
MES-0223-2B	Murch ES	2nd floor hallway adjacent to Classroom 208	2/23/16	< 1		
MES-0223-3A	Murch ES	2nd floor hallway adjacent to Classroom 200	2/23/16	< 1		
MES-0223-3B	Murch ES	2nd floor hallway adjacent to Classroom 200	2/23/16	< 1		
MES-0223-4A	Murch ES	1st floor hallway adjacent to Boy's Room	2/23/16	< 1		
MES-0223-4B	Murch ES	1st floor hallway adjacent to Boy's Room	2/23/16	< 1		
MES-0223-5A	Murch ES	1st floor inside Gym	2/23/16	< 1		
MES-0223-5B	Murch ES	1st floor inside Gym	2/23/16	< 1		
MES-0223-6A	Murch ES	1st floor hallway adjacent to Classroom 101	2/23/16	< 1		
MES-0223-6B	Murch ES	1st floor hallway adjacent to Classroom 101	2/23/16	< 1		
MES-0223-7A	Murch ES	Inside Kaufman trailer adjacent to Girl's Room	2/23/16	< 1		
MES-0223-7B	Murch ES	Inside Kaufman trailer adjacent to Girl's Room	2/23/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
NES-1124-1A	Nalle ES	2nd floor hallway across from Classroom 214 (high)	11/24/15	< 1		
NES-1124-1B	Nalle ES	2nd floor hallway across from Classroom 214 (high)	11/24/15	< 1		
NES-1124-2A	Nalle ES	2nd floor hallway across from Classroom 214 (low)	11/24/15	< 1		
NES-1124-2B	Nalle ES	2nd floor hallway across from Classroom 214 (low)	11/24/15	< 1		
NES-1124-3A	Nalle ES	1st floor hallway adjacent to Custodian Closet 111 (high)	11/24/15	< 1		
NES-1124-3B	Nalle ES	1st floor hallway adjacent to Custodian Closet 111 (high)	11/24/15	< 1		
NES-1124-4A	Nalle ES	1st floor hallway adjacent to Custodian Closet 111 (low)	11/24/15	< 1		
NES-1124-4B	Nalle ES	1st floor hallway adjacent to Custodian Closet 111 (low)	11/24/15	< 1		
NES-1124-5A	Nalle ES	1st floor inside Classroom 118	11/24/15	< 1		
NES-1124-5B	Nalle ES	1st floor inside Classroom 118	11/24/15	< 1		
NES-1124-6A	Nalle ES	1st floor inside Classroom 112	11/24/15	< 1		
NES-1124-6B	Nalle ES	1st floor inside Classroom 112	11/24/15	< 1		
NES-1124-7A	Nalle ES	1st floor inside Classroom 110	11/24/15	< 1		
NES-1124-7B	Nalle ES	1st floor inside Classroom 110	11/24/15	< 1		
NES-1124-8A	Nalle ES	1st floor inside Health Suite 107	11/24/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
NES-1124-8B	Nalle ES	1st floor inside Health Suite 107	11/24/15	< 1		
NES-1124-9A	Nalle ES	1st floor inside Classroom 106	11/24/15	< 1		
NES-1124-9B	Nalle ES	1st floor inside Classroom 106	11/24/15	< 1		
NES-1124-10A	Nalle ES	1st floor inside Classroom 104	11/24/15	3.2		
NES-1124-10B	Nalle ES	1st floor inside Classroom 104	11/24/15	< 1		
NES-1124-11A	Nalle ES	1st floor inside Classroom 132	11/24/15	< 1		
NES-1124-11B	Nalle ES	1st floor inside Classroom 132	11/24/15	< 1		
NES-1124-12A	Nalle ES	1st floor inside Classroom 130	11/24/15	< 1		
NES-1124-12B	Nalle ES	1st floor inside Classroom 130	11/24/15	< 1		
NES-1124-13A	Nalle ES	1st floor hallway adjacent to Custodian Closet 127	11/24/15	< 1		
NES-1124-13B	Nalle ES	1st floor hallway adjacent to Custodian Closet 127	11/24/15	< 1		
NES-1124-14A	Nalle ES	1st floor inside Classroom 128	11/24/15	< 1		
NES-1124-14B	Nalle ES	1st floor inside Classroom 128	11/24/15	< 1		
NES-1124-15A	Nalle ES	1st floor inside Classroom 123	11/24/15	< 1		
NES-1124-15B	Nalle ES	1st floor inside Classroom 123	11/24/15	< 1		
NES-1124-16A	Nalle ES	Basement floor hallway near Stair 2 (high)	11/24/15	< 1		
NES-1124-16B	Nalle ES	Basement floor hallway near Stair 2 (high)	11/24/15	< 1		
NES-1124-17A	Nalle ES	Basement floor hallway near Stair 2 (low)	11/24/15	< 1		
NES-1124-17B	Nalle ES	Basement floor hallway near Stair 2 (low)	11/24/15	< 1		
NES-1124-18A	Nalle ES	Basement floor inside Cafeteria	11/24/15	< 1		
NES-1124-18B	Nalle ES	Basement floor inside Cafeteria	11/24/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
NES-0108-1A	Noyes ES	2nd floor hallway adjacent to Classroom 202 (high)	1/18/16	< 1		
NES-0108-1B	Noyes ES	2nd floor hallway adjacent to Classroom 202 (high)	1/18/16	< 1		
NES-0108-2A	Noyes ES	2nd floor hallway adjacent to Classroom 202 (low)	1/18/16	< 1		
NES-0108-2B	Noyes ES	2nd floor hallway adjacent to Classroom 202 (low)	1/18/16	< 1		
NES-0108-3A	Noyes ES	2nd floor inside Classroom 203	1/18/16	< 1		
NES-0108-3B	Noyes ES	2nd floor inside Classroom 203	1/18/16	< 1		
NES-0108-4A	Noyes ES	2nd floor inside Classroom 204	1/18/16	< 1		
NES-0108-4B	Noyes ES	2nd floor inside Classroom 204	1/18/16	< 1		
NES-0108-5A	Noyes ES	2nd floor inside Classroom 206	1/18/16	< 1		
NES-0108-5B	Noyes ES	2nd floor inside Classroom 206	1/18/16	< 1		
NES-0108-6A	Noyes ES	2nd floor inside Classroom 205	1/18/16	< 1		
NES-0108-6B	Noyes ES	2nd floor inside Classroom 205	1/18/16	< 1		
NES-0108-7A	Noyes ES	2nd floor hallway near Elevator (high)	1/18/16	< 1		
NES-0108-7B	Noyes ES	2nd floor hallway near Elevator (high)	1/18/16	< 1		
NES-0108-8A	Noyes ES	2nd floor hallway near Elevator (low)	1/18/16	< 1		
NES-0108-8B	Noyes ES	2nd floor hallway near Elevator (low)	1/18/16	< 1		
NES-0108-9A	Noyes ES	2nd floor inside Classroom 213	1/18/16	3.9		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
NES-0108-9B	Noyes ES	2nd floor inside Classroom 213	1/18/16	< 1		
NES-0108-10A	Noyes ES	2nd floor inside Speech Room 212	1/18/16	2.6		
NES-0108-10B	Noyes ES	2nd floor inside Speech Room 212	1/18/16	< 1		
NES-0108-11A	Noyes ES	2nd floor inside Classroom 214	1/18/16	< 1		
NES-0108-11B	Noyes ES	2nd floor inside Classroom 214	1/18/16	< 1		
NES-0108-12A	Noyes ES	2nd floor inside Classroom 216	1/18/16	< 1		
NES-0108-12B	Noyes ES	2nd floor inside Classroom 216	1/18/16	< 1		
NES-0108-13A	Noyes ES	1st floor hallway at entrance to Gym (high)	1/18/16	< 1		
NES-0108-13B	Noyes ES	1st floor hallway at entrance to Gym (high)	1/18/16	< 1		
NES-0108-14A	Noyes ES	1st floor hallway at entrance to Gym (low)	1/18/16	< 1		
NES-0108-14B	Noyes ES	1st floor hallway at entrance to Gym (low)	1/18/16	< 1		
NES-0108-15A	Noyes ES	1st floor hallway adjacent to Stair A (high)	1/18/16	< 1		
NES-0108-15B	Noyes ES	1st floor hallway adjacent to Stair A (high)	1/18/16	< 1		
NES-0108-16A	Noyes ES	1st floor hallway adjacent to Stair A (low)	1/18/16	< 1		
NES-0108-16B	Noyes ES	1st floor hallway adjacent to Stair A (low)	1/18/16	< 1		
NES-0108-17A	Noyes ES	1st floor hallway near entrance to Auditorium (high)	1/18/16	< 1		
NES-0108-17B	Noyes ES	1st floor hallway near entrance to Auditorium (high)	1/18/16	< 1		
NES-0108-18A	Noyes ES	1st floor hallway near entrance to Auditorium (low)	1/18/16	< 1		
NES-0108-18B	Noyes ES	1st floor hallway near entrance to Auditorium (low)	1/18/16	< 1		
NES-0108-19A	Noyes ES	1st floor inside Classroom 128	1/18/16	< 1		
NES-0108-19B	Noyes ES	1st floor inside Classroom 128	1/18/16	< 1		
NES-0108-20A	Noyes ES	1st floor inside Classroom 130	1/18/16	< 1		
NES-0108-20B	Noyes ES	1st floor inside Classroom 130	1/18/16	< 1		
NES-0108-21A	Noyes ES	1st floor inside Classroom 129	1/18/16	< 1		
NES-0108-21B	Noyes ES	1st floor inside Classroom 129	1/18/16	< 1		
NES-0108-22A	Noyes ES	1st floor inside Classroom 131	1/18/16	< 1		
NES-0108-22B	Noyes ES	1st floor inside Classroom 131	1/18/16	< 1		
NES-0108-23A	Noyes ES	1st floor inside Classroom 132	1/18/16	< 1		
NES-0108-23B	Noyes ES	1st floor inside Classroom 132	1/18/16	< 1		
NES-0108-24A	Noyes ES	1st floor inside Classroom 134	1/18/16	< 1		
NES-0108-24B	Noyes ES	1st floor inside Classroom 134	1/18/16	< 1		
NES-0108-25A	Noyes ES	1st floor inside Classroom 133	1/18/16	< 1		
NES-0108-25B	Noyes ES	1st floor inside Classroom 133	1/18/16	< 1		
NES-0108-26A	Noyes ES	1st floor inside Classroom 135	1/18/16	< 1		
NES-0108-26B	Noyes ES	1st floor inside Classroom 135	1/18/16	< 1		
			<b>Percentage of Passed Samples</b>			<b>100.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
OES-1204-1A	Orr ES	4th floor hallway adjacent to Girl's room	12/4/15	< 1		
OES-1204-1B	Orr ES	4th floor hallway adjacent to Girl's room	12/4/15	< 1		
OES-1204-2A	Orr ES	4th floor hallway adjacent to Boy's room	12/4/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
OES-1204-2B	Orr ES	4th floor hallway adjacent to Boy's room	12/4/15	< 1		
OES-1204-3A	Orr ES	3rd floor hallway adjacent to Girl's room	12/4/15	< 1		
OES-1204-3B	Orr ES	3rd floor hallway adjacent to Girl's room	12/4/15	< 1		
OES-1204-4A	Orr ES	3rd floor hallway adjacent to Boy's room	12/4/15	< 1		
OES-1204-4B	Orr ES	3rd floor hallway adjacent to Boy's room	12/4/15	< 1		
OES-1204-5A	Orr ES	2nd floor hallway adjacent to Girl's Room	12/4/15	< 1		
OES-1204-5B	Orr ES	2nd floor hallway adjacent to Girl's Room	12/4/15	< 1		
OES-1204-6A	Orr ES	2nd floor hallway adjacent to Boy's Room	12/4/15	< 1		
OES-1204-6B	Orr ES	2nd floor hallway adjacent to Boy's Room	12/4/15	< 1		
OES-1204-7A	Orr ES	1st floor inside Pre-K 2	12/4/15	< 1		
OES-1204-7B	Orr ES	1st floor inside Pre-K 2	12/4/15	< 1		
OES-1204-8A	Orr ES	1st floor inside Pre-K 1	12/4/15	1.8		
OES-1204-8B	Orr ES	1st floor inside Pre-K 1	12/4/15	1.8		
OES-1204-9A	Orr ES	1st floor inside Kindergarten 2	12/4/15	< 1		
OES-1204-9B	Orr ES	1st floor inside Kindergarten 2	12/4/15	< 1		
OES-1204-10A	Orr ES	1st floor inside Kindergarten 1	12/4/15	< 1		
OES-1204-10B	Orr ES	1st floor inside Kindergarten 1	12/4/15	< 1		
OES-1204-11A	Orr ES	1st floor hallway between Men's and Women's Restrooms	12/4/15	< 1		
OES-1204-11B	Orr ES	1st floor hallway between Men's and Women's Restrooms	12/4/15	< 1		
OES-1204-12A	Orr ES	1st floor inside Multi-Purpose Room across from Stage Door	12/4/15	< 1		
OES-1204-12B	Orr ES	1st floor inside Multi-Purpose Room across from Stage Door	12/4/15	< 1		
OES-1204-13A	Orr ES	1st floor inside Multi-Purpose Room near Kitchen	12/4/15	< 1		
OES-1204-13B	Orr ES	1st floor inside Multi-Purpose Room near Kitchen	12/4/15	< 1		
OES-1204-14A	Orr ES	1st floor inside Multi-Purpose Room near Storage Room	12/4/15	< 1		
OES-1204-14B	Orr ES	1st floor inside Multi-Purpose Room near Storage Room	12/4/15	< 1		
OES-1204-15A	Orr ES	1st floor hallway adjacent to Instructional Resource Room	12/4/15	< 1		
OES-1204-15B	Orr ES	1st floor hallway adjacent to Instructional Resource Room	12/4/15	< 1		
OES-1204-16A	Orr ES	1st floor hallway across from Main Office	12/4/15	< 1		
OES-1204-16B	Orr ES	1st floor hallway across from Main Office	12/4/15	< 1		
OES-1204-17A	Orr ES	1st floor inside Health Suite	12/4/15	< 1		
OES-1204-17B	Orr ES	1st floor inside Health Suite	12/4/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
OES-0322-1A	Oyster ES	4th floor inside Classroom 401	3/22/16	< 1		
OES-0322-1B	Oyster ES	4th floor inside Classroom 401	3/22/16	< 1		
OES-0322-2A	Oyster ES	4th floor inside Classroom 405	3/22/16	< 1		
OES-0322-2B	Oyster ES	4th floor inside Classroom 405	3/22/16	< 1		
OES-0322-3A	Oyster ES	4th floor inside Classroom 407	3/22/16	< 1		
OES-0322-3B	Oyster ES	4th floor inside Classroom 407	3/22/16	< 1		
OES-0322-4A	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (high)	3/22/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
OES-0322-4B	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (high)	3/22/16	< 1		
OES-0322-5A	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (low)	3/22/16	< 1		
OES-0322-5B	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (low)	3/22/16	< 1		
OES-0322-6A	Oyster ES	4th floor inside Classroom 410	3/22/16	< 1		
OES-0322-6B	Oyster ES	4th floor inside Classroom 410	3/22/16	< 1		
OES-0322-7A	Oyster ES	4th floor inside Classroom 412	3/22/16	< 1		
OES-0322-7B	Oyster ES	4th floor inside Classroom 412	3/22/16	< 1		
OES-0322-8A	Oyster ES	3rd floor inside Classroom 301	3/22/16	< 1		
OES-0322-8B	Oyster ES	3rd floor inside Classroom 301	3/22/16	< 1		
OES-0322-9A	Oyster ES	3rd floor inside Classroom 304	3/22/16	< 1		
OES-0322-9B	Oyster ES	3rd floor inside Classroom 304	3/22/16	< 1		
OES-0322-10A	Oyster ES	3rd floor inside Classroom 308	3/22/16	< 1		
OES-0322-10B	Oyster ES	3rd floor inside Classroom 308	3/22/16	< 1		
OES-0322-11A	Oyster ES	3rd floor hallway across from Room 310 (high)	3/22/16	< 1		
OES-0322-11B	Oyster ES	3rd floor hallway across from Room 310 (high)	3/22/16	< 1		
OES-0322-12A	Oyster ES	3rd floor hallway across from Room 310 (low)	3/22/16	< 1		
OES-0322-12B	Oyster ES	3rd floor hallway across from Room 310 (low)	3/22/16	< 1		
OES-0322-13A	Oyster ES	3rd floor inside Classroom 313	3/22/16	< 1		
OES-0322-13B	Oyster ES	3rd floor inside Classroom 313	3/22/16	< 1		
OES-0322-14A	Oyster ES	3rd floor inside Classroom 316	3/22/16	< 1		
OES-0322-14B	Oyster ES	3rd floor inside Classroom 316	3/22/16	< 1		
OES-0322-15A	Oyster ES	3rd floor inside Guidance Suite 309	3/22/16	< 1		
OES-0322-15B	Oyster ES	3rd floor inside Guidance Suite 309	3/22/16	< 1		
OES-0322-16A	Oyster ES	2nd floor inside Classroom 201	3/22/16	< 1		
OES-0322-16B	Oyster ES	2nd floor inside Classroom 201	3/22/16	< 1		
OES-0322-17A	Oyster ES	2nd floor inside Classroom 202	3/22/16	< 1		
OES-0322-17B	Oyster ES	2nd floor inside Classroom 202	3/22/16	< 1		
OES-0322-18A	Oyster ES	2nd floor inside Gym (high)	3/22/16	< 1		
OES-0322-18B	Oyster ES	2nd floor inside Gym (high)	3/22/16	< 1		
OES-0322-19A	Oyster ES	2nd floor inside Gym (low)	3/22/16	< 1		
OES-0322-19B	Oyster ES	2nd floor inside Gym (low)	3/22/16	< 1		
OES-0322-20A	Oyster ES	2nd floor hallway between Boy's and Girl's Rooms (high)	3/22/16	< 1		
OES-0322-20B	Oyster ES	2nd floor hallway between Boy's and Girl's Rooms (high)	3/22/16	< 1		
OES-0322-21A	Oyster ES	2nd floor hallway between Boy's and Girl's Rooms (low)	3/22/16	< 1		
OES-0322-21B	Oyster ES	2nd floor hallway between Boy's and Girl's Rooms (low)	3/22/16	< 1		
OES-0322-22A	Oyster ES	2nd floor inside Classroom 210	3/22/16	< 1		
OES-0322-22B	Oyster ES	2nd floor inside Classroom 210	3/22/16	< 1		
OES-0322-23A	Oyster ES	2nd floor inside Classroom 211	3/22/16	< 1		
OES-0322-23B	Oyster ES	2nd floor inside Classroom 211	3/22/16	< 1		
OES-0322-24A	Oyster ES	1st floor hallway between Boy's and Girl's Rooms (high)	3/22/16	< 1		
OES-0322-24B	Oyster ES	1st floor hallway between Boy's and Girl's Rooms (high)	3/22/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
OES-0322-25A	Oyster ES	1st floor hallway between Boy's and Girl's Rooms (low)	3/22/16	< 1		
OES-0322-25B	Oyster ES	1st floor hallway between Boy's and Girl's Rooms (low)	3/22/16	< 1		
OES-0322-26A	Oyster ES	1st floor inside Art Room 104	3/22/16	< 1		
OES-0322-26B	Oyster ES	1st floor inside Art Room 104	3/22/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
PES-0112-1A	Patterson ES	3rd floor hallway adjacent to Janitor's Closet 302 (high)	1/12/16	< 1		
PES-0112-1B	Patterson ES	3rd floor hallway adjacent to Janitor's Closet 302 (high)	1/12/16	< 1		
PES-0112-2A	Patterson ES	3rd floor hallway adjacent to Janitor's Closet 302 (low)	1/12/16	< 1		
PES-0112-2B	Patterson ES	3rd floor hallway adjacent to Janitor's Closet 302 (low)	1/12/16	< 1		
PES-0112-3A	Patterson ES	3rd floor inside Classroom 312	1/12/16	< 1		
PES-0112-3B	Patterson ES	3rd floor inside Classroom 312	1/12/16	< 1		
PES-0112-4A	Patterson ES	3rd floor inside Classroom 311	1/12/16	< 1		
PES-0112-4B	Patterson ES	3rd floor inside Classroom 311	1/12/16	< 1		
PES-0112-5A	Patterson ES	3rd floor inside Classroom 316	1/12/16	< 1		
PES-0112-5B	Patterson ES	3rd floor inside Classroom 316	1/12/16	< 1		
PES-0112-6A	Patterson ES	3rd floor inside Classroom 307	1/12/16	< 1		
PES-0112-6B	Patterson ES	3rd floor inside Classroom 307	1/12/16	< 1		
PES-0112-7A	Patterson ES	3rd floor inside Classroom 321	1/12/16	< 1		
PES-0112-7B	Patterson ES	3rd floor inside Classroom 321	1/12/16	< 1		
PES-0112-8A	Patterson ES	3rd floor inside Classroom 317	1/12/16	< 1		
PES-0112-8B	Patterson ES	3rd floor inside Classroom 317	1/12/16	< 1		
PES-0112-9A	Patterson ES	3rd floor inside Classroom 324	1/12/16	< 1		
PES-0112-9B	Patterson ES	3rd floor inside Classroom 324	1/12/16	< 1		
PES-0112-10A	Patterson ES	3rd floor inside Classroom 323	1/12/16	< 1		
PES-0112-10B	Patterson ES	3rd floor inside Classroom 323	1/12/16	< 1		
PES-0112-11A	Patterson ES	2nd floor hallway adjacent to Janitor's Closet 208B (high)	1/12/16	< 1		
PES-0112-11B	Patterson ES	2nd floor hallway adjacent to Janitor's Closet 208B (high)	1/12/16	< 1		
PES-0112-12A	Patterson ES	2nd floor hallway adjacent to Janitor's Closet 208B (low)	1/12/16	< 1		
PES-0112-12B	Patterson ES	2nd floor hallway adjacent to Janitor's Closet 208B (low)	1/12/16	< 1		
PES-0112-13A	Patterson ES	2nd floor inside Classroom 215	1/12/16	< 1		
PES-0112-13B	Patterson ES	2nd floor inside Classroom 215	1/12/16	< 1		
PES-0112-14A	Patterson ES	2nd floor inside Classroom 214	1/12/16	< 1		
PES-0112-14B	Patterson ES	2nd floor inside Classroom 214	1/12/16	< 1		
PES-0112-15A	Patterson ES	2nd floor inside Classroom 216	1/12/16	< 1		
PES-0112-15B	Patterson ES	2nd floor inside Classroom 216	1/12/16	< 1		
PES-0112-16A	Patterson ES	2nd floor inside Classroom 213	1/12/16	< 1		
PES-0112-16B	Patterson ES	2nd floor inside Classroom 213	1/12/16	< 1		
PES-0112-17A	Patterson ES	2nd floor inside Classroom 221	1/12/16	< 1		
PES-0112-17B	Patterson ES	2nd floor inside Classroom 221	1/12/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
PES-0112-18A	Patterson ES	2nd floor inside Classroom 223	1/12/16	< 1		
PES-0112-18B	Patterson ES	2nd floor inside Classroom 223	1/12/16	< 1		
PES-0112-19A	Patterson ES	2nd floor inside Classroom 222	1/12/16	< 1		
PES-0112-19B	Patterson ES	2nd floor inside Classroom 222	1/12/16	< 1		
PES-0112-20A	Patterson ES	2nd floor inside Classroom 224	1/12/16	< 1		
PES-0112-20B	Patterson ES	2nd floor inside Classroom 224	1/12/16	< 1		
PES-0112-21A	Patterson ES	2nd floor inside Classroom 225	1/12/16	< 1		
PES-0112-21B	Patterson ES	2nd floor inside Classroom 225	1/12/16	< 1		
PES-0112-22A	Patterson ES	2nd floor inside Classroom 220	1/12/16	< 1		
PES-0112-22B	Patterson ES	2nd floor inside Classroom 220	1/12/16	< 1		
PES-0112-23A	Patterson ES	2nd floor inside Classroom 226	1/12/16	< 1		
PES-0112-23B	Patterson ES	2nd floor inside Classroom 226	1/12/16	< 1		
PES-0112-24A	Patterson ES	2nd floor inside Classroom 218	1/12/16	< 1		
PES-0112-24B	Patterson ES	2nd floor inside Classroom 218	1/12/16	< 1		
PES-0112-25A	Patterson ES	2nd floor inside Classroom 227	1/12/16	< 1		
PES-0112-25B	Patterson ES	2nd floor inside Classroom 227	1/12/16	< 1		
PES-0112-26A	Patterson ES	2nd floor inside Classroom 230	1/12/16	< 1		
PES-0112-26B	Patterson ES	2nd floor inside Classroom 230	1/12/16	< 1		
PES-0112-27A	Patterson ES	2nd floor inside Classroom 232	1/12/16	< 1		
PES-0112-27B	Patterson ES	2nd floor inside Classroom 232	1/12/16	< 1		
PES-0112-28A	Patterson ES	1st floor hallway adjacent to Janitor's Closet 110 (high)	1/12/16	< 1		
PES-0112-28B	Patterson ES	1st floor hallway adjacent to Janitor's Closet 110 (high)	1/12/16	< 1		
PES-0112-29A	Patterson ES	1st floor hallway adjacent to Janitor's Closet 110 (low)	1/12/16	< 1		
PES-0112-29B	Patterson ES	1st floor hallway adjacent to Janitor's Closet 110 (low)	1/12/16	< 1		
PES-0112-30A	Patterson ES	1st floor inside Classroom 115	1/12/16	< 1		
PES-0112-30B	Patterson ES	1st floor inside Classroom 115	1/12/16	< 1		
PES-0112-31A	Patterson ES	1st floor inside Classroom 123	1/12/16	< 1		
PES-0112-31B	Patterson ES	1st floor inside Classroom 123	1/12/16	< 1		
PES-0112-32A	Patterson ES	1st floor inside Classroom 120	1/12/16	< 1		
PES-0112-32B	Patterson ES	1st floor inside Classroom 120	1/12/16	< 1		
PES-0112-33A	Patterson ES	1st floor inside Classroom 119	1/12/16	< 1		
PES-0112-33B	Patterson ES	1st floor inside Classroom 119	1/12/16	< 1		
PES-0112-34A	Patterson ES	1st floor inside Classroom 125	1/12/16	< 1		
PES-0112-34B	Patterson ES	1st floor inside Classroom 125	1/12/16	< 1		
PES-0112-35A	Patterson ES	1st floor inside Classroom 127	1/12/16	< 1		
PES-0112-35B	Patterson ES	1st floor inside Classroom 127	1/12/16	< 1		
PES-0112-36A	Patterson ES	1st floor inside Classroom 124	1/12/16	< 1		
PES-0112-36B	Patterson ES	1st floor inside Classroom 124	1/12/16	< 1		
PES-0112-37A	Patterson ES	1st floor inside Classroom 126	1/12/16	< 1		
PES-0112-37B	Patterson ES	1st floor inside Classroom 126	1/12/16	< 1		
PES-0112-38A	Patterson ES	1st floor inside Cafeteria (high)	1/12/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
PES-0112-38B	Patterson ES	1st floor inside Cafeteria (high)	1/12/16	< 1		
PES-0112-39A	Patterson ES	1st floor inside Cafeteria (low)	1/12/16	< 1		
PES-0112-39B	Patterson ES	1st floor inside Cafeteria (low)	1/12/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
PES-1125-1A	Payne ES	3rd floor hallway adjacent to Girl's Room (high)	11/25/15	< 1		
PES-1125-1B	Payne ES	3rd floor hallway adjacent to Girl's Room (high)	11/25/15	< 1		
PES-1125-2A	Payne ES	3rd floor hallway adjacent to Girl's Room (low)	11/25/15	< 1		
PES-1125-2B	Payne ES	3rd floor hallway adjacent to Girl's Room (low)	11/25/15	< 1		
PES-1125-3A	Payne ES	2nd floor hallway adjacent to Boy's Room (high)	11/25/15	< 1		
PES-1125-3B	Payne ES	2nd floor hallway adjacent to Boy's Room (high)	11/25/15	< 1		
PES-1125-4A	Payne ES	2nd floor hallway adjacent to Boy's Room (low)	11/25/15	< 1		
PES-1125-4B	Payne ES	2nd floor hallway adjacent to Boy's Room (low)	11/25/15	< 1		
PES-1125-5A	Payne ES	1st floor hallway adjacent to Unisex Restroom (high)	11/25/15	< 1		
PES-1125-5B	Payne ES	1st floor hallway adjacent to Unisex Restroom (high)	11/25/15	< 1		
PES-1125-6A	Payne ES	1st floor hallway adjacent to Unisex Restroom (low)	11/25/15	< 1		
PES-1125-6B	Payne ES	1st floor hallway adjacent to Unisex Restroom (low)	11/25/15	< 1		
PES-1125-7A	Payne ES	1st floor hallway adjacent to Cafeteria (high)	11/25/15	< 1		
PES-1125-7B	Payne ES	1st floor hallway adjacent to Cafeteria (high)	11/25/15	< 1		
PES-1125-8A	Payne ES	1st floor hallway adjacent to Cafeteria (low)	11/25/15	< 1		
PES-1125-8B	Payne ES	1st floor hallway adjacent to Cafeteria (low)	11/25/15	< 1		
PES-1125-9A	Payne ES	1st floor inside Classroom 161	11/25/15	< 1		
PES-1125-9B	Payne ES	1st floor inside Classroom 161	11/25/15	< 1		
PES-1125-10A	Payne ES	1st floor inside Classroom 190	11/25/15	< 1		
PES-1125-10B	Payne ES	1st floor inside Classroom 190	11/25/15	< 1		
PES-1125-11A	Payne ES	1st floor inside Classroom 168	11/25/15	< 1		
PES-1125-11B	Payne ES	1st floor inside Classroom 168	11/25/15	< 1		
PES-1125-12A	Payne ES	1st floor inside Classroom 187	11/25/15	< 1		
PES-1125-12B	Payne ES	1st floor inside Classroom 187	11/25/15	< 1		
PES-1125-13A	Payne ES	1st floor inside Classroom 184	11/25/15	< 1		
PES-1125-13B	Payne ES	1st floor inside Classroom 184	11/25/15	< 1		
PES-1125-14A	Payne ES	1st floor hallway across from Classroom 184 (high)	11/25/15	< 1		
PES-1125-14B	Payne ES	1st floor hallway across from Classroom 184 (high)	11/25/15	< 1		
PES-1125-15A	Payne ES	1st floor hallway across from Classroom 184 (low)	11/25/15	< 1		
PES-1125-15B	Payne ES	1st floor hallway across from Classroom 184 (low)	11/25/15	< 1		
PES-1125-16A	Payne ES	1st floor inside Classroom 172	11/25/15	< 1		
PES-1125-16B	Payne ES	1st floor inside Classroom 172	11/25/15	< 1		
PES-1125-17A	Payne ES	1st floor hallway adjacent to Classroom 181 (high)	11/25/15	< 1		
PES-1125-17B	Payne ES	1st floor hallway adjacent to Classroom 181 (high)	11/25/15		8600	Filter Installed.
PES-1125-18A	Payne ES	1st floor hallway adjacent to Classroom 181 (low)	11/25/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
PES-1125-18B	Payne ES	1st floor hallway adjacent to Classroom 181 (low)	11/25/15	< 1		
PES-0205-1A	Payne ES	1st floor hallway adjacent to Classroom 181 (high) (Retest)	2/5/16	< 1		
PES-0205-1B	Payne ES	1st floor hallway adjacent to Classroom 181 (high) (Retest)	2/5/16	< 1		
PES-0205-2A	Payne ES	1st floor hallway adjacent to Classroom 181 (low) (Retest)	2/5/16	< 1		
PES-0205-2B	Payne ES	1st floor hallway adjacent to Classroom 181 (low) (Retest)	2/5/16	< 1		
PES-1125-19A	Payne ES	1st floor inside Classroom 181	11/25/15	< 1		
PES-1125-19B	Payne ES	1st floor inside Classroom 181	11/25/15	< 1		
<b>Percentage of Passed Samples</b>						<b>97.37%</b>
<b>Percentage of Failed Samples</b>						<b>2.63%</b>
PES-1013-1A	Peabody ES	3rd floor inside Classroom 303	10/13/15	< 1		
PES-1013-1B	Peabody ES	3rd floor inside Classroom 303	10/13/15	< 1		
PES-1013-2A	Peabody ES	3rd floor inside Classroom 304	10/13/15	< 1		
PES-1013-2B	Peabody ES	3rd floor inside Classroom 304	10/13/15	< 1		
PES-1013-3A	Peabody ES	3rd floor inside Classroom 306	10/13/15	< 1		
PES-1013-3B	Peabody ES	3rd floor inside Classroom 306	10/13/15	< 1		
PES-1013-4A	Peabody ES	3rd floor inside Classroom 307	10/13/15	< 1		
PES-1013-4B	Peabody ES	3rd floor inside Classroom 307	10/13/15	< 1		
PES-1013-5A	Peabody ES	2nd floor inside Classroom 203	10/13/15	< 1		
PES-1013-5B	Peabody ES	2nd floor inside Classroom 203	10/13/15	< 1		
PES-1013-6A	Peabody ES	2nd floor inside Classroom 204	10/13/15	< 1		
PES-1013-6B	Peabody ES	2nd floor inside Classroom 204	10/13/15	< 1		
PES-1013-7A	Peabody ES	2nd floor inside Classroom 206	10/13/15	< 1		
PES-1013-7B	Peabody ES	2nd floor inside Classroom 206	10/13/15	< 1		
PES-1013-8A	Peabody ES	2nd floor inside Classroom 207	10/13/15	< 1		
PES-1013-8B	Peabody ES	2nd floor inside Classroom 207	10/13/15	< 1		
PES-1013-9A	Peabody ES	1st floor inside Classroom 103	10/13/15	< 1		
PES-1013-9B	Peabody ES	1st floor inside Classroom 103	10/13/15	< 1		
PES-1013-10A	Peabody ES	1st floor inside Classroom 104	10/13/15	< 1		
PES-1013-10B	Peabody ES	1st floor inside Classroom 104	10/13/15	< 1		
PES-1013-11A	Peabody ES	1st floor inside Classroom 106	10/13/15	< 1		
PES-1013-11B	Peabody ES	1st floor inside Classroom 106	10/13/15	< 1		
PES-1013-12A	Peabody ES	1st floor inside Classroom 107	10/13/15	< 1		
PES-1013-12B	Peabody ES	1st floor inside Classroom 107	10/13/15	< 1		
PES-1013-13A	Peabody ES	Basement floor hallway adjacent to Girl's Room (high)	10/13/15	< 1		
PES-1013-13B	Peabody ES	Basement floor hallway adjacent to Girl's Room (high)	10/13/15	< 1		
PES-1013-14A	Peabody ES	Basement floor hallway adjacent to Girl's Room (low)	10/13/15	< 1		
PES-1013-14B	Peabody ES	Basement floor hallway adjacent to Girl's Room (low)	10/13/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
PHS-0119-1A	Phelps HS	2nd floor hallway adjacent to Classroom C211	1/19/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
PHS-0119-1B	Phelps HS	2nd floor hallway adjacent to Classroom C211	1/19/16	< 1		
PHS-0119-2A	Phelps HS	2nd floor hallway adjacent to Music Room S206	1/19/16	< 1		
PHS-0119-2B	Phelps HS	2nd floor hallway adjacent to Music Room S206	1/19/16	< 1		
PHS-0119-3A	Phelps HS	1st floor hallway adjacent to Classroom C108	1/19/16	< 1		
PHS-0119-3B	Phelps HS	1st floor hallway adjacent to Classroom C108	1/19/16	< 1		
PHS-0119-4A	Phelps HS	1st floor hallway adjacent to Classroom C110	1/19/16	< 1		
PHS-0119-4B	Phelps HS	1st floor hallway adjacent to Classroom C110	1/19/16	< 1		
PHS-0119-5A	Phelps HS	1st floor hallway adjacent to Wood Shop T106	1/19/16	< 1		
PHS-0119-5B	Phelps HS	1st floor hallway adjacent to Wood Shop T106	1/19/16	< 1		
PHS-0119-6A	Phelps HS	1st floor hallway adjacent to Electric Shop T104	1/19/16	< 1		
PHS-0119-6B	Phelps HS	1st floor hallway adjacent to Electric Shop T104	1/19/16	< 1		
PHS-0119-7A	Phelps HS	Lower level hallway adjacent to Custodian Closet S005	1/19/16	< 1		
PHS-0119-7B	Phelps HS	Lower level hallway adjacent to Custodian Closet S005	1/19/16	< 1		
PHS-0119-8A	Phelps HS	Lower level hallway across from Gym S001	1/19/16	< 1		
PHS-0119-8B	Phelps HS	Lower level hallway across from Gym S001	1/19/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
	Plummer ES					
	Plummer ES					
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
PES-0219-1A	Powell ES	2nd floor hallway adjacent to Classroom 211	2/19/16	< 1		
PES-0219-1B	Powell ES	2nd floor hallway adjacent to Classroom 211	2/19/16	< 1		
PES-0219-2A	Powell ES	2nd floor hallway adjacent to Classroom 206 (high)	2/19/16	< 1		
PES-0219-2B	Powell ES	2nd floor hallway adjacent to Classroom 206 (high)	2/19/16	< 1		
PES-0219-3A	Powell ES	2nd floor hallway adjacent to Classroom 206 (low)	2/19/16	< 1		
PES-0219-3B	Powell ES	2nd floor hallway adjacent to Classroom 206 (low)	2/19/16	< 1		
PES-0219-4A	Powell ES	2nd floor hallway adjacent to Classroom 201 (high)	2/19/16	< 1		
PES-0219-4B	Powell ES	2nd floor hallway adjacent to Classroom 201 (high)	2/19/16	< 1		
PES-0219-5A	Powell ES	2nd floor hallway adjacent to Classroom 201 (low)	2/19/16	< 1		
PES-0219-5B	Powell ES	2nd floor hallway adjacent to Classroom 201 (low)	2/19/16	< 1		
PES-0219-6A	Powell ES	2nd floor inside Classroom 201	2/19/16	< 1		
PES-0219-6B	Powell ES	2nd floor inside Classroom 201	2/19/16	< 1		
PES-0219-7A	Powell ES	2nd floor inside Classroom 202	2/19/16	< 1		
PES-0219-7B	Powell ES	2nd floor inside Classroom 202	2/19/16	< 1		
PES-0219-8A	Powell ES	2nd floor inside Classroom 206	2/19/16	< 1		
PES-0219-8B	Powell ES	2nd floor inside Classroom 206	2/19/16	< 1		
PES-0219-9A	Powell ES	2nd floor inside Classroom 208	2/19/16	< 1		
PES-0219-9B	Powell ES	2nd floor inside Classroom 208	2/19/16	< 1		
PES-0219-10A	Powell ES	2nd floor inside Classroom 211	2/19/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
PES-0219-10B	Powell ES	2nd floor inside Classroom 211	2/19/16	< 1		
PES-0219-11A	Powell ES	2nd floor inside Classroom 212	2/19/16	< 1		
PES-0219-11B	Powell ES	2nd floor inside Classroom 212	2/19/16	< 1		
PES-0219-12A	Powell ES	2nd floor inside Room 213 Instructional Coach	2/19/16	< 1		
PES-0219-12B	Powell ES	2nd floor inside Room 213 Instructional Coach	2/19/16	< 1		
PES-0219-13A	Powell ES	2nd floor inside Teacher's Lounge 216	2/19/16	< 1		
PES-0219-13B	Powell ES	2nd floor inside Teacher's Lounge 216	2/19/16	< 1		
PES-0219-14A	Powell ES	2nd floor hallway adjacent to Teacher's Lounge 216	2/19/16	< 1		
PES-0219-14B	Powell ES	2nd floor adjacent hallway to Teacher's Lounge 216	2/19/16	< 1		
PES-0219-15A	Powell ES	2nd floor inside Classroom 221	2/19/16	< 1		
PES-0219-15B	Powell ES	2nd floor inside Classroom 221	2/19/16	< 1		
PES-0219-16A	Powell ES	2nd floor inside Classroom 222	2/19/16	< 1		
PES-0219-16B	Powell ES	2nd floor inside Classroom 222	2/19/16	< 1		
PES-0219-17A	Powell ES	2nd floor inside Classroom 223	2/19/16	< 1		
PES-0219-17B	Powell ES	2nd floor inside Classroom 223	2/19/16	< 1		
PES-0219-18A	Powell ES	2nd floor inside Classroom 224	2/19/16	< 1		
PES-0219-18B	Powell ES	2nd floor inside Classroom 224	2/19/16	< 1		
PES-0219-19A	Powell ES	1st floor hallway adjacent to Classroom 101 (high)	2/19/16	< 1		
PES-0219-19B	Powell ES	1st floor hallway adjacent to Classroom 101 (high)	2/19/16	< 1		
PES-0219-20A	Powell ES	1st floor hallway adjacent to Classroom 101 (low)	2/19/16	< 1		
PES-0219-20B	Powell ES	1st floor hallway adjacent to Classroom 101 (low)	2/19/16	< 1		
PES-0219-21A	Powell ES	1st floor inside Classroom 101	2/19/16	< 1		
PES-0219-21B	Powell ES	1st floor inside Classroom 101	2/19/16	< 1		
PES-0219-22A	Powell ES	1st floor inside Classroom 102	2/19/16	< 1		
PES-0219-22B	Powell ES	1st floor inside Classroom 102	2/19/16	< 1		
PES-0219-23A	Powell ES	1st floor inside Classroom 104	2/19/16	< 1		
PES-0219-23B	Powell ES	1st floor inside Classroom 104	2/19/16	< 1		
PES-0219-24A	Powell ES	1st floor hallway adjacent to Classroom 105 (high)	2/19/16	< 1		
PES-0219-24B	Powell ES	1st floor hallway adjacent to Classroom 105 (high)	2/19/16	< 1		
PES-0219-25A	Powell ES	1st floor hallway adjacent to Classroom 105 (low)	2/19/16	< 1		
PES-0219-25B	Powell ES	1st floor hallway adjacent to Classroom 105 (low)	2/19/16	< 1		
PES-0219-26A	Powell ES	1st floor inside Classroom 106	2/19/16	< 1		
PES-0219-26B	Powell ES	1st floor inside Classroom 106	2/19/16	< 1		
PES-0219-27A	Powell ES	1st floor inside Classroom 107	2/19/16	< 1		
PES-0219-27B	Powell ES	1st floor inside Classroom 107	2/19/16	< 1		
PES-0219-28A	Powell ES	1st floor inside Classroom 108	2/19/16	< 1		
PES-0219-28B	Powell ES	1st floor inside Classroom 108	2/19/16	< 1		
PES-0219-29A	Powell ES	1st floor inside Classroom 110	2/19/16	< 1		
PES-0219-29B	Powell ES	1st floor inside Classroom 110	2/19/16	< 1		
PES-0219-30A	Powell ES	1st floor hallway adjacent to Classroom 110	2/19/16	< 1		
PES-0219-30B	Powell ES	1st floor hallway adjacent to Classroom 110	2/19/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
PES-0219-31A	Powell ES	1st floor hallway across from Main Office	2/19/16	< 1		
PES-0219-31B	Powell ES	1st floor hallway across from Main Office	2/19/16	< 1		
PES-0219-32A	Powell ES	1st floor inside Classroom 113	2/19/16	< 1		
PES-0219-32B	Powell ES	1st floor inside Classroom 113	2/19/16	< 1		
PES-0219-33A	Powell ES	1st floor inside Classroom 114	2/19/16	< 1		
PES-0219-33B	Powell ES	1st floor inside Classroom 114	2/19/16	< 1		
PES-0219-34A	Powell ES	1st floor inside Classroom 115	2/19/16	< 1		
PES-0219-34B	Powell ES	1st floor inside Classroom 115	2/19/16	< 1		
PES-0219-35A	Powell ES	1st floor inside Classroom 116	2/19/16	< 1		
PES-0219-35B	Powell ES	1st floor inside Classroom 116	2/19/16	< 1		
PES-0219-36A	Powell ES	1st floor inside Classroom 117	2/19/16	< 1		
PES-0219-36B	Powell ES	1st floor inside Classroom 117	2/19/16	< 1		
PES-0219-37A	Powell ES	1st floor inside Classroom 118	2/19/16	< 1		
PES-0219-37B	Powell ES	1st floor inside Classroom 118	2/19/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
RH-1211-1A	Randle Highlands ES	2nd floor hallway adjacent to Custodian Closet 2214 (high)	12/11/15	< 1		
RH-1211-1B	Randle Highlands ES	2nd floor hallway adjacent to Custodian Closet 2214 (high)	12/11/15	< 1		
RH-1211-2A	Randle Highlands ES	2nd floor hallway adjacent to Custodian Closet 2214 (low)	12/11/15	< 1		
RH-1211-2B	Randle Highlands ES	2nd floor hallway adjacent to Custodian Closet 2214 (low)	12/11/15	< 1		
RH-1211-3A	Randle Highlands ES	2nd floor inside Vestibule between Rm 2201 and 2203 (high)	12/11/15	< 1		
RH-1211-3B	Randle Highlands ES	2nd floor inside Vestibule between Rm 2201 and 2203 (high)	12/11/15	< 1		
RH-1211-4A	Randle Highlands ES	2nd floor inside Vestibule between Rm 2201 and 2203 (low)	12/11/15	< 1		
RH-1211-4B	Randle Highlands ES	2nd floor inside Vestibule between Rm 2201 and 2203 (low)	12/11/15	< 1		
RH-1211-5A	Randle Highlands ES	2nd floor inside Vestibule 2231 (high)	12/11/15	< 1		
RH-1211-5B	Randle Highlands ES	2nd floor inside Vestibule 2231 (high)	12/11/15	< 1		
RH-1211-6A	Randle Highlands ES	2nd floor inside Vestibule 2231 (low)	12/11/15	< 1		
RH-1211-6B	Randle Highlands ES	2nd floor inside Vestibule 2231 (low)	12/11/15	< 1		
RH-1211-7A	Randle Highlands ES	2nd floor inside Vestibule 2226 (high)	12/11/15	< 1		
RH-1211-7B	Randle Highlands ES	2nd floor inside Vestibule 2226 (high)	12/11/15	< 1		
RH-1211-8A	Randle Highlands ES	2nd floor inside Vestibule 2226 (low)	12/11/15	< 1		
RH-1211-8B	Randle Highlands ES	2nd floor inside Vestibule 2226 (low)	12/11/15	< 1		
RH-1211-9A	Randle Highlands ES	1st floor hallway adjacent to Classroom 2114 (high)	12/11/15	< 1		
RH-1211-9B	Randle Highlands ES	1st floor hallway adjacent to Classroom 2114 (high)	12/11/15	< 1		
RH-1211-10A	Randle Highlands ES	1st floor hallway adjacent to Classroom 2114 (low)	12/11/15	< 1		
RH-1211-10B	Randle Highlands ES	1st floor hallway adjacent to Classroom 2114 (low)	12/11/15	< 1		
RH-1211-11A	Randle Highlands ES	1st floor inside Vestibule 2121 (high)	12/11/15	< 1		
RH-1211-11B	Randle Highlands ES	1st floor inside Vestibule 2121 (high)	12/11/15	< 1		
RH-1211-12A	Randle Highlands ES	1st floor inside Vestibule 2121 (low)	12/11/15	< 1		
RH-1211-12B	Randle Highlands ES	1st floor inside Vestibule 2121 (low)	12/11/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
RH-1211-13A	Randle Highlands ES	1st floor inside Vestibule 2126 (high)	12/11/15	< 1		
RH-1211-13B	Randle Highlands ES	1st floor inside Vestibule 2126 (high)	12/11/15	< 1		
RH-1211-14A	Randle Highlands ES	1st floor inside Vestibule 2126 (low)	12/11/15	< 1		
RH-1211-14B	Randle Highlands ES	1st floor inside Vestibule 2126 (low)	12/11/15	< 1		
RH-1211-15A	Randle Highlands ES	1st floor inside Vestibule 2131 (high)	12/11/15	< 1		
RH-1211-15B	Randle Highlands ES	1st floor inside Vestibule 2131 (high)	12/11/15	< 1		
RH-1211-16A	Randle Highlands ES	1st floor inside Vestibule 2131 (low)	12/11/15	< 1		
RH-1211-16B	Randle Highlands ES	1st floor inside Vestibule 2131 (low)	12/11/15	< 1		
RH-1211-17A	Randle Highlands ES	Ground floor hallway adjacent to Custodian Closet 2014 (high)	12/11/15	< 1		
RH-1211-17B	Randle Highlands ES	Ground floor hallway adjacent to Custodian Closet 2014 (high)	12/11/15	< 1		
RH-1211-18A	Randle Highlands ES	Ground floor hallway adjacent to Custodian Closet 2014 (low)	12/11/15	< 1		
RH-1211-18B	Randle Highlands ES	Ground floor hallway adjacent to Custodian Closet 2014 (low)	12/11/15	< 1		
RH-1211-19A	Randle Highlands ES	Ground floor inside Vestibule 2031 (high)	12/11/15	< 1		
RH-1211-19B	Randle Highlands ES	Ground floor inside Vestibule 2031 (high)	12/11/15	< 1		
RH-1211-20A	Randle Highlands ES	Ground floor inside Vestibule 2031 (low)	12/11/15	< 1		
RH-1211-20B	Randle Highlands ES	Ground floor inside Vestibule 2031 (low)	12/11/15	< 1		
RH-1211-21A	Randle Highlands ES	Ground floor inside Vestibule 2026 (high)	12/11/15	< 1		
RH-1211-21B	Randle Highlands ES	Ground floor inside Vestibule 2026 (high)	12/11/15	< 1		
RH-1211-22A	Randle Highlands ES	Ground floor inside Vestibule 2026 (low)	12/11/15	< 1		
RH-1211-22B	Randle Highlands ES	Ground floor inside Vestibule 2026 (low)	12/11/15	< 1		
RH-1211-23A	Randle Highlands ES	Ground floor inside Vestibule 2021 (high)	12/11/15	< 1		
RH-1211-23B	Randle Highlands ES	Ground floor inside Vestibule 2021 (high)	12/11/15	< 1		
RH-1211-24A	Randle Highlands ES	Ground floor inside Vestibule 2021 (low)	12/11/15	< 1		
RH-1211-24B	Randle Highlands ES	Ground floor inside Vestibule 2031 (low)	12/11/15	< 1		
RH-1211-25A	Randle Highlands ES	Basement floor hallway adjacent to Custodian Closet 2B14 (high)	12/11/15	< 1		
RH-1211-25B	Randle Highlands ES	Basement floor hallway adjacent to Custodian Closet 2B14 (high)	12/11/15	< 1		
RH-1211-26A	Randle Highlands ES	Basement floor hallway adjacent to Custodian Closet 2B14 (low)	12/11/15	< 1		
RH-1211-26B	Randle Highlands ES	Basement floor hallway adjacent to Custodian Closet 2B14 (low)	12/11/15	< 1		
RH-1211-27A	Randle Highlands ES	Basement floor inside Vestibule 2B31 (high)	12/11/15	< 1		
RH-1211-27B	Randle Highlands ES	Basement floor inside Vestibule 2B31 (high)	12/11/15	< 1		
RH-1211-28A	Randle Highlands ES	Basement floor inside Vestibule 2B31 (low)	12/11/15	< 1		
RH-1211-28B	Randle Highlands ES	Basement floor inside Vestibule 2B31 (low)	12/11/15	< 1		
RH-1211-29A	Randle Highlands ES	Basement floor inside Vestibule 2B26 (low)	12/11/15	< 1		
RH-1211-29B	Randle Highlands ES	Basement floor inside Vestibule 2B26 (low)	12/11/15	< 1		
RH-1211-30A	Randle Highlands ES	Basement floor inside Vestibule 2B21 (high)	12/11/15	< 1		
RH-1211-30B	Randle Highlands ES	Basement floor inside Vestibule 2B21 (high)	12/11/15	< 1		
RH-1211-31A	Randle Highlands ES	Basement floor inside Vestibule 2B21 (low)	12/11/15	< 1		
RH-1211-31B	Randle Highlands ES	Basement floor inside Vestibule 2B21 (low)	12/11/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
REC-0225-1A	Raymond EC	3rd floor hallway adjacent to Classroom 30	2/25/16	< 1		
REC-0225-1B	Raymond EC	3rd floor hallway adjacent to Classroom 30	2/25/16	< 1		
REC-0225-2A	Raymond EC	2nd floor hallway adjacent to Classroom 22	2/25/16	< 1		
REC-0225-2B	Raymond EC	2nd floor hallway adjacent to Classroom 22	2/25/16	< 1		
REC-0225-3A	Raymond EC	2nd floor hallway across from Classroom 209	2/25/16	< 1		
REC-0225-3B	Raymond EC	2nd floor hallway across from Classroom 209	2/25/16	< 1		
REC-0225-4A	Raymond EC	2nd floor hallway across from Classroom 217	2/25/16	< 1		
REC-0225-4B	Raymond EC	2nd floor hallway across from Classroom 217	2/25/16	< 1		
REC-0225-5A	Raymond EC	1st floor inside Classroom 116	2/25/16	< 1		
REC-0225-5B	Raymond EC	1st floor inside Classroom 116	2/25/16	< 1		
REC-0225-6A	Raymond EC	1st floor inside Classroom 117	2/25/16	< 1		
REC-0225-6B	Raymond EC	1st floor inside Classroom 117	2/25/16	< 1		
REC-0225-7A	Raymond EC	1st floor hallway across from Classroom 115	2/25/16	< 1		
REC-0225-7B	Raymond EC	1st floor hallway across from Classroom 115	2/25/16	< 1		
REC-0225-8A	Raymond EC	1st floor inside Classroom 115	2/25/16	< 1		
REC-0225-8B	Raymond EC	1st floor inside Classroom 115	2/25/16	< 1		
REC-0225-9A	Raymond EC	1st floor inside Classroom 113	2/25/16	< 1		
REC-0225-9B	Raymond EC	1st floor inside Classroom 113	2/25/16	< 1		
REC-0225-10A	Raymond EC	1st floor inside Classroom 110	2/25/16	< 1		
REC-0225-10B	Raymond EC	1st floor inside Classroom 110	2/25/16	< 1		
REC-0225-11A	Raymond EC	1st floor inside Classroom 111	2/25/16	< 1		
REC-0225-11B	Raymond EC	1st floor inside Classroom 111	2/25/16	< 1		
REC-0225-12A	Raymond EC	1st floor hallway across from Classroom 109	2/25/16	2.8		
REC-0225-12B	Raymond EC	1st floor hallway across from Classroom 109	2/25/16	4.1		
REC-0225-13A	Raymond EC	1st floor hallway adjacent to Health Suite	2/25/16	< 1		
REC-0225-13B	Raymond EC	1st floor hallway adjacent to Health Suite	2/25/16	< 1		
REC-0225-14A	Raymond EC	1st floor hallway across from Kitchen	2/25/16	< 1		
REC-0225-14B	Raymond EC	1st floor hallway across from Kitchen	2/25/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
RT-1007-1A	River Terrace EC	1st floor inside Cafeteria 129 (high)	10/7/15	< 1		
RT-1007-1B	River Terrace EC	1st floor inside Cafeteria 129 (high)	10/7/15	< 1		
RT-1007-2A	River Terrace EC	1st floor inside Cafeteria 129 (low)	10/7/15	< 1		
RT-1007-2B	River Terrace EC	1st floor inside Cafeteria 129 (low)	10/7/15	< 1		
RT-1007-3A	River Terrace EC	1st floor hallway adjacent to Custodian Closet 123 (high)	10/7/15	< 1		
RT-1007-3B	River Terrace EC	1st floor hallway adjacent to Custodian Closet 123 (high)	10/7/15	< 1		
RT-1007-4A	River Terrace EC	1st floor hallway adjacent to Custodian Closet 123 (low)	10/7/15	< 1		
RT-1007-4B	River Terrace EC	1st floor hallway adjacent to Custodian Closet 123 (low)	10/7/15	< 1		
RT-1007-5A	River Terrace EC	1st floor inside Classroom 138	10/7/15	< 1		
RT-1007-5B	River Terrace EC	1st floor inside Classroom 138	10/7/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
RT-1007-6A	River Terrace EC	1st floor inside Classroom 136	10/7/15	< 1		
RT-1007-6B	River Terrace EC	1st floor inside Classroom 136	10/7/15	< 1		
RT-1007-7A	River Terrace EC	1st floor inside Classroom 124	10/7/15	< 1		
RT-1007-7B	River Terrace EC	1st floor inside Classroom 124	10/7/15	< 1		
RT-1007-8A	River Terrace EC	1st floor hallway across from Media Center 130 (high)	10/7/15	< 1		
RT-1007-8B	River Terrace EC	1st floor hallway across from Media Center 130 (high)	10/7/15	< 1		
RT-1007-9A	River Terrace EC	1st floor hallway across from Media Center 130 (low)	10/7/15	< 1		
RT-1007-9B	River Terrace EC	1st floor hallway across from Media Center 130 (low)	10/7/15	< 1		
RT-1007-10A	River Terrace EC	1st floor inside Classroom 126	10/7/15	< 1		
RT-1007-10B	River Terrace EC	1st floor inside Classroom 126	10/7/15	< 1		
RT-1007-11A	River Terrace EC	1st floor inside Classroom 120	10/7/15	< 1		
RT-1007-11B	River Terrace EC	1st floor inside Classroom 120	10/7/15	< 1		
RT-1007-12A	River Terrace EC	1st floor inside Classroom 118	10/7/15	< 1		
RT-1007-12B	River Terrace EC	1st floor inside Classroom 118	10/7/15	< 1		
RT-1007-13A	River Terrace EC	1st floor inside Classroom 114	10/7/15	< 1		
RT-1007-13B	River Terrace EC	1st floor inside Classroom 114	10/7/15	< 1		
RT-1007-14A	River Terrace EC	1st floor inside Classroom 112	10/7/15	1.1		
RT-1007-14B	River Terrace EC	1st floor inside Classroom 112	10/7/15	< 1		
RT-1007-15A	River Terrace EC	1st floor inside Classroom 110	10/7/15	< 1		
RT-1007-15B	River Terrace EC	1st floor inside Classroom 110	10/7/15	< 1		
RT-1007-16A	River Terrace EC	1st floor inside Pool Area 106 (high)	10/7/15	< 1		
RT-1007-16B	River Terrace EC	1st floor inside Pool Area 106 (high)	10/7/15	< 1		
RT-1007-17A	River Terrace EC	1st floor inside Pool Area 106 (low)	10/7/15	< 1		
RT-1007-17B	River Terrace EC	1st floor inside Pool Area 106 (low)	10/7/15	< 1		
RT-1007-18A	River Terrace EC	1st floor hallway adjacent to Health Suite 104-A (high)	10/7/15	< 1		
RT-1007-18B	River Terrace EC	1st floor hallway adjacent to Health Suite 104-A (high)	10/7/15	< 1		
RT-1007-19A	River Terrace EC	1st floor hallway adjacent to Health Suite 104-A (low)	10/7/15	< 1		
RT-1007-19B	River Terrace EC	1st floor hallway adjacent to Health Suite 104-A (low)	10/7/15	< 1		
RT-1007-20A	River Terrace EC	1st floor inside Classroom 107	10/7/15	< 1		
RT-1007-20B	River Terrace EC	1st floor inside Classroom 107	10/7/15	< 1		
RT-1007-21A	River Terrace EC	1st floor inside Classroom 109	10/7/15	< 1		
RT-1007-21B	River Terrace EC	1st floor inside Classroom 109	10/7/15	< 1		
RT-1007-22A	River Terrace EC	1st floor inside Classroom 111	10/7/15	< 1		
RT-1007-22B	River Terrace EC	1st floor inside Classroom 111	10/7/15	< 1		
RT-1007-23A	River Terrace EC	1st floor inside Classroom 113	10/7/15	< 1		
RT-1007-23B	River Terrace EC	1st floor inside Classroom 113	10/7/15	< 1		
RT-1007-24A	River Terrace EC	1st floor inside Classroom 115	10/7/15	< 1		
RT-1007-24B	River Terrace EC	1st floor inside Classroom 115	10/7/15	< 1		
RT-1007-25A	River Terrace EC	1st floor inside Classroom 117	10/7/15	< 1		
RT-1007-25B	River Terrace EC	1st floor inside Classroom 117	10/7/15	< 1		
RT-1007-26A	River Terrace EC	1st floor inside Classroom 146	10/7/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
RT-1007-26B	River Terrace EC	1st floor inside Classroom 146	10/7/15	< 1		
RT-1007-27A	River Terrace EC	1st floor inside Classroom 142	10/7/15	< 1		
RT-1007-27B	River Terrace EC	1st floor inside Classroom 142	10/7/15	< 1		
RT-1007-28A	River Terrace EC	1st floor inside Classroom 144	10/7/15	1.4		
RT-1007-28B	River Terrace EC	1st floor inside Classroom 144	10/7/15	1.4		
RT-1007-29A	River Terrace EC	1st floor inside Classroom 122	10/7/15	< 1		
RT-1007-29B	River Terrace EC	1st floor inside Classroom 122	10/7/15	< 1		
RT-1007-30A	River Terrace EC	1st floor inside Classroom 116	10/7/15	1.4		
RT-1007-30B	River Terrace EC	1st floor inside Classroom 116	10/7/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
RES-0127-1A	Ross ES	2nd floor hallway across from Classroom 205 (high)	1/27/16	< 1		
RES-0127-1B	Ross ES	2nd floor hallway across from Classroom 205 (high)	1/27/16	< 1		
RES-0127-2A	Ross ES	2nd floor hallway across from Classroom 205 (low)	1/27/16	< 1		
RES-0127-2B	Ross ES	2nd floor hallway across from Classroom 205 (low)	1/27/16	< 1		
RES-0127-3A	Ross ES	1st floor hallway across from Classroom 106 (high)	1/27/16	< 1		
RES-0127-3B	Ross ES	1st floor hallway across from Classroom 106 (high)	1/27/16	< 1		
RES-0127-4A	Ross ES	1st floor hallway across from Classroom 106 (low)	1/27/16	< 1		
RES-0127-4B	Ross ES	1st floor hallway across from Classroom 106 (low)	1/27/16	< 1		
RES-0127-5A	Ross ES	Basement floor hallway across from Main Office B07 (high)	1/27/16	< 1		
RES-0127-5B	Ross ES	Basement floor hallway across from Main Office B07 (high)	1/27/16	< 1		
RES-0127-6A	Ross ES	Basement floor hallway across from Main Office B07 (low)	1/27/16	< 1		
RES-0127-6B	Ross ES	Basement floor hallway across from Main Office B07 (low)	1/27/16	< 1		
RES-0127-7A	Ross ES	Basement floor inside Dining Area B11 (high)	1/27/16	< 1		
RES-0127-7B	Ross ES	Basement floor inside Dining Area B11 (high)	1/27/16	< 1		
RES-0127-8A	Ross ES	Basement floor inside Dining Area B11 (low)	1/27/16	< 1		
RES-0127-8B	Ross ES	Basement floor inside Dining Area B11 (low)	1/27/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SES-1209-1A	Savoy ES	3rd floor hallway adjacent to Storage Room (high)	12/9/15	< 1		
SES-1209-1B	Savoy ES	3rd floor hallway adjacent to Storage Room (high)	12/9/15	< 1		
SES-1209-2A	Savoy ES	3rd floor hallway adjacent to Storage Room (low)	12/9/15	< 1		
SES-1209-2B	Savoy ES	3rd floor hallway adjacent to Storage Room (low)	12/9/15	< 1		
SES-1209-3A	Savoy ES	3rd floor hallway adjacent to Art Room 306 (high)	12/9/15	< 1		
SES-1209-3B	Savoy ES	3rd floor hallway adjacent to Art Room 306 (high)	12/9/15	< 1		
SES-1209-4A	Savoy ES	3rd floor hallway adjacent to Art Room 306 (low)	12/9/15	< 1		
SES-1209-4B	Savoy ES	3rd floor hallway adjacent to Art Room 306 (low)	12/9/15	< 1		
SES-1209-5A	Savoy ES	2nd floor hallway adjacent to Teacher's Lounge 203 (high)	12/9/15	< 1		
SES-1209-5B	Savoy ES	2nd floor hallway adjacent to Teacher's Lounge 203 (high)	12/9/15	< 1		
SES-1209-6A	Savoy ES	2nd floor hallway adjacent to Teacher's Lounge 203 (low)	12/9/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
SES-1209-6B	Savoy ES	2nd floor hallway adjacent to Teacher's Lounge 203 (low)	12/9/15	< 1		
SES-1209-7A	Savoy ES	2nd floor hallway adjacent to Classroom 208 (high)	12/9/15	< 1		
SES-1209-7B	Savoy ES	2nd floor hallway adjacent to Classroom 208 (high)	12/9/15	< 1		
SES-1209-8A	Savoy ES	2nd floor hallway adjacent to Classroom 208 (low)	12/9/15	< 1		
SES-1209-8B	Savoy ES	2nd floor hallway adjacent to Classroom 208 (low)	12/9/15	< 1		
SES-1209-9A	Savoy ES	2nd floor inside Library (high)	12/9/15	< 1		
SES-1209-9B	Savoy ES	2nd floor inside Library (high)	12/9/15	< 1		
SES-1209-10A	Savoy ES	2nd floor inside Library (low)	12/9/15	< 1		
SES-1209-10B	Savoy ES	2nd floor inside Library (low)	12/9/15	< 1		
SES-1209-11A	Savoy ES	1st floor hallway between Boy's and Girl's Rooms (high)	12/9/15	< 1		
SES-1209-11B	Savoy ES	1st floor hallway between Boy's and Girl's Rooms (high)	12/9/15	< 1		
SES-1209-12A	Savoy ES	1st floor hallway between Boy's and Girl's Rooms (low)	12/9/15	< 1		
SES-1209-12B	Savoy ES	1st floor hallway between Boy's and Girl's Rooms (low)	12/9/15	< 1		
SES-1209-13A	Savoy ES	1st floor hallway at entrance to Gym (high)	12/9/15	< 1		
SES-1209-13B	Savoy ES	1st floor hallway at entrance to Gym (high)	12/9/15	< 1		
SES-1209-14A	Savoy ES	1st floor hallway at entrance to Gym (low)	12/9/15	< 1		
SES-1209-14B	Savoy ES	1st floor hallway at entrance to Gym (low)	12/9/15	< 1		
SES-1209-15A	Savoy ES	1st floor inside Classroom 109	12/9/15	< 1		
SES-1209-15B	Savoy ES	1st floor inside Classroom 109	12/9/15	< 1		
SES-1209-16A	Savoy ES	1st floor inside Classroom 111	12/9/15	< 1		
SES-1209-16B	Savoy ES	1st floor inside Classroom 111	12/9/15	< 1		
SES-1209-17A	Savoy ES	1st floor inside Classroom 113	12/9/15	< 1		
SES-1209-17B	Savoy ES	1st floor inside Classroom 113	12/9/15	< 1		
SES-1209-18A	Savoy ES	1st floor inside Classroom 120	12/9/15	< 1		
SES-1209-18B	Savoy ES	1st floor inside Classroom 120	12/9/15	< 1		
SES-1209-19A	Savoy ES	1st floor inside Classroom 115	12/9/15	< 1		
SES-1209-19B	Savoy ES	1st floor inside Classroom 115	12/9/15	< 1		
SES-1209-20A	Savoy ES	1st floor inside Classroom 122	12/9/15	< 1		
SES-1209-20B	Savoy ES	1st floor inside Classroom 122	12/9/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SWS-1029-1A	School Within A School @ Goding	4th floor hallway across from Classroom 408	10/29/15	< 1		
SWS-1029-1B	School Within A School @ Goding	4th floor hallway across from Classroom 408	10/29/15	1.1		
SWS-1029-2A	School Within A School @ Goding	4th floor hallway adjacent to Classroom 403	10/29/15	< 1		
SWS-1029-2B	School Within A School @ Goding	4th floor hallway adjacent to Classroom 403	10/29/15	< 1		
SWS-1029-3A	School Within A School @ Goding	3rd floor hallway adjacent to Classroom 303	10/29/15	< 1		
SWS-1029-3B	School Within A School @ Goding	3rd floor hallway adjacent to Classroom 303	10/29/15	< 1		
SWS-1029-4A	School Within A School @ Goding	3rd floor hallway across from Classroom 308	10/29/15	< 1		
SWS-1029-4B	School Within A School @ Goding	3rd floor hallway across from Classroom 308	10/29/15	< 1		
SWS-1029-5A	School Within A School @ Goding	2nd floor hallway across from Classroom 206	10/29/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
SWS-1029-5B	School Within A School @ Goding	2nd floor hallway across from Classroom 206	10/29/15	< 1		
SWS-1029-6A	School Within A School @ Goding	2nd floor hallway adjacent to Classroom 203	10/29/15	< 1		
SWS-1029-6B	School Within A School @ Goding	2nd floor hallway adjacent to Classroom 203	10/29/15	< 1		
SWS-1029-7A	School Within A School @ Goding	1st floor hallway adjacent to Classroom 103	10/29/15	1.6		
SWS-1029-7B	School Within A School @ Goding	1st floor hallway adjacent to Classroom 103	10/29/15	1		
SWS-1029-8A	School Within A School @ Goding	1st floor hallway adjacent to Custodian Closet	10/29/15	< 1		
SWS-1029-8B	School Within A School @ Goding	1st floor hallway adjacent to Custodian Closet	10/29/15	1.4		
SWS-1029-9A	School Within A School @ Goding	Basement floor inside Cafeteria	10/29/15	1.6		
SWS-1029-9B	School Within A School @ Goding	Basement floor inside Cafeteria	10/29/15	1.7		
SWS-1029-10A	School Within A School @ Goding	Basement floor hallway adjacent to Custodian Closet	10/29/15	< 1		
SWS-1029-10B	School Within A School @ Goding	Basement floor hallway adjacent to Custodian Closet	10/29/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SWW-0309-1A	School Without Walls HS	3rd floor hallway between Men's and Women's Restrooms (high)	3/9/16	< 1		
SWW-0309-1B	School Without Walls HS	3rd floor hallway between Men's and Women's Restrooms (high)	3/9/16	< 1		
SWW-0309-2A	School Without Walls HS	3rd floor hallway between Men's and Women's Restrooms (low)	3/9/16	< 1		
SWW-0309-2B	School Without Walls HS	3rd floor hallway between Men's and Women's Restrooms (low)	3/9/16	< 1		
SWW-0309-3A	School Without Walls HS	2nd floor hallway between Men's and Women's Restrooms (high)	3/9/16	< 1		
SWW-0309-3B	School Without Walls HS	2nd floor hallway between Men's and Women's Restrooms (high)	3/9/16	< 1		
SWW-0309-4A	School Without Walls HS	2nd floor hallway between Men's and Women's Restrooms (low)	3/9/16	< 1		
SWW-0309-4B	School Without Walls HS	2nd floor hallway between Men's and Women's Restrooms (low)	3/9/16	< 1		
SWW-0309-5A	School Without Walls HS	1st floor hallway between Men's and Women's Restrooms (high)	3/9/16	< 1		
SWW-0309-5B	School Without Walls HS	1st floor hallway between Men's and Women's Restrooms (high)	3/9/16	< 1		
SWW-0309-6A	School Without Walls HS	1st floor hallway between Men's and Women's Restrooms (low)	3/9/16	< 1		
SWW-0309-6B	School Without Walls HS	1st floor hallway between Men's and Women's Restrooms (low)	3/9/16	< 1		
SWW-0309-7A	School Without Walls HS	Lower Level hallway across from elevator (high)	3/9/16	< 1		
SWW-0309-7B	School Without Walls HS	Lower Level hallway across from elevator (high)	3/9/16	< 1		
SWW-0309-8A	School Without Walls HS	Lower Level hallway across from elevator (low)	3/9/16	< 1		
SWW-0309-8B	School Without Walls HS	Lower Level hallway across from elevator (low)	3/9/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
	Seaton ES					
	Seaton ES					
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SES-1201-1A	Shepherd ES	2nd floor hallway adjacent to Classroom A210	12/1/15	< 1		
SES-1201-1B	Shepherd ES	2nd floor hallway adjacent to Classroom A210	12/1/15	< 1		
SES-1201-2A	Shepherd ES	1st floor hallway adjacent to Classroom A104	12/1/15	< 1		
SES-1201-2B	Shepherd ES	1st floor hallway adjacent to Classroom A104	12/1/15	< 1		
SES-1201-3A	Shepherd ES	Basement floor in Cafeteria	12/1/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
SES-1201-3B	Shepherd ES	Basement floor in Cafeteria	12/1/15	< 1		
SES-1201-4A	Shepherd ES	Basement floor in Teacher's Lounge next to Boiler Room	12/1/15	< 1		
SES-1201-4B	Shepherd ES	Basement floor in Teacher's Lounge next to Boiler Room	12/1/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SES-1208-1A	Simon ES	3rd floor hallway adjacent to Janitor's Closet 309	12/8/15	< 1		
SES-1208-1B	Simon ES	3rd floor hallway adjacent to Janitor's Closet 309	12/8/15	< 1		
SES-1208-2A	Simon ES	3rd floor hallway adjacent to Storage Room 305	12/8/15	< 1		
SES-1208-2B	Simon ES	3rd floor hallway adjacent to Storage Room 305	12/8/15	< 1		
SES-1208-3A	Simon ES	2nd floor hallway adjacent to Janitor's Closet 205	12/8/15	< 1		
SES-1208-3B	Simon ES	2nd floor hallway adjacent to Janitor's Closet 205	12/8/15	< 1		
SES-1208-4A	Simon ES	2nd floor hallway adjacent to Janitor's Closet 211	12/8/15	< 1		
SES-1208-4B	Simon ES	2nd floor hallway adjacent to Janitor's Closet 211	12/8/15	< 1		
SES-1208-5A	Simon ES	1st floor hallway adjacent to Janitor's Closet 116	12/8/15	< 1		
SES-1208-5B	Simon ES	1st floor hallway adjacent to Janitor's Closet 116	12/8/15	< 1		
SES-1208-6A	Simon ES	1st floor hallway adjacent to Storage Room 105	12/8/15	< 1		
SES-1208-6B	Simon ES	1st floor hallway adjacent to Storage Room 105	12/8/15	< 1		
SES-1208-7A	Simon ES	Ground floor hallway adjacent to Teacher's Lounge 003	12/8/15	< 1		
SES-1208-7B	Simon ES	Ground floor hallway adjacent to Teacher's Lounge 003	12/8/15	< 1		
SES-1208-8A	Simon ES	Ground floor hallway adjacent to Health Suite 013	12/8/15	< 1		
SES-1208-8B	Simon ES	Ground floor hallway adjacent to Health Suite 013	12/8/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SES-1009-1A	Smothers ES	3rd floor hallway adjacent to Classroom 301	10/9/15	< 1		
SES-1009-1B	Smothers ES	3rd floor hallway adjacent to Classroom 301	10/9/15	< 1		
SES-1009-2A	Smothers ES	3rd floor hallway adjacent to Classroom 310	10/9/15	< 1		
SES-1009-2B	Smothers ES	3rd floor hallway adjacent to Classroom 310	10/9/15	< 1		
SES-1009-3A	Smothers ES	2nd floor hallway adjacent to Art Room 201	10/9/15	< 1		
SES-1009-3B	Smothers ES	2nd floor hallway adjacent to Art Room 201	10/9/15	< 1		
SES-1009-4A	Smothers ES	2nd floor hallway adjacent to Library 212	10/9/15	< 1		
SES-1009-4B	Smothers ES	2nd floor hallway adjacent to Library 212	10/9/15	< 1		
SES-1009-5A	Smothers ES	1st floor hallway adjacent to Classroom 104	10/9/15	< 1		
SES-1009-5B	Smothers ES	1st floor hallway adjacent to Classroom 104	10/9/15	< 1		
SES-1009-6A	Smothers ES	1st floor hallway across from Classroom 111	10/9/15	< 1		
SES-1009-6B	Smothers ES	1st floor hallway across from Classroom 111	10/9/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SMS-1222-1A	Sousa MS	3rd floor hallway adjacent to Classroom C 301	12/22/15	< 1		
SMS-1222-1B	Sousa MS	3rd floor hallway adjacent to Classroom C 301	12/22/15	< 1		
SMS-1222-2A	Sousa MS	3rd floor inside Science Room B304 (Window side, right) (1)	12/22/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
SMS-1222-2B	Sousa MS	3rd floor inside Science Room B304 (Window side, right) (1)	12/22/15	< 1		
SMS-1222-3A	Sousa MS	3rd floor inside Science Room B304 (other side, from left) (2)	12/22/15	< 1		
SMS-1222-3B	Sousa MS	3rd floor inside Science Room B304 (other side, from left) (2)	12/22/15	< 1		
SMS-1222-4A	Sousa MS	3rd floor inside Science Room B304 (3)	12/22/15	< 1		
SMS-1222-4B	Sousa MS	3rd floor inside Science Room B304 (3)	12/22/15	< 1		
SMS-1222-5A	Sousa MS	3rd floor inside Science Room B304 (4)	12/22/15	< 1		
SMS-1222-5B	Sousa MS	3rd floor inside Science Room B304 (4)	12/22/15	< 1		
SMS-1222-6A	Sousa MS	3rd floor inside Science Room B304 (5)	12/22/15	< 1		
SMS-1222-6B	Sousa MS	3rd floor inside Science Room B304 (5)	12/22/15	< 1		
SMS-1222-7A	Sousa MS	3rd floor hallway adjacent to Classroom A301 (high)	12/22/15	< 1		
SMS-1222-7B	Sousa MS	3rd floor hallway adjacent to Classroom A301 (high)	12/22/15	< 1		
SMS-1222-8A	Sousa MS	3rd floor hallway adjacent to Classroom A301 (low)	12/22/15	< 1		
SMS-1222-8B	Sousa MS	3rd floor hallway adjacent to Classroom A301 (low)	12/22/15	< 1		
SMS-1222-9A	Sousa MS	3rd floor inside Science Room A309 (Window side, left) (1)	12/22/15	< 1		
SMS-1222-9B	Sousa MS	3rd floor inside Science Room A309 (Window side, left) (1)	12/22/15	< 1		
SMS-1222-10A	Sousa MS	3rd floor inside Science Room A309 (Window side, right) (2)	12/22/15	< 1		
SMS-1222-10B	Sousa MS	3rd floor inside Science Room A309 (Window side, right) (2)	12/22/15	< 1		
SMS-1222-11A	Sousa MS	3rd floor inside Science Room A309 (other side, left) (3)	12/22/15	5.8		
SMS-1222-11B	Sousa MS	3rd floor inside Science Room A309 (other side, left) (3)	12/22/15	< 1		
SMS-1222-12A	Sousa MS	3rd floor inside Science Room A309 (other side, right) (4)	12/22/15	< 1		
SMS-1222-12B	Sousa MS	3rd floor inside Science Room A309 (other side, right) (4)	12/22/15	< 1		
SMS-1222-13A	Sousa MS	2nd floor hallway adjacent to Classroom C201 (high)	12/22/15	< 1		
SMS-1222-13B	Sousa MS	2nd floor hallway adjacent to Classroom C201 (high)	12/22/15	< 1		
SMS-1222-14A	Sousa MS	2nd floor hallway adjacent to Classroom C201 (low)	12/22/15	< 1		
SMS-1222-14B	Sousa MS	2nd floor hallway adjacent to Classroom C201 (low)	12/22/15	< 1		
SMS-1222-15A	Sousa MS	2nd floor inside Science Room B204 (Window side, left) (1)	12/22/15	< 1		
SMS-1222-15B	Sousa MS	2nd floor inside Science Room B204 (Window side, left) (1)	12/22/15	< 1		
SMS-1222-16A	Sousa MS	2nd floor inside Science Room B204 (Window side, right) (2)	12/22/15	< 1		
SMS-1222-16B	Sousa MS	2nd floor inside Science Room B204 (Window side, right) (2)	12/22/15	< 1		
SMS-1222-17A	Sousa MS	2nd floor inside Science Room B204 (other side, from left) (3)	12/22/15	< 1		
SMS-1222-17B	Sousa MS	2nd floor inside Science Room B204 (other side, from left) (3)	12/22/15	< 1		
SMS-1222-18A	Sousa MS	2nd floor inside Science Room B204 (4)	12/22/15	< 1		
SMS-1222-18B	Sousa MS	2nd floor inside Science Room B204 (4)	12/22/15	< 1		
SMS-1222-19A	Sousa MS	2nd floor inside Science Room B204 (5)	12/22/15	< 1		
SMS-1222-19B	Sousa MS	2nd floor inside Science Room B204 (5)	12/22/15	< 1		
SMS-1222-20A	Sousa MS	2nd floor inside Science Room B204 (6)	12/22/15	< 1		
SMS-1222-20B	Sousa MS	2nd floor inside Science Room B204 (6)	12/22/15	< 1		
SMS-1222-21A	Sousa MS	2nd floor hallway adjacent to Classroom A201 (high)	12/22/15	< 1		
SMS-1222-21B	Sousa MS	2nd floor hallway adjacent to Classroom A201 (high)	12/22/15	< 1		
SMS-1222-22A	Sousa MS	2nd floor hallway adjacent to Classroom A201 (low)	12/22/15	< 1		
SMS-1222-22B	Sousa MS	2nd floor hallway adjacent to Classroom A201 (low)	12/22/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
SMS-1222-23A	Sousa MS	2nd floor inside Science Room A209 (Window side, left) (1)	12/22/15	< 1		
SMS-1222-23B	Sousa MS	2nd floor inside Science Room A209 (Window side, left) (1)	12/22/15	< 1		
SMS-1222-24A	Sousa MS	2nd floor inside Science Room A209 (Window side, right) (2)	12/22/15	< 1		
SMS-1222-24B	Sousa MS	2nd floor inside Science Room A209 (Window side, right) (2)	12/22/15	< 1		
SMS-1222-25A	Sousa MS	2nd floor inside Science Room A209 (other side, from left) (3)	12/22/15	< 1		
SMS-1222-25B	Sousa MS	2nd floor inside Science Room A209 (other side, from left) (3)	12/22/15	< 1		
SMS-1222-26A	Sousa MS	2nd floor inside Science Room A209 (4)	12/22/15	2.5		
SMS-1222-26B	Sousa MS	2nd floor inside Science Room A209 (4)	12/22/15	< 1		
SMS-1222-27A	Sousa MS	2nd floor inside Science Room A209 (5)	12/22/15	< 1		
SMS-1222-27B	Sousa MS	2nd floor inside Science Room A209 (5)	12/22/15	< 1		
SMS-1222-28A	Sousa MS	2nd floor inside Science Room A209 (6)	12/22/15	< 1		
SMS-1222-28B	Sousa MS	2nd floor inside Science Room A209 (6)	12/22/15	< 1		
SMS-1222-29A	Sousa MS	1st floor hallway adjacent to Classroom C101 (high)	12/22/15	< 1		
SMS-1222-29B	Sousa MS	1st floor hallway adjacent to Classroom C101 (high)	12/22/15	< 1		
SMS-1222-30A	Sousa MS	1st floor hallway adjacent to Classroom C101 (low)	12/22/15	< 1		
SMS-1222-30B	Sousa MS	1st floor hallway adjacent to Classroom C101 (low)	12/22/15	< 1		
SMS-1222-31A	Sousa MS	1st floor hallway adjacent to Classroom A101 (high)	12/22/15	< 1		
SMS-1222-31B	Sousa MS	1st floor hallway adjacent to Classroom A101 (high)	12/22/15	< 1		
SMS-1222-32A	Sousa MS	1st floor hallway adjacent to Classroom A101 (low)	12/22/15	< 1		
SMS-1222-32B	Sousa MS	1st floor hallway adjacent to Classroom A101 (low)	12/22/15	< 1		
SMS-1222-33A	Sousa MS	1st floor inside Science Room B104 (Window side, left) (1)	12/22/15	< 1		
SMS-1222-33B	Sousa MS	1st floor inside Science Room B104 (Window side, left) (1)	12/22/15	< 1		
SMS-1222-34A	Sousa MS	1st floor inside Science Room B104 (Window side, right) (2)	12/22/15	< 1		
SMS-1222-34B	Sousa MS	1st floor inside Science Room B104 (window side, right t) (2)	12/22/15	< 1		
SMS-1222-35A	Sousa MS	1st floor inside Science Room B104 (other side, from left) (3)	12/22/15	4.6		
SMS-1222-35B	Sousa MS	1st floor inside Science Room B104 (other side, from left) (3)	12/22/15	< 1		
SMS-1222-36A	Sousa MS	1st floor inside Science Room B104 (4)	12/22/15	< 1		
SMS-1222-36B	Sousa MS	1st floor inside Science Room B104 (4)	12/22/15	< 1		
SMS-1222-37A	Sousa MS	1st floor inside Science Room B104 (5)	12/22/15	< 1		
SMS-1222-37B	Sousa MS	1st floor inside Science Room B104 (5)	12/22/15	< 1		
SMS-1222-38A	Sousa MS	1st floor inside Science Room A109 (Window side, left) (1)	12/22/15	2.3		
SMS-1222-38B	Sousa MS	1st floor inside Science Room A109 (Window side, left) (1)	12/22/15	< 1		
SMS-1222-39A	Sousa MS	1st floor inside Science Room A109 (Window side, right) (2)	12/22/15	< 1		
SMS-1222-39B	Sousa MS	1st floor inside Science Room A109 (Window side, right) (2)	12/22/15	< 1		
SMS-1222-40A	Sousa MS	1st floor inside Science Room A109 (other side, left) (3)	12/22/15	1.8		
SMS-1222-40B	Sousa MS	1st floor inside Science Room A109 (other side, left) (3)	12/22/15	< 1		
SMS-1222-41A	Sousa MS	1st floor inside Science Room A109 (other side, from left) (4)	12/22/15	2.5		
SMS-1222-41B	Sousa MS	1st floor inside Science Room A109 (4)	12/22/15	< 1		
SMS-1222-42A	Sousa MS	1st floor inside Science Room A109 (5)	12/22/15	< 1		
SMS-1222-42B	Sousa MS	1st floor inside Science Room A109 (5)	12/22/15	< 1		
SMS-1222-43A	Sousa MS	1st floor inside Science Room A109 (6)	12/22/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
SMS-1222-43B	Sousa MS	1st floor inside Science Room A109 (6)	12/22/15	< 1		
SMS-1222-44A	Sousa MS	1st floor hallway adjacent to Health Suite B122 (high)	12/22/15	< 1		
SMS-1222-44B	Sousa MS	1st floor hallway adjacent to Health Suite B122 (high)	12/22/15	< 1		
SMS-1222-45A	Sousa MS	1st floor hallway adjacent to Health Suite B122 (low)	12/22/15	< 1		
SMS-1222-45B	Sousa MS	1st floor hallway adjacent to Health Suite B122 (low)	12/22/15	< 1		
SMS-1222-46A	Sousa MS	1st floor hallway adjacent to Gym D111 (high)	12/22/15	< 1		
SMS-1222-46B	Sousa MS	1st floor hallway adjacent to Gym D111 (high)	12/22/15	< 1		
SMS-1222-47A	Sousa MS	1st floor hallway adjacent to Gym D111 (low)	12/22/15	< 1		
SMS-1222-47B	Sousa MS	1st floor hallway adjacent to Gym D111 (low)	12/22/15	< 1		
SMS-1222-48A	Sousa MS	1st floor hallway across from Back Stage D101 (high)	12/22/15	< 1		
SMS-1222-48B	Sousa MS	1st floor hallway across from Back Stage D101 (high)	12/22/15	< 1		
SMS-1222-49A	Sousa MS	1st floor hallway across from Back Stage D101 (low)	12/22/15	< 1		
SMS-1222-49B	Sousa MS	1st floor hallway across from Back Stage D101 (low)	12/22/15	< 1		
SMS-1222-50A	Sousa MS	1st floor inside Gym inside Girl's Locker Room (high)	12/22/15	< 1		
SMS-1222-50B	Sousa MS	1st floor inside Gym inside Girl's Locker Room (high)	12/22/15	< 1		
SMS-1222-51A	Sousa MS	1st floor inside Gym inside Girl's Locker Room (low)	12/22/15	< 1		
SMS-1222-51B	Sousa MS	1st floor inside Gym inside Girl's Locker Room (high)	12/22/15	< 1		
SMS-1222-52A	Sousa MS	1st floor inside Gym inside Boy's Locker Room (high)	12/22/15	< 1		
SMS-1222-52B	Sousa MS	1st floor inside Gym inside Boy's Locker Room (high)	12/22/15	< 1		
SMS-1222-53A	Sousa MS	1st floor inside Gym inside Boy's Locker Room (low)	12/22/15	< 1		
SMS-1222-53B	Sousa MS	1st floor inside Gym inside Boy's Locker Room (low)	12/22/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SES-1207-1A	Stanton ES	3rd floor hallway across from Electric Closet 315 (high)	12/7/15	< 1		
SES-1207-1B	Stanton ES	3rd floor hallway across from Electric Closet 315 (high)	12/7/15	< 1		
SES-1207-2A	Stanton ES	3rd floor hallway across from Electric Closet 315 (low)	12/7/15	< 1		
SES-1207-2B	Stanton ES	3rd floor hallway across from Electric Closet 315 (low)	12/7/15	< 1		
SES-1207-3A	Stanton ES	3rd floor hallway across from Classroom 310 (high)	12/7/15	< 1		
SES-1207-3B	Stanton ES	3rd floor hallway across from Classroom 310 (high)	12/7/15	< 1		
SES-1207-4A	Stanton ES	3rd floor hallway across from Classroom 310 (low)	12/7/15	< 1		
SES-1207-4B	Stanton ES	3rd floor hallway across from Classroom 310 (low)	12/7/15	< 1		
SES-1207-5A	Stanton ES	2nd floor hallway across from Classroom 207 (high)	12/7/15	< 1		
SES-1207-5B	Stanton ES	2nd floor hallway across from Classroom 207 (high)	12/7/15	< 1		
SES-1207-6A	Stanton ES	2nd floor hallway across from Classroom 207 (low)	12/7/15	< 1		
SES-1207-6B	Stanton ES	2nd floor hallway across from Classroom 207 (low)	12/7/15	< 1		
SES-1207-7A	Stanton ES	2nd floor hallway across from Electric Closet 213 (high)	12/7/15	< 1		
SES-1207-7B	Stanton ES	2nd floor hallway across from Electric Closet 213 (high)	12/7/15	< 1		
SES-1207-8A	Stanton ES	2nd floor hallway across from Electric Closet 213 (low)	12/7/15	< 1		
SES-1207-8B	Stanton ES	2nd floor hallway across from Electric Closet 213 (low)	12/7/15	< 1		
SES-1207-9A	Stanton ES	1st floor hallway across from Electric Closet 106-C (high)	12/7/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
SES-1207-9B	Stanton ES	1st floor hallway across from Electric Closet 106-C (high)	12/7/15	< 1		
SES-1207-10A	Stanton ES	1st floor hallway across from Electric Closet 106-C (low)	12/7/15	< 1		
SES-1207-10B	Stanton ES	1st floor hallway across from Electric Closet 106-C (low)	12/7/15	< 1		
SES-1207-11A	Stanton ES	Basement floor hallway between Boy's and Girl's Restrooms (high)	12/7/15	< 1		
SES-1207-11B	Stanton ES	Basement floor hallway between Boy's and Girl's Restrooms (high)	12/7/15	< 1		
SES-1207-12A	Stanton ES	Basement floor hallway between Boy's and Girl's Restrooms (low)	12/7/15	< 1		
SES-1207-12B	Stanton ES	Basement floor hallway between Boy's and Girl's Restrooms (low)	12/7/15	< 1		
SES-1207-13A	Stanton ES	Basement floor inside Cafeteria	12/7/15	< 1		
SES-1207-13B	Stanton ES	Basement floor inside Cafeteria	12/7/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SES-0307-1A	Stoddert ES	2nd floor inside Classroom 246	3/7/16	< 1		
SES-0307-1B	Stoddert ES	2nd floor inside Classroom 246	3/7/16	< 1		
SES-0307-2A	Stoddert ES	2nd floor inside Classroom 245	3/7/16	< 1		
SES-0307-2B	Stoddert ES	2nd floor inside Classroom 245	3/7/16	< 1		
SES-0307-3A	Stoddert ES	2nd floor inside Classroom 247	3/7/16	1.9		
SES-0307-3B	Stoddert ES	2nd floor inside Classroom 247	3/7/16	3.8		
SES-0307-4A	Stoddert ES	2nd floor inside Classroom 244	3/7/16	< 1		
SES-0307-4B	Stoddert ES	2nd floor inside Classroom 244	3/7/16	< 1		
SES-0307-5A	Stoddert ES	2nd floor inside Classroom 231	3/7/16	< 1		
SES-0307-5B	Stoddert ES	2nd floor inside Classroom 231	3/7/16	< 1		
SES-0307-6A	Stoddert ES	2nd floor inside Classroom 232	3/7/16	< 1		
SES-0307-6B	Stoddert ES	2nd floor inside Classroom 232	3/7/16	< 1		
SES-0307-7A	Stoddert ES	2nd floor inside Classroom 233	3/7/16	< 1		
SES-0307-7B	Stoddert ES	2nd floor inside Classroom 233	3/7/16	< 1		
SES-0307-8A	Stoddert ES	2nd floor inside Classroom 234	3/7/16	< 1		
SES-0307-8B	Stoddert ES	2nd floor inside Classroom 234	3/7/16	< 1		
SES-0307-9A	Stoddert ES	2nd floor hallway between Boy's and Girl's Rooms (high)	3/7/16	< 1		
SES-0307-9B	Stoddert ES	2nd floor hallway between Boy's and Girl's Rooms (high)	3/7/16	< 1		
SES-0307-10A	Stoddert ES	2nd floor hallway between Boy's and Girl's Rooms (low)	3/7/16	< 1		
SES-0307-10B	Stoddert ES	2nd floor hallway between Boy's and Girl's Rooms (low)	3/7/16	< 1		
SES-0307-11A	Stoddert ES	2nd floor inside Classroom 227 left	3/7/16	< 1		
SES-0307-11B	Stoddert ES	2nd floor inside Classroom 227 left	3/7/16	< 1		
SES-0307-12A	Stoddert ES	2nd floor inside Classroom 227 right	3/7/16	3		
SES-0307-12B	Stoddert ES	2nd floor inside Classroom 227 right	3/7/16	1.7		
SES-0307-13A	Stoddert ES	2nd floor inside Classroom 227 other side	3/7/16	< 1		
SES-0307-13B	Stoddert ES	2nd floor inside Classroom 227 other side	3/7/16	< 1		
SES-0307-14A	Stoddert ES	1st floor inside Classroom 146	3/7/16	< 1		
SES-0307-14B	Stoddert ES	1st floor inside Classroom 146	3/7/16	< 1		
SES-0307-15A	Stoddert ES	1st floor inside Classroom 147	3/7/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
SES-0307-15B	Stoddert ES	1st floor inside Classroom 147	3/7/16	< 1		
SES-0307-16A	Stoddert ES	1st floor inside Classroom 144	3/7/16	< 1		
SES-0307-16B	Stoddert ES	1st floor inside Classroom 144	3/7/16	< 1		
SES-0307-17A	Stoddert ES	1st floor inside Classroom 142	3/7/16	1.6		
SES-0307-17B	Stoddert ES	1st floor inside Classroom 142	3/7/16	< 1		
SES-0307-18A	Stoddert ES	1st floor inside Classroom 131	3/7/16	< 1		
SES-0307-18B	Stoddert ES	1st floor inside Classroom 131	3/7/16	< 1		
SES-0307-19A	Stoddert ES	1st floor inside Classroom 132	3/7/16	< 1		
SES-0307-19B	Stoddert ES	1st floor inside Classroom 132	3/7/16	< 1		
SES-0307-20A	Stoddert ES	1st floor inside Classroom 133	3/7/16	< 1		
SES-0307-20B	Stoddert ES	1st floor inside Classroom 133	3/7/16	< 1		
SES-0307-21A	Stoddert ES	1st floor inside Classroom 134	3/7/16	< 1		
SES-0307-21B	Stoddert ES	1st floor inside Classroom 134	3/7/16	< 1		
SES-0307-22A	Stoddert ES	1st floor hallway between Boy's and Girl's Rooms (high)	3/7/16	< 1		
SES-0307-22B	Stoddert ES	1st floor hallway between Boy's and Girl's Rooms (high)	3/7/16	< 1		
SES-0307-23A	Stoddert ES	1st floor hallway between Boy's and Girl's Rooms (low)	3/7/16	2		
SES-0307-23B	Stoddert ES	1st floor hallway between Boy's and Girl's Rooms (low)	3/7/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
	Stuart Hobson MS					
	Stuart Hobson MS					
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
TEC-0203-1A	Takoma EC	3rd floor hallway adjacent to Elevator (high)	2/3/16	< 1		
TEC-0203-1B	Takoma EC	3rd floor hallway adjacent to Elevator (high)	2/3/16	< 1		
TEC-0203-2A	Takoma EC	3rd floor hallway adjacent to Elevator (low)	2/3/16	< 1		
TEC-0203-2B	Takoma EC	3rd floor hallway adjacent to Elevator (low)	2/3/16	< 1		
TEC-0203-3A	Takoma EC	3rd floor hallway adjacent to Science Lab 327 (high)	2/3/16	< 1		
TEC-0203-3B	Takoma EC	3rd floor hallway adjacent to Science Lab 327 (high)	2/3/16	< 1		
TEC-0203-4A	Takoma EC	3rd floor hallway adjacent to Science Lab 327 (low)	2/3/16	< 1		
TEC-0203-4B	Takoma EC	3rd floor hallway adjacent to Science Lab 327 (low)	2/3/16	< 1		
TEC-0203-5A	Takoma EC	2nd floor hallway adjacent to Elevator (high)	2/3/16	< 1		
TEC-0203-5B	Takoma EC	2nd floor hallway adjacent to Elevator (high)	2/3/16	< 1		
TEC-0203-6A	Takoma EC	2nd floor hallway adjacent to Elevator (low)	2/3/16	< 1		
TEC-0203-6B	Takoma EC	2nd floor hallway adjacent to Elevator (low)	2/3/16	7.5		
TEC-0203-7A	Takoma EC	2nd floor hallway adjacent to Stair 4 (high)	2/3/16	< 1		
TEC-0203-7B	Takoma EC	2nd floor hallway adjacent to Stair 4 (high)	2/3/16	< 1		
TEC-0203-8A	Takoma EC	2nd floor hallway adjacent to Stair 4 (low)	2/3/16	< 1		
TEC-0203-8B	Takoma EC	2nd floor hallway adjacent to Stair 4 (low)	2/3/16	< 1		
TEC-0203-9A	Takoma EC	1st floor hallway across from Elevator (high)	2/3/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
TEC-0203-9B	Takoma EC	1st floor hallway across from Elevator (high)	2/3/16	< 1		
TEC-0203-10A	Takoma EC	1st floor hallway across from Elevator (low)	2/3/16	< 1		
TEC-0203-10B	Takoma EC	1st floor hallway across from Elevator (low)	2/3/16	< 1		
TEC-0203-11A	Takoma EC	1st floor hallway adjacent to Parent Resource Room 133 (high)	2/3/16	< 1		
TEC-0203-11B	Takoma EC	1st floor hallway adjacent to Parent Resource Room 133 (high)	2/3/16	< 1		
TEC-0203-12A	Takoma EC	1st floor hallway adjacent to Parent Resource Room 133 (high)	2/3/16	< 1		
TEC-0203-12B	Takoma EC	1st floor hallway adjacent to Parent Resource Room 133 (high)	2/3/16	< 1		
TEC-0203-13A	Takoma EC	Inside Gym Bldg. adjacent to Girl's Locker Room	2/3/16	< 1		
TEC-0203-13B	Takoma EC	Inside Gym Bldg. adjacent to Girl's Locker Room	2/3/16	< 1		
TEC-0203-14A	Takoma EC	Inside Gym Bldg. adjacent to Boy's Locker Room	2/3/16	< 1		
TEC-0203-14B	Takoma EC	Inside Gym Bldg. adjacent to Boy's Locker Room	2/3/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
TES-0105-1A	Thomas ES	3rd floor hallway adjacent to Storage Room (high)	1/5/16	< 1		
TES-0105-1B	Thomas ES	3rd floor hallway adjacent to Storage Room (high)	1/5/16	< 1		
TES-0105-2A	Thomas ES	3rd floor hallway adjacent to Storage Room (low)	1/5/16	< 1		
TES-0105-2B	Thomas ES	3rd floor hallway adjacent to Storage Room (low)	1/5/16	< 1		
TES-0105-3A	Thomas ES	2nd floor hallway adjacent to Storage Room (high)	1/5/16	< 1		
TES-0105-3B	Thomas ES	2nd floor hallway adjacent to Storage Room (high)	1/5/16	< 1		
TES-0105-4A	Thomas ES	2nd floor hallway adjacent to Storage Room (low)	1/5/16	< 1		
TES-0105-4B	Thomas ES	2nd floor hallway adjacent to Storage Room (low)	1/5/16	< 1		
TES-0105-5A	Thomas ES	2nd floor hallway adjacent to Custodian Closet near Classroom 220	1/5/16	< 1		
TES-0105-5B	Thomas ES	2nd floor hallway adjacent to Custodian Closet near Classroom 220	1/5/16	< 1		
TES-0105-6A	Thomas ES	2nd floor hallway adjacent to Classroom 214	1/5/16	< 1		
TES-0105-6B	Thomas ES	2nd floor hallway adjacent to Classroom 214	1/5/16	< 1		
TES-0105-7A	Thomas ES	1st floor hallway across from Auditorium near Main Entrance	1/5/16	< 1		
TES-0105-7B	Thomas ES	1st floor hallway across from Auditorium near Main Entrance	1/5/16	< 1		
TES-0105-8A	Thomas ES	1st floor inside Cafeteria	1/5/16	< 1		
TES-0105-8B	Thomas ES	1st floor inside Cafeteria	1/5/16	< 1		
TES-0105-9A	Thomas ES	1st floor hallway adjacent to Boy's Room (high)	1/5/16	< 1		
TES-0105-9B	Thomas ES	1st floor hallway adjacent to Boy's Room (high)	1/5/16	< 1		
TES-0105-10A	Thomas ES	1st floor hallway adjacent to Boy's Room (low)	1/5/16	< 1		
TES-0105-10B	Thomas ES	1st floor hallway adjacent to Boy's Room (low)	1/5/16	< 1		
TES-0105-11A	Thomas ES	1st floor hallway adjacent to Storage Room (high)	1/5/16	< 1		
TES-0105-11B	Thomas ES	1st floor hallway adjacent to Storage Room (high)	1/5/16	< 1		
TES-0105-12A	Thomas ES	1st floor hallway adjacent to Storage Room (low)	1/5/16	< 1		
TES-0105-12B	Thomas ES	1st floor hallway adjacent to Storage Room (low)	1/5/16	< 1		
TES-0105-13A	Thomas ES	1st floor inside Principal's Office ( old Health Suite)	1/5/16	< 1		
TES-0105-13B	Thomas ES	1st floor inside Principal's Office ( old Health Suite)	1/5/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
TES-0202-1A	Thomson ES	3rd floor hallway across from elevator (high)	2/2/16	< 1		
TES-0202-1B	Thomson ES	3rd floor hallway across from elevator (high)	2/2/16	< 1		
TES-0202-2A	Thomson ES	3rd floor hallway across from elevator (low)	2/2/16	< 1		
TES-0202-2B	Thomson ES	3rd floor hallway across from elevator (low)	2/2/16	< 1		
TES-0202-3A	Thomson ES	3rd floor inside Classroom 310	2/2/16	< 1		
TES-0202-3B	Thomson ES	3rd floor inside Classroom 310	2/2/16	< 1		
TES-0202-4A	Thomson ES	3rd floor inside Classroom 309	2/2/16	< 1		
TES-0202-4B	Thomson ES	3rd floor inside Classroom 309	2/2/16	< 1		
TES-0202-5A	Thomson ES	3rd floor inside Classroom 308	2/2/16		33	Device has been turned off. Filter installation pending.
TES-0202-5B	Thomson ES	3rd floor inside Classroom 308	2/2/16	2.4		
TES-0202-6A	Thomson ES	3rd floor inside Classroom 307	2/2/16	< 1		
TES-0202-6B	Thomson ES	3rd floor inside Classroom 307	2/2/16	< 1		
TES-0202-7A	Thomson ES	2nd floor hallway across from elevator (high)	2/2/16	< 1		
TES-0202-7B	Thomson ES	2nd floor hallway across from elevator (high)	2/2/16	< 1		
TES-0202-8A	Thomson ES	2nd floor hallway across from elevator (low)	2/2/16	< 1		
TES-0202-8B	Thomson ES	2nd floor hallway across from elevator (low)	2/2/16	< 1		
TES-0202-9A	Thomson ES	2nd floor inside Classroom 204	2/2/16	< 1		
TES-0202-9B	Thomson ES	2nd floor inside Classroom 204	2/2/16	< 1		
TES-0202-10A	Thomson ES	2nd floor inside Classroom 208	2/2/16	< 1		
TES-0202-10B	Thomson ES	2nd floor inside Classroom 208	2/2/16	< 1		
TES-0202-11A	Thomson ES	2nd floor inside Classroom 211	2/2/16	< 1		
TES-0202-11B	Thomson ES	2nd floor inside Classroom 211	2/2/16	< 1		
TES-0202-12A	Thomson ES	2nd floor inside Classroom 210	2/2/16	2		
TES-0202-12B	Thomson ES	2nd floor inside Classroom 210	2/2/16	< 1		
TES-0202-13A	Thomson ES	2nd floor inside Classroom 209	2/2/16	< 1		
TES-0202-13B	Thomson ES	2nd floor inside Classroom 209	2/2/16	< 1		
TES-0202-14A	Thomson ES	2nd floor inside Teacher's Workroom 215	2/2/16	< 1		
TES-0202-14B	Thomson ES	2nd floor inside Teacher's Workroom 215	2/2/16	< 1		
TES-0202-15A	Thomson ES	2nd floor inside Classroom 219	2/2/16	< 1		
TES-0202-15B	Thomson ES	2nd floor inside Classroom 219	2/2/16	< 1		
TES-0202-16A	Thomson ES	2nd floor inside Classroom 220	2/2/16	< 1		
TES-0202-16B	Thomson ES	2nd floor inside Classroom 220	2/2/16	< 1		
TES-0202-17A	Thomson ES	2nd floor inside Classroom 221	2/2/16	1.5		
TES-0202-17B	Thomson ES	2nd floor inside Classroom 221	2/2/16	< 1		
TES-0202-18A	Thomson ES	2nd floor inside Classroom 223	2/2/16	< 1		
TES-0202-18B	Thomson ES	2nd floor inside Classroom 223	2/2/16	< 1		
TES-0202-19A	Thomson ES	1st floor hallway adjacent to Storage 129 (high)	2/2/16	< 1		
TES-0202-19B	Thomson ES	1st floor hallway adjacent to Storage 129 (high)	2/2/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
TES-0202-20A	Thomson ES	1st floor hallway adjacent to Storage 129 (low)	2/2/16	< 1		
TES-0202-20B	Thomson ES	1st floor hallway adjacent to Storage 129 (low)	2/2/16	< 1		
TES-0202-21A	Thomson ES	1st floor inside Classroom 115	2/2/16	< 1		
TES-0202-21B	Thomson ES	1st floor inside Classroom 115	2/2/16	< 1		
TES-0202-22A	Thomson ES	1st floor inside Classroom 112	2/2/16	< 1		
TES-0202-22B	Thomson ES	1st floor inside Classroom 112	2/2/16	< 1		
TES-0202-23A	Thomson ES	1st floor inside Classroom 113	2/2/16	< 1		
TES-0202-23B	Thomson ES	1st floor inside Classroom 113	2/2/16	< 1		
TES-0202-24A	Thomson ES	1st floor inside Classroom 114	2/2/16	< 1		
TES-0202-24B	Thomson ES	1st floor inside Classroom 114	2/2/16	< 1		
TES-0202-25A	Thomson ES	1st floor inside Classroom 123	2/2/16	< 1		
TES-0202-25B	Thomson ES	1st floor inside Classroom 123	2/2/16	< 1		
TES-0202-26A	Thomson ES	1st floor inside Classroom 124	2/2/16	< 1		
TES-0202-26B	Thomson ES	1st floor inside Classroom 124	2/2/16	< 1		
TES-0202-27A	Thomson ES	1st floor inside Classroom 126	2/2/16	< 1		
TES-0202-27B	Thomson ES	1st floor inside Classroom 126	2/2/16	< 1		
TES-0202-28A	Thomson ES	1st floor inside Classroom 127	2/2/16	< 1		
TES-0202-28B	Thomson ES	1st floor inside Classroom 127	2/2/16	< 1		
TES-0202-29A	Thomson ES	Ground floor hallway adjacent to Room G02 (high)	2/2/16	< 1		
TES-0202-29B	Thomson ES	Ground floor hallway adjacent to Room G02 (high)	2/2/16	< 1		
TES-0202-30A	Thomson ES	Ground floor hallway adjacent to Room G02 (low)	2/2/16	< 1		
TES-0202-30B	Thomson ES	Ground floor hallway adjacent to Room G02 (low)	2/2/16	< 1		
TES-0202-31A	Thomson ES	Basement floor inside Cafeteria (high)	2/2/16	< 1		
TES-0202-31B	Thomson ES	Basement floor inside Cafeteria (high)	2/2/16	< 1		
TES-0202-32A	Thomson ES	Basement floor inside Cafeteria (low)	2/2/16	< 1		
TES-0202-32B	Thomson ES	Basement floor inside Cafeteria (low)	2/2/16	< 1		
<b>Percentage of Passed Samples</b>						<b>98.44%</b>
<b>Percentage of Failed Samples</b>						<b>1.56%</b>
TES-0121-1A	Truesdell ES	3rd floor hallway adjacent to Classroom 300	1/21/16	< 1		
TES-0121-1B	Truesdell ES	3rd floor hallway adjacent to Classroom 300	1/21/16	< 1		
TES-0121-2A	Truesdell ES	3rd floor hallway adjacent to Roof Door	1/21/16	< 1		
TES-0121-2B	Truesdell ES	3rd floor hallway adjacent to Roof Door	1/21/16	< 1		
TES-0121-3A	Truesdell ES	2nd floor inside Classroom 217	1/21/16	< 1		
TES-0121-3B	Truesdell ES	2nd floor inside Classroom 217	1/21/16	< 1		
TES-0121-4A	Truesdell ES	2nd floor inside Classroom 216	1/21/16	< 1		
TES-0121-4B	Truesdell ES	2nd floor inside Classroom 216	1/21/16	< 1		
TES-0121-5A	Truesdell ES	2nd floor hallway adjacent to Classroom 212	1/21/16	< 1		
TES-0121-5B	Truesdell ES	2nd floor hallway adjacent to Classroom 212	1/21/16	< 1		
TES-0121-6A	Truesdell ES	2nd floor hallway adjacent to Classroom 200	1/21/16	< 1		
TES-0121-6B	Truesdell ES	2nd floor hallway adjacent to Classroom 200	1/21/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
TES-0121-7A	Truesdell ES	2nd floor inside Classroom 200	1/21/16		23	Device has been turned off. Filter installation pending.
TES-0121-7B	Truesdell ES	2nd floor inside Classroom 200	1/21/16	1.8		
TES-0121-8A	Truesdell ES	2nd floor inside Classroom 201	1/21/16	< 1		
TES-0121-8B	Truesdell ES	2nd floor inside Classroom 201	1/21/16	< 1		
TES-0121-9A	Truesdell ES	1st floor hallway across from Library 117	1/21/16	< 1		
TES-0121-9B	Truesdell ES	1st floor hallway across from Library 117	1/21/16	< 1		
TES-0121-10A	Truesdell ES	1st floor hallway across from Music Room 126	1/21/16	< 1		
TES-0121-10B	Truesdell ES	1st floor hallway across from Music Room 126	1/21/16	< 1		
TES-0121-11A	Truesdell ES	2nd floor hallway across from Classroom 218	1/21/16	< 1		
TES-0121-11B	Truesdell ES	2nd floor hallway across from Classroom 218	1/21/16	< 1		
TES-0121-12A	Truesdell ES	2nd floor hallway across from Classroom 227	1/21/16	< 1		
TES-0121-12B	Truesdell ES	2nd floor hallway across from Classroom 227	1/21/16	< 1		
TES-0121-13A	Truesdell ES	1st floor inside Classroom 115 Pre-School	1/21/16	< 1		
TES-0121-13B	Truesdell ES	1st floor inside Classroom 115 Pre-School	1/21/16	< 1		
TES-0121-14A	Truesdell ES	1st floor inside Classroom 114 Pre-School	1/21/16	< 1		
TES-0121-14B	Truesdell ES	1st floor inside Classroom 114 Pre-School	1/21/16	< 1		
TES-0121-15A	Truesdell ES	1st floor hallway across from Boy's and Girl's Rooms	1/21/16	< 1		
TES-0121-15B	Truesdell ES	1st floor hallway across from Boy's and Girl's Rooms	1/21/16	< 1		
TES-0121-16A	Truesdell ES	1st floor hallway across from Café Annex 103	1/21/16	< 1		
TES-0121-16B	Truesdell ES	1st floor hallway across from Café Annex 103	1/21/16	< 1		
TES-0121-17A	Truesdell ES	1st floor inside Classroom 101 Pre-K	1/21/16	< 1		
TES-0121-17B	Truesdell ES	1st floor inside Classroom 101 Pre-K	1/21/16	< 1		
TES-0121-18A	Truesdell ES	1st floor inside Classroom 100 Pre-K	1/21/16	< 1		
TES-0121-18B	Truesdell ES	1st floor inside Classroom 100 Pre-K	1/21/16	< 1		
TES-0121-19A	Truesdell ES	Basement floor hallway adjacent to Rm 013	1/21/16	< 1		
TES-0121-19B	Truesdell ES	Basement floor hallway adjacent to Rm 013	1/21/16	< 1		
TES-0121-20A	Truesdell ES	Basement floor inside Health Suite	1/21/16	< 1		
TES-0121-20B	Truesdell ES	Basement floor inside Health Suite	1/21/16	< 1		
<b>Percentage of Passed Samples</b>					<b>97.50%</b>	
<b>Percentage of Failed Samples</b>					<b>2.50%</b>	
TES-0406-1A	Tubman ES	3rd floor hallway adjacent to Classroom 308	2/6/16	< 1		
TES-0406-1B	Tubman ES	3rd floor hallway adjacent to Classroom 308	2/6/16	< 1		
TES-0406-2A	Tubman ES	3rd floor hallway adjacent to Classroom 306	2/6/16	< 1		
TES-0406-2B	Tubman ES	3rd floor hallway adjacent to Classroom 306	2/6/16	< 1		
TES-0406-3A	Tubman ES	3rd floor hallway across from Storage Room 301	2/6/16	< 1		
TES-0406-3B	Tubman ES	3rd floor hallway across from Storage Room 301	2/6/16	< 1		
TES-0406-4A	Tubman ES	2nd floor hallway across from Storage Room 201	2/6/16	< 1		
TES-0406-4B	Tubman ES	2nd floor hallway across from Storage Room 201	2/6/16	< 1		
TES-0406-5A	Tubman ES	2nd floor hallway adjacent to Classroom 206	2/6/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
TES-0406-5B	Tubman ES	2nd floor hallway adjacent to Classroom 206	2/6/16	< 1		
TES-0406-6A	Tubman ES	1st floor hallway adjacent to Classroom 114	2/6/16	< 1		
TES-0406-6B	Tubman ES	1st floor hallway adjacent to Classroom 114	2/6/16	< 1		
TES-0406-7A	Tubman ES	1st floor inside Classroom 114	2/6/16	< 1		
TES-0406-7B	Tubman ES	1st floor inside Classroom 114	2/6/16	< 1		
TES-0406-8A	Tubman ES	1st floor inside Classroom 115	2/6/16	< 1		
TES-0406-8B	Tubman ES	1st floor inside Classroom 115	2/6/16	< 1		
TES-0406-9A	Tubman ES	1st floor inside Classroom 113	2/6/16	< 1		
TES-0406-9B	Tubman ES	1st floor inside Classroom 113	2/6/16	< 1		
TES-0406-10A	Tubman ES	1st floor inside Classroom 110	2/6/16	< 1		
TES-0406-10B	Tubman ES	1st floor inside Classroom 110	2/6/16	< 1		
TES-0406-11A	Tubman ES	1st floor inside Classroom 111	2/6/16	< 1		
TES-0406-11B	Tubman ES	1st floor inside Classroom 111	2/6/16	< 1		
TES-0406-12A	Tubman ES	1st floor inside Classroom 108	2/6/16	< 1		
TES-0406-12B	Tubman ES	1st floor inside Classroom 108	2/6/16	< 1		
TES-0406-13A	Tubman ES	1st floor inside Health Suite 104	2/6/16	< 1		
TES-0406-13B	Tubman ES	1st floor inside Health Suite 104	2/6/16	< 1		
TES-0406-14A	Tubman ES	1st floor inside Multi-Purpose Room	2/6/16	< 1		
TES-0406-14B	Tubman ES	1st floor inside Multi-Purpose Room	2/6/16	< 1		
TES-0406-15A	Tubman ES	1st floor inside Classroom 122	2/6/16	< 1		
TES-0406-15B	Tubman ES	1st floor inside Classroom 122	2/6/16	< 1		
TES-0406-16A	Tubman ES	1st floor inside Classroom 121	2/6/16	< 1		
TES-0406-16B	Tubman ES	1st floor inside Classroom 121	2/6/16	< 1		
TES-0406-17A	Tubman ES	1st floor inside Classroom 120	2/6/16	< 1		
TES-0406-17B	Tubman ES	1st floor inside Classroom 120	2/6/16	< 1		
TES-0406-18A	Tubman ES	1st floor inside Classroom 119	2/6/16	< 1		
TES-0406-18B	Tubman ES	1st floor inside Classroom 119	2/6/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
TES-1217-1A	Turner ES	3rd floor hallway adjacent to Girl's Room (high)	12/17/15	< 1		
TES-1217-1B	Turner ES	3rd floor hallway adjacent to Girl's Room (high)	12/17/15	< 1		
TES-1217-2A	Turner ES	3rd floor hallway adjacent to Girl's Room (low)	12/17/15	< 1		
TES-1217-2B	Turner ES	3rd floor hallway adjacent to Girl's Room (low)	12/17/15	< 1		
TES-1217-3A	Turner ES	3rd floor hallway adjacent to elevator (high)	12/17/15	< 1		
TES-1217-3B	Turner ES	3rd floor hallway adjacent to elevator (high)	12/17/15	< 1		
TES-1217-4A	Turner ES	3rd floor hallway adjacent to elevator (low)	12/17/15	< 1		
TES-1217-4B	Turner ES	3rd floor hallway adjacent to elevator (low)	12/17/15	< 1		
TES-1217-5A	Turner ES	3rd floor across from Classroom 310 (high)	12/17/15	< 1		
TES-1217-5B	Turner ES	3rd floor across from Classroom 310 (high)	12/17/15	< 1		
TES-1217-6A	Turner ES	3rd floor across from Classroom 310 (low)	12/17/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
TES-1217-6B	Turner ES	3rd floor across from Classroom 310 (low)	12/17/15	< 1		
TES-1217-7A	Turner ES	3rd floor hallway adjacent to Janitor's Closet 302 (high)	12/17/15	< 1		
TES-1217-7B	Turner ES	3rd floor hallway adjacent to Janitor's Closet 302 (high)	12/17/15	< 1		
TES-1217-8A	Turner ES	3rd floor hallway adjacent to Janitor's Closet 302 (low)	12/17/15	< 1		
TES-1217-8B	Turner ES	3rd floor hallway adjacent to Janitor's Closet 302 (low)	12/17/15	< 1		
TES-1217-9A	Turner ES	2nd floor hallway adjacent to Janitor's Closet 202 (high)	12/17/15	< 1		
TES-1217-9B	Turner ES	2nd floor hallway adjacent to Janitor's Closet 202 (high)	12/17/15	< 1		
TES-1217-10A	Turner ES	2nd floor hallway adjacent to Janitor's Closet 202 (low)	12/17/15	< 1		
TES-1217-10B	Turner ES	2nd floor hallway adjacent to Janitor's Closet 202 (low)	12/17/15	< 1		
TES-1217-11A	Turner ES	2nd floor hallway at entrance to Library (high)	12/17/15	< 1		
TES-1217-11B	Turner ES	2nd floor hallway at entrance to Library (high)	12/17/15	< 1		
TES-1217-12A	Turner ES	2nd floor hallway at entrance to Library (low)	12/17/15	< 1		
TES-1217-12B	Turner ES	2nd floor hallway at entrance to Library (low)	12/17/15	< 1		
TES-1217-13A	Turner ES	2nd floor hallway adjacent to elevator (high)	12/17/15	< 1		
TES-1217-13B	Turner ES	2nd floor hallway adjacent to elevator (high)	12/17/15	< 1		
TES-1217-14A	Turner ES	2nd floor hallway adjacent to elevator (low)	12/17/15	< 1		
TES-1217-14B	Turner ES	2nd floor hallway adjacent to elevator (low)	12/17/15	< 1		
TES-1217-15A	Turner ES	2nd floor hallway adjacent to Girl's Room (high)	12/17/15	< 1		
TES-1217-15B	Turner ES	2nd floor hallway adjacent to Girl's Room (high)	12/17/15	< 1		
TES-1217-16A	Turner ES	2nd floor hallway adjacent to Girl's Room (low)	12/17/15	< 1		
TES-1217-16B	Turner ES	2nd floor hallway adjacent to Girl's Room (low)	12/17/15	< 1		
TES-1217-17A	Turner ES	1st floor hallway adjacent to Janitor's Closet 102 (high)	12/17/15	< 1		
TES-1217-17B	Turner ES	1st floor hallway adjacent to Janitor's Closet 102 (high)	12/17/15	< 1		
TES-1217-18A	Turner ES	1st floor hallway adjacent to Janitor's Closet 102 (low)	12/17/15	< 1		
TES-1217-18B	Turner ES	1st floor hallway adjacent to Janitor's Closet 102 (low)	12/17/15	< 1		
TES-1217-19A	Turner ES	1st floor inside Classroom 106	12/17/15	< 1		
TES-1217-19B	Turner ES	1st floor inside Classroom 106	12/17/15	< 1		
TES-1217-20A	Turner ES	1st floor inside Classroom 107	12/17/15	< 1		
TES-1217-20B	Turner ES	1st floor inside Classroom 107	12/17/15	< 1		
TES-1217-21A	Turner ES	1st floor inside Classroom 108	12/17/15	< 1		
TES-1217-21B	Turner ES	1st floor inside Classroom 108	12/17/15	< 1		
TES-1217-22A	Turner ES	1st floor inside Classroom 109A	12/17/15	2.9		
TES-1217-22B	Turner ES	1st floor inside Classroom 109A	12/17/15	< 1		
TES-1217-23A	Turner ES	1st floor inside Classroom 109B	12/17/15	7.4		
TES-1217-23B	Turner ES	1st floor inside Classroom 109B	12/17/15	< 1		
TES-1217-24A	Turner ES	1st floor hallway across from Classroom 108 (high)	12/17/15	< 1		
TES-1217-24B	Turner ES	1st floor hallway across from Classroom 108 (high)	12/17/15	< 1		
TES-1217-25A	Turner ES	1st floor hallway across from Classroom 108 (low)	12/17/15	< 1		
TES-1217-25B	Turner ES	1st floor hallway across from Classroom 108 (low)	12/17/15	< 1		
TES-1217-26A	Turner ES	1st floor hallway adjacent to Elevator (high)	12/17/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
TES-1217-26B	Turner ES	1st floor hallway adjacent to Elevator (high)	12/17/15	< 1		
TES-1217-27A	Turner ES	1st floor hallway adjacent to Elevator (low)	12/17/15	< 1		
TES-1217-27B	Turner ES	1st floor hallway adjacent to Elevator (low)	12/17/15	< 1		
TES-1217-28A	Turner ES	1st floor inside Classroom 113 Pre-K	12/17/15	2.1		
TES-1217-28B	Turner ES	1st floor inside Classroom 113 Pre-K	12/17/15	< 1		
TES-1217-29A	Turner ES	1st floor inside Classroom 116 Pre-K	12/17/15	12		
TES-1217-29B	Turner ES	1st floor inside Classroom 116 Pre-K	12/17/15	5.7		
TES-1217-30A	Turner ES	1st floor inside Classroom 117 Pre-K	12/17/15	< 1		
TES-1217-30B	Turner ES	1st floor inside Classroom 117 Pre-K	12/17/15	< 1		
TES-1217-31A	Turner ES	1st floor hallway across from Main Office (high)	12/17/15	< 1		
TES-1217-31B	Turner ES	1st floor hallway across from Main Office (high)	12/17/15	< 1		
TES-1217-32A	Turner ES	1st floor hallway across from Main Office (low)	12/17/15	< 1		
TES-1217-32B	Turner ES	1st floor hallway across from Main Office (low)	12/17/15	< 1		
TES-1217-33A	Turner ES	1st floor hallway across from Gym (high)	12/17/15	< 1		
TES-1217-33B	Turner ES	1st floor hallway across from Gym (high)	12/17/15	< 1		
TES-1217-34A	Turner ES	1st floor hallway across from Gym (low)	12/17/15	< 1		
TES-1217-34B	Turner ES	1st floor hallway across from Gym (low)	12/17/15	< 1		
TES-0309-1A	Turner ES	1st floor inside Classroom 112	3/9/16	< 1		
TES-0309-1B	Turner ES	1st floor inside Classroom 112	3/9/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
TES-1224-1A	Tyler ES	3rd floor hallway across from Boy's Room	12/24/15	< 1		
TES-1224-1B	Tyler ES	3rd floor hallway across from Boy's Room	12/24/15	< 1		
TES-1224-2A	Tyler ES	3rd floor hallway across from Girl's Room	12/24/15	< 1		
TES-1224-2B	Tyler ES	3rd floor hallway across from Girl's Room	12/24/15	< 1		
TES-1224-3A	Tyler ES	2nd floor hallway across from Girl's Room	12/24/15	< 1		
TES-1228-3B	Tyler ES	2nd floor hallway across from Girl's Room	12/24/15	< 1		
TES-1224-4A	Tyler ES	2nd floor hallway across from Boy's Room	12/24/15	< 1		
TES-1224-4B	Tyler ES	2nd floor hallway across from Boy's Room	12/24/15	< 1		
TES-1224-5A	Tyler ES	1st floor hallway across from Girl's Room (high)	12/24/15	< 1		
TES-1224-5B	Tyler ES	1st floor hallway across from Girl's Room (high)	12/24/15	< 1		
TES-1224-6A	Tyler ES	1st floor hallway across from Girl's Room (low)	12/24/15	< 1		
TES-1224-6B	Tyler ES	1st floor hallway across from Girl's Room (low)	12/24/15	< 1		
TES-1224-7A	Tyler ES	1st floor hallway adjacent to Classroom 142 (high)	12/24/15	< 1		
TES-1228-7B	Tyler ES	1st floor hallway adjacent to Classroom 142 (high)	12/24/15	< 1		
TES-1224-8A	Tyler ES	1st floor hallway adjacent to Classroom 142 (low)	12/24/15	< 1		
TES-1224-8B	Tyler ES	1st floor hallway adjacent to Classroom 142 (low)	12/24/15	< 1		
TES-1224-9A	Tyler ES	1st floor hallway adjacent to Electrical Room 138 (high)	12/24/15	< 1		
TES-1224-9B	Tyler ES	1st floor hallway adjacent to Electrical Room 138 (high)	12/24/15	< 1		
TES-1224-10A	Tyler ES	1st floor hallway adjacent to Electrical Room 138 (low)	12/24/15	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
TES-1224-10B	Tyler ES	1st floor hallway adjacent to Electrical Room 138 (low)	12/24/15	< 1		
TES-1224-11A	Tyler ES	Basement floor inside Cafeteria	12/24/15	< 1		
TES-1224-11B	Tyler ES	Basement floor inside Cafeteria	12/24/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
VN-1120-1A	Van Ness ES	2nd floor hallway across from Stairwell B (high)	11/20/15	< 1		
VN-1120-1B	Van Ness ES	2nd floor hallway across from Stairwell B (high)	11/20/15	< 1		
VN-1120-2A	Van Ness ES	2nd floor hallway across from Stairwell B (low)	11/20/15	< 1		
VN-1120-2B	Van Ness ES	2nd floor hallway across from Stairwell B (low)	11/20/15	< 1		
VN-1120-3A	Van Ness ES	1st floor hallway across from Laundry Room 135 (high)	11/20/15	< 1		
VN-1120-3B	Van Ness ES	1st floor hallway across from Laundry Room 135 (high)	11/20/15	< 1		
VN-1120-4A	Van Ness ES	1st floor hallway across from Laundry Room 135 (low)	11/20/15	< 1		
VN-1120-4B	Van Ness ES	1st floor hallway across from Laundry Room 135 (low)	11/20/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
WJ-0129-1A	Walker Jones ES	3rd floor inside Staff Lounge 300	1/29/16	< 1		
WJ-0129-1B	Walker Jones ES	3rd floor inside Staff Lounge 300	1/29/16	< 1		
WJ-0129-2A	Walker Jones ES	3rd floor hallway adjacent to Girl's Room (high)	1/29/16	< 1		
WJ-0129-2B	Walker Jones ES	3rd floor hallway adjacent to Girl's Room (high)	1/29/16	< 1		
WJ-0129-3A	Walker Jones ES	3rd floor hallway adjacent to Girl's Room (low)	1/29/16	< 1		
WJ-0129-3B	Walker Jones ES	3rd floor hallway adjacent to Girl's Room (low)	1/29/16	< 1		
WJ-0129-4A	Walker Jones ES	3rd floor inside Classroom 320 (clockwise from left)	1/29/16	1.4		
WJ-0129-4B	Walker Jones ES	3rd floor inside Classroom 320	1/29/16	< 1		
WJ-0129-5A	Walker Jones ES	3rd floor inside Classroom 320	1/29/16	2.4		
WJ-0129-5B	Walker Jones ES	3rd floor inside Classroom 320	1/29/16	< 1		
WJ-0129-6A	Walker Jones ES	3rd floor inside Classroom 320	1/29/16	11		
WJ-0129-6B	Walker Jones ES	3rd floor inside Classroom 320	1/29/16	< 1		
WJ-0129-7A	Walker Jones ES	3rd floor inside Classroom 320	1/29/16	< 1		
WJ-0129-7B	Walker Jones ES	3rd floor inside Classroom 320	1/29/16	2.9		
WJ-0129-8A	Walker Jones ES	3rd floor inside Classroom 324 (clockwise from left)	1/29/16	< 1		
WJ-0129-8B	Walker Jones ES	3rd floor inside Classroom 324	1/29/16	< 1		
WJ-0129-9A	Walker Jones ES	3rd floor inside Classroom 324	1/29/16	< 1		
WJ-0129-9B	Walker Jones ES	3rd floor inside Classroom 324	1/29/16	< 1		
WJ-0129-10A	Walker Jones ES	3rd floor inside Classroom 324	1/29/16	2.5		
WJ-0129-10B	Walker Jones ES	3rd floor inside Classroom 324	1/29/16	< 1		
WJ-0129-11A	Walker Jones ES	2nd floor inside Classroom 206	1/29/16	< 1		
WJ-0129-11B	Walker Jones ES	2nd floor inside Classroom 206	1/29/16	< 1		
WJ-0129-12A	Walker Jones ES	2nd floor inside Classroom 208	1/29/16	2.5		
WJ-0129-12B	Walker Jones ES	2nd floor inside Classroom 208	1/29/16	< 1		
WJ-0129-13A	Walker Jones ES	2nd floor inside Classroom 210	1/29/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
WJ-0129-13B	Walker Jones ES	2nd floor inside Classroom 210	1/29/16	< 1		
WJ-0129-14A	Walker Jones ES	2nd floor inside Classroom 212	1/29/16	1.4		
WJ-0129-14B	Walker Jones ES	2nd floor inside Classroom 212	1/29/16	< 1		
WJ-0129-15A	Walker Jones ES	2nd floor hallway adjacent to Girl's Room (high)	1/29/16	< 1		
WJ-0129-15B	Walker Jones ES	2nd floor hallway adjacent to Girl's Room (high)	1/29/16	< 1		
WJ-0129-16A	Walker Jones ES	2nd floor hallway adjacent to Girl's Room (low)	1/29/16	< 1		
WJ-0129-16B	Walker Jones ES	2nd floor hallway adjacent to Girl's Room (low)	1/29/16	< 1		
WJ-0129-17A	Walker Jones ES	2nd floor inside Classroom 220	1/29/16	< 1		
WJ-0129-17B	Walker Jones ES	2nd floor inside Classroom 220	1/29/16	< 1		
WJ-0129-18A	Walker Jones ES	2nd floor inside Classroom 217	1/29/16	< 1		
WJ-0129-18B	Walker Jones ES	2nd floor inside Classroom 217	1/29/16	< 1		
WJ-0129-19A	Walker Jones ES	2nd floor inside Classroom 222	1/29/16	< 1		
WJ-0129-19B	Walker Jones ES	2nd floor inside Classroom 222	1/29/16	< 1		
WJ-0129-20A	Walker Jones ES	2nd floor inside Classroom 224	1/29/16	< 1		
WJ-0129-20B	Walker Jones ES	2nd floor inside Classroom 224	1/29/16	< 1		
WJ-0129-21A	Walker Jones ES	2nd floor inside Classroom 219	1/29/16	< 1		
WJ-0129-21B	Walker Jones ES	2nd floor inside Classroom 219	1/29/16	< 1		
WJ-0129-22A	Walker Jones ES	2nd floor inside Classroom 221	1/29/16	< 1		
WJ-0129-22B	Walker Jones ES	2nd floor inside Classroom 221	1/29/16	< 1		
WJ-0129-23A	Walker Jones ES	2nd floor inside Classroom 226	1/29/16	< 1		
WJ-0129-23B	Walker Jones ES	2nd floor inside Classroom 226	1/29/16	< 1		
WJ-0129-24A	Walker Jones ES	2nd floor inside Classroom 227 (left)	1/29/16	9.5		
WJ-0129-24B	Walker Jones ES	2nd floor inside Classroom 227 (left)	1/29/16	2.1		
WJ-0129-25A	Walker Jones ES	2nd floor inside Classroom 227 (right)	1/29/16	< 1		
WJ-0129-25B	Walker Jones ES	2nd floor inside Classroom 227 (right)	1/29/16	< 1		
WJ-0129-26A	Walker Jones ES	1st floor inside Classroom 104	1/29/16	< 1		
WJ-0129-26B	Walker Jones ES	1st floor inside Classroom 104	1/29/16	< 1		
WJ-0129-27A	Walker Jones ES	1st floor inside Classroom 103	1/29/16	< 1		
WJ-0129-27B	Walker Jones ES	1st floor inside Classroom 103	1/29/16	< 1		
WJ-0129-28A	Walker Jones ES	1st floor inside Classroom 106	1/29/16	< 1		
WJ-0129-28B	Walker Jones ES	1st floor inside Classroom 106	1/29/16	< 1		
WJ-0129-29A	Walker Jones ES	1st floor inside Classroom 105	1/29/16	< 1		
WJ-0129-29B	Walker Jones ES	1st floor inside Classroom 105	1/29/16	< 1		
WJ-0129-30A	Walker Jones ES	1st floor inside Classroom 108	1/29/16	< 1		
WJ-0129-30B	Walker Jones ES	1st floor inside Classroom 108	1/29/16	< 1		
WJ-0129-31A	Walker Jones ES	1st floor hallway adjacent to Girl's Room (high)	1/29/16	< 1		
WJ-0129-31B	Walker Jones ES	1st floor hallway adjacent to Girl's Room (high)	1/29/16	< 1		
WJ-0129-32A	Walker Jones ES	1st floor hallway adjacent to Girl's Room (low)	1/29/16	< 1		
WJ-0129-32B	Walker Jones ES	1st floor hallway adjacent to Girl's Room (low)	1/29/16	< 1		
WJ-0129-33A	Walker Jones ES	1st floor inside Classroom 115	1/29/16	< 1		
WJ-0129-33B	Walker Jones ES	1st floor inside Classroom 115	1/29/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
WJ-0129-34A	Walker Jones ES	1st floor inside Classroom 120	1/29/16	< 1		
WJ-0129-34B	Walker Jones ES	1st floor inside Classroom 120	1/29/16	< 1		
WJ-0129-35A	Walker Jones ES	1st floor inside Classroom 122	1/29/16	< 1		
WJ-0129-35B	Walker Jones ES	1st floor inside Classroom 122	1/29/16	< 1		
WJ-0129-36A	Walker Jones ES	1st floor inside Classroom 117	1/29/16	1		
WJ-0129-36B	Walker Jones ES	1st floor inside Classroom 117	1/29/16	< 1		
WJ-0129-37A	Walker Jones ES	1st floor inside Classroom 119	1/29/16	1.9		
WJ-0129-37B	Walker Jones ES	1st floor inside Classroom 119	1/29/16	< 1		
WJ-0129-38A	Walker Jones ES	1st floor inside Classroom 126	1/29/16	1.5		
WJ-0129-38B	Walker Jones ES	1st floor inside Classroom 128	1/29/16	1.2		
WJ-0129-39A	Walker Jones ES	1st floor inside Classroom 128	1/29/16	< 1		
WJ-0129-39B	Walker Jones ES	1st floor inside Classroom 128	1/29/16	< 1		
WJ-0129-40A	Walker Jones ES	Lower level inside Classroom 034	1/29/16	1.4		
WJ-0129-40B	Walker Jones ES	Lower level inside Classroom 034	1/29/16	< 1		
WJ-0129-41A	Walker Jones ES	Lower level inside Classroom 032	1/29/16	< 1		
WJ-0129-41B	Walker Jones ES	Lower level inside Classroom 032	1/29/16	< 1		
WJ-0129-42A	Walker Jones ES	Lower level across from Classroom 032 (high)	1/29/16	< 1		
WJ-0129-42B	Walker Jones ES	Lower level across from Classroom 032 (high)	1/29/16	< 1		
WJ-0129-43A	Walker Jones ES	Lower level across from Classroom 032 (low)	1/29/16	< 1		
WJ-0129-43B	Walker Jones ES	Lower level across from Classroom 032 (low)	1/29/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
WHS-0120-1A	Washington Metro HS	3rd floor hallway adjacent to Classroom 312	1/20/16	< 1		
WHS-0120-1B	Washington Metro HS	3rd floor hallway adjacent to Classroom 312	1/20/16	< 1		
WHS-0120-2A	Washington Metro HS	2nd floor hallway adjacent to Men's Room	1/20/16	< 1		
WHS-0120-2B	Washington Metro HS	2nd floor hallway adjacent to Men's Room	1/20/16	< 1		
WHS-0120-3A	Washington Metro HS	2nd floor hallway adjacent to Classroom 210	1/20/16	< 1		
WHS-0120-3B	Washington Metro HS	2nd floor hallway adjacent to Classroom 210	1/20/16	< 1		
WHS-0120-4A	Washington Metro HS	1st floor between Men's and Women's Rooms	1/20/16	< 1		
WHS-0120-4B	Washington Metro HS	1st floor between Men's and Women's Rooms	1/20/16	< 1		
WHS-0120-5A	Washington Metro HS	1st floor hallway adjacent to Classroom 106	1/20/16	< 1		
WHS-0120-5B	Washington Metro HS	1st floor hallway adjacent to Classroom 106	1/20/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
WES-1231-1A	Watkins ES	4th floor hallway across from elevator	12/31/15	< 1		
WES-1231-1B	Watkins ES	4th floor hallway across from elevator	12/31/15	< 1		
WES-1231-2A	Watkins ES	4th floor hallway across from Classroom 403	12/31/15	< 1		
WES-1231-2B	Watkins ES	4th floor hallway across from Classroom 403	12/31/15	< 1		
WES-1231-3A	Watkins ES	4th floor hallway across from Classroom 406	12/31/15	< 1		
WES-1231-3B	Watkins ES	4th floor hallway across from Classroom 406	12/31/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
WES-1231-4A	Watkins ES	3rd floor hallway across from Classroom 306	12/31/15	< 1		
WES-1231-4B	Watkins ES	3rd floor hallway across from Classroom 306	12/31/15	< 1		
WES-1231-5A	Watkins ES	3rd floor hallway across from Classroom 303	12/31/15	< 1		
WES-1231-5B	Watkins ES	3rd floor hallway across from Classroom 303	12/31/15	< 1		
WES-1231-6A	Watkins ES	3rd floor hallway across from elevator	12/31/15	< 1		
WES-1231-6B	Watkins ES	3rd floor hallway across from elevator	12/31/15	< 1		
WES-1231-7A	Watkins ES	2nd floor hallway across from elevator	12/31/15	< 1		
WES-1231-7B	Watkins ES	2nd floor hallway across from elevator	12/31/15	< 1		
WES-1231-8A	Watkins ES	2nd floor hallway adjacent to Business Manager's Office 207	12/31/15	< 1		
WES-1231-8B	Watkins ES	2nd floor hallway adjacent to Business Manager's Office 207	12/31/15	< 1		
WES-1231-9A	Watkins ES	1st floor hallway adjacent to Classroom 112	12/31/15	< 1		
WES-1231-9B	Watkins ES	1st floor hallway adjacent to Classroom 112	12/31/15	< 1		
WES-1231-10A	Watkins ES	1st floor hallway across from Classroom 108	12/31/15	< 1		
WES-1231-10B	Watkins ES	1st floor hallway across from Classroom 108	12/31/15	< 1		
WES-1231-11A	Watkins ES	1st floor hallway across from elevator	12/31/15	< 1		
WES-1231-11B	Watkins ES	1st floor hallway across from elevator	12/31/15	2.5		
				<b>Percentage of Passed Samples</b>		<b>100.00%</b>
				<b>Percentage of Failed Samples</b>		<b>0.00%</b>
WES-0208-1A	West ES	Mezzanine level in Library	2/8/16	< 1		
WES-0208-1B	West ES	Mezzanine level in Library	2/8/16	< 1		
WES-0208-2A	West ES	2nd floor inside Teacher's Lounge	2/8/16	< 1		
WES-0208-2B	West ES	2nd floor inside Teacher's Lounge	2/8/16	< 1		
WES-0208-3A	West ES	2nd floor across from Teacher's Lounge	2/8/16	< 1		
WES-0208-3B	West ES	2nd floor across from Teacher's Lounge	2/8/16	< 1		
WES-0208-4A	West ES	2nd floor inside Multi-Purpose Room	2/8/16	< 1		
WES-0208-4B	West ES	2nd floor inside Multi-Purpose Room	2/8/16	< 1		
WES-0208-5A	West ES	2nd floor hallway across from Multi-Purpose Room (high)	2/8/16	< 1		
WES-0208-5B	West ES	2nd floor hallway across from Multi-Purpose Room (high)	2/8/16	< 1		
WES-0208-6A	West ES	2nd floor hallway across from Multi-Purpose Room (low)	2/8/16	< 1		
WES-0208-6B	West ES	2nd floor hallway across from Multi-Purpose Room (low)	2/8/16	< 1		
WES-0208-7A	West ES	2nd floor inside Learning Center (right)	2/8/16	< 1		
WES-0208-7B	West ES	2nd floor inside Learning Center (right)	2/8/16	< 1		
WES-0208-8A	West ES	1st floor inside Health Suite	2/8/16	< 1		
WES-0208-8B	West ES	1st floor inside Health Suite	2/8/16	< 1		
WES-0208-9A	West ES	1st floor hallway adjacent to Women's Room	2/8/16	< 1		
WES-0208-9B	West ES	1st floor hallway adjacent to Women's Room	2/8/16	< 1		
WES-0208-10A	West ES	1st floor hallway adjacent to Main Office	2/8/16	< 1		
WES-0208-10B	West ES	1st floor hallway adjacent to Main Office	2/8/16	< 1		
WES-0208-11A	West ES	1st floor hallway between Men's and Women's Rooms	2/8/16	< 1		
WES-0208-11B	West ES	1st floor hallway between Men's and Women's Rooms	2/8/16	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
WES-0208-12A	West ES	1st floor inside Pre-School/Kindergarten near Boy's Room	2/8/16	< 1		
WES-0208-12B	West ES	1st floor inside Pre-School/Kindergarten near Boy's Room	2/8/16	< 1		
WES-0208-13A	West ES	1st floor inside Pre-School/Kindergarten near Restroom	2/8/16	< 1		
WES-0208-13B	West ES	1st floor inside Pre-School/Kindergarten near Restroom	2/8/16	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
WEC-1218-1A	Wheatley EC	2nd floor hallway adjacent to Classroom 203 (high)	12/18/15	< 1		
WEC-1218-1B	Wheatley EC	2nd floor hallway adjacent to Classroom 203 (high)	12/18/15	< 1		
WEC-1218-2A	Wheatley EC	2nd floor hallway adjacent to Classroom 203 (low)	12/18/15	< 1		
WEC-1218-2B	Wheatley EC	2nd floor hallway adjacent to Classroom 203 (low)	12/18/15	< 1		
WEC-1218-3A	Wheatley EC	2nd floor hallway across from Social Worker 232 (high)	12/18/15	< 1		
WEC-1218-3B	Wheatley EC	2nd floor hallway across from Social Worker 232 (high)	12/18/15	< 1		
WEC-1218-4A	Wheatley EC	2nd floor hallway across from Social Worker 232 (low)	12/18/15	< 1		
WEC-1218-4B	Wheatley EC	2nd floor hallway across from Social Worker 232 (low)	12/18/15	< 1		
WEC-1218-5A	Wheatley EC	2nd floor inside Classroom 222	12/18/15	< 1		
WEC-1218-5B	Wheatley EC	2nd floor inside Classroom 222	12/18/15	< 1		
WEC-1218-6A	Wheatley EC	2nd floor inside Classroom 224	12/18/15	< 1		
WEC-1218-6B	Wheatley EC	2nd floor inside Classroom 224	12/18/15	< 1		
WEC-1218-7A	Wheatley EC	2nd floor inside Classroom 227	12/18/15	< 1		
WEC-1218-7B	Wheatley EC	2nd floor inside Classroom 227	12/18/15	< 1		
WEC-1218-8A	Wheatley EC	2nd floor inside Classroom 229	12/18/15	< 1		
WEC-1218-8B	Wheatley EC	2nd floor inside Classroom 229	12/18/15	< 1		
WEC-1218-9A	Wheatley EC	2nd floor inside Classroom 234	12/18/15	< 1		
WEC-1218-9B	Wheatley EC	2nd floor inside Classroom 234	12/18/15	< 1		
WEC-1218-10A	Wheatley EC	2nd floor inside Classroom 207	12/18/15	< 1		
WEC-1218-10B	Wheatley EC	2nd floor inside Classroom 207	12/18/15	< 1		
WEC-1218-11A	Wheatley EC	2nd floor inside Classroom 215	12/18/15		23	Filter Installed.
WEC-1218-11B	Wheatley EC	2nd floor inside Classroom 215	12/18/15	3.7		
WEC-0205-1A	Wheatley EC	2nd floor inside Classroom 215 (Retest)	2/5/16	< 1		
WEC-0205-1B	Wheatley EC	2nd floor inside Classroom 215 (Retest)	2/5/16	< 1		
WEC-1218-12A	Wheatley EC	2nd floor inside Classroom 203	12/18/15	< 1		
WEC-1218-12B	Wheatley EC	2nd floor inside Classroom 203	12/18/15	< 1		
WEC-1218-13A	Wheatley EC	2nd floor inside Counselor Room 225	12/18/15	< 1		
WEC-1218-13B	Wheatley EC	2nd floor inside Counselor Room 225	12/18/15	< 1		
WEC-1218-14A	Wheatley EC	1st floor inside Classroom 103	12/18/15	< 1		
WEC-1218-14B	Wheatley EC	1st floor inside Classroom 103	12/18/15	< 1		
WEC-1218-15A	Wheatley EC	1st floor inside Classroom 111	12/18/15	< 1		
WEC-1218-15B	Wheatley EC	1st floor inside Classroom 111	12/18/15	< 1		
WEC-1218-16A	Wheatley EC	1st floor inside Classroom 113	12/18/15	5.7		
WEC-1218-16B	Wheatley EC	1st floor inside Classroom 113	12/18/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
WEC-1218-17A	Wheatley EC	1st floor inside Classroom 115	12/18/15	< 1		
WEC-1218-17B	Wheatley EC	1st floor inside Classroom 115	12/18/15	< 1		
WEC-1218-18A	Wheatley EC	1st floor inside Classroom 107	12/18/15	< 1		
WEC-1218-18B	Wheatley EC	1st floor inside Classroom 107	12/18/15	< 1		
WEC-1218-19A	Wheatley EC	1st floor inside Classroom 136	12/18/15	< 1		
WEC-1218-19B	Wheatley EC	1st floor inside Classroom 136	12/18/15	< 1		
WEC-1218-20A	Wheatley EC	1st floor inside Classroom 135	12/18/15	< 1		
WEC-1218-20B	Wheatley EC	1st floor inside Classroom 135	12/18/15	< 1		
WEC-1218-21A	Wheatley EC	1st floor hallway across from Storage Room 133 (high)	12/18/15	< 1		
WEC-1218-21B	Wheatley EC	1st floor hallway across from Storage Room 133 (high)	12/18/15	< 1		
WEC-1218-22A	Wheatley EC	1st floor hallway across from Storage Room 133 (low)	12/18/15	< 1		
WEC-1218-22B	Wheatley EC	1st floor hallway across from Storage Room 133 (low)	12/18/15	< 1		
WEC-1218-23A	Wheatley EC	1st floor inside Classroom 123	12/18/15	< 1		
WEC-1218-23B	Wheatley EC	1st floor inside Classroom 123	12/18/15	< 1		
WEC-1218-24A	Wheatley EC	1st floor inside Classroom 125	12/18/15	< 1		
WEC-1218-24B	Wheatley EC	1st floor inside Classroom 125	12/18/15	< 1		
WEC-1218-25A	Wheatley EC	Ground floor inside Classroom G08	12/18/15	< 1		
WEC-1218-25B	Wheatley EC	Ground floor inside Classroom G08	12/18/15	< 1		
WEC-1218-26A	Wheatley EC	Ground floor inside Classroom G05	12/18/15	< 1		
WEC-1218-26B	Wheatley EC	Ground floor inside Classroom G05	12/18/15	< 1		
WEC-1218-27A	Wheatley EC	Ground floor hallway adjacent to Conference Room G46 (high)	12/18/15	< 1		
WEC-1218-27B	Wheatley EC	Ground floor hallway adjacent to Conference Room G46 (high)	12/18/15	< 1		
WEC-1218-28A	Wheatley EC	Ground floor hallway adjacent to Conference Room G46 (low)	12/18/15	< 1		
WEC-1218-28B	Wheatley EC	Ground floor hallway adjacent to Conference Room G46 (low)	12/18/15	< 1		
WEC-1218-29A	Wheatley EC	Ground floor inside Classroom G51	12/18/15	< 1		
WEC-1218-29B	Wheatley EC	Ground floor inside Classroom G51	12/18/15	< 1		
WEC-1218-30A	Wheatley EC	Ground floor inside Classroom G54	12/18/15	< 1		
WEC-1218-30B	Wheatley EC	Ground floor inside Classroom G54	12/18/15	< 1		
WEC-1218-31A	Wheatley EC	Ground floor inside Classroom G57	12/18/15	< 1		
WEC-1218-31B	Wheatley EC	Ground floor inside Classroom G57	12/18/15	< 1		
WEC-1218-32A	Wheatley EC	Ground floor inside Classroom G59	12/18/15	< 1		
WEC-1218-32B	Wheatley EC	Ground floor inside Classroom G59	12/18/15	< 1		
			<b>Percentage of Passed Samples</b>			<b>98.48%</b>
			<b>Percentage of Failed Samples</b>			<b>1.52%</b>
WES-0212-1A	Whittier ES	3rd floor hallway adjacent to Classroom 310	2/12/16	< 1		
WES-0212-1B	Whittier ES	3rd floor hallway adjacent to Classroom 310	2/12/16	1.2		
WES-0212-2A	Whittier ES	3rd floor hallway adjacent to Classroom 308	2/12/16	< 1		
WES-0212-2B	Whittier ES	3rd floor hallway adjacent to Classroom 308	2/12/16	1.5		
WES-0212-3A	Whittier ES	2nd floor hallway adjacent to Health Suite 227	2/12/16	< 1		
WES-0212-3B	Whittier ES	2nd floor hallway adjacent to Health Suite 227	2/12/16	< 1		

SY 2016 Lead in Water Sampling Results

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
WES-0212-4A	Whittier ES	2nd floor hallway adjacent to Classroom 230	2/12/16	< 1		
WES-0212-4B	Whittier ES	2nd floor hallway adjacent to Classroom 230	2/12/16	< 1		
WES-0212-5A	Whittier ES	1st floor hallway adjacent to Book Room 138	2/12/16	< 1		
WES-0212-5B	Whittier ES	1st floor hallway adjacent to Book Room 138	2/12/16	< 1		
WES-0212-6A	Whittier ES	1st floor hallway across from Gym	2/12/16	< 1		
WES-0212-6B	Whittier ES	1st floor hallway across from Gym	2/12/16	< 1		
WES-0212-7A	Whittier ES	2nd floor hallway across from Classroom 201	2/12/16	1.3		
WES-0212-7B	Whittier ES	2nd floor hallway across from Classroom 201	2/12/16	1.9		
WES-0212-8A	Whittier ES	1st floor hallway across from Classroom 101	2/12/16	1.8		
WES-0212-8B	Whittier ES	1st floor hallway across from Classroom 101	2/12/16	1.8		
WES-0212-9A	Whittier ES	Basement floor hallway across from Classroom 002	2/12/16	3.3		
WES-0212-9B	Whittier ES	Basement floor hallway across from Classroom 002	2/12/16	1.2		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
	Wilson HS					
	Wilson HS					
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
HDW-1008-1A	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Lab 342	10/8/15	< 1		
HDW-1008-1B	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Lab 342	10/8/15	< 1		
HDW-1008-2A	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Lab 333	10/8/15	< 1		
HDW-1008-2B	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Lab 333	10/8/15	< 1		
HDW-1008-3A	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Classroom 317 (high)	10/8/15	< 1		
HDW-1008-3B	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Classroom 317 (high)	10/8/15	< 1		
HDW-1008-4A	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Classroom 317 (low)	10/8/15	< 1		
HDW-1008-4B	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Classroom 317 (low)	10/8/15	< 1		
HDW-1008-5A	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Janitor Closet 209 B (high)	10/8/15	< 1		
HDW-1008-5B	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Janitor Closet 209 B (high)	10/8/15	< 1		
HDW-1008-6A	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Janitor Closet 209 B (low)	10/8/15	< 1		
HDW-1008-6B	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Janitor Closet 209 B (low)	10/8/15	< 1		
HDW-1008-7A	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Classroom 238 (high)	10/8/15	< 1		
HDW-1008-7B	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Classroom 238 (high)	10/8/15	< 1		
HDW-1008-8A	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Classroom 238 (low)	10/8/15	< 1		
HDW-1008-8B	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Classroom 238 (low)	10/8/15	< 1		
HDW-1008-9A	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Classroom 237 (high)	10/8/15	< 1		
HDW-1008-9B	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Classroom 237 (high)	10/8/15	< 1		
HDW-1008-10A	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Classroom 237 (low)	10/8/15	< 1		
HDW-1008-10B	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Classroom 237 (low)	10/8/15	< 1		

Sample Identification	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
HDW-1008-11A	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Electric Room 222 (high)	10/8/15	< 1		
HDW-1008-11B	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Electric Room 222 (high)	10/8/15	< 1		
HDW-1008-12A	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Electric Room 222 (low)	10/8/15	< 1		
HDW-1008-12B	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Electric Room 222 (low)	10/8/15	< 1		
HDW-1008-13A	Woodson SHS ( H.D. )	1st floor inside Cafeteria (high)	10/8/15	< 1		
HDW-1008-13B	Woodson SHS ( H.D. )	1st floor inside Cafeteria (high)	10/8/15	< 1		
HDW-1008-14A	Woodson SHS ( H.D. )	1st floor inside Cafeteria (low)	10/8/15	< 1		
HDW-1008-14B	Woodson SHS ( H.D. )	1st floor inside Cafeteria (low)	10/8/15	< 1		
HDW-1008-15A	Woodson SHS ( H.D. )	1st floor hallway adjacent to Main Office (high)	10/8/15	< 1		
HDW-1008-15B	Woodson SHS ( H.D. )	1st floor hallway adjacent to Main Office (high)	10/8/15	< 1		
HDW-1008-16A	Woodson SHS ( H.D. )	1st floor hallway adjacent to Main Office (low)	10/8/15	< 1		
HDW-1008-16B	Woodson SHS ( H.D. )	1st floor hallway adjacent to Main Office (low)	10/8/15	< 1		
HDW-1008-17A	Woodson SHS ( H.D. )	Lower level inside Pool Area (high)	10/8/15	< 1		
HDW-1008-17B	Woodson SHS ( H.D. )	Lower level inside Pool Area (high)	10/8/15	< 1		
HDW-1008-18A	Woodson SHS ( H.D. )	Lower level inside Pool Area (low)	10/8/15	< 1		
HDW-1008-18B	Woodson SHS ( H.D. )	Lower level inside Pool Area (low)	10/8/15	< 1		
HDW-1008-19A	Woodson SHS ( H.D. )	Lower level inside Big Gym (high)	10/8/15	< 1		
HDW-1008-19B	Woodson SHS ( H.D. )	Lower level inside Big Gym (high)	10/8/15	< 1		
HDW-1008-20A	Woodson SHS ( H.D. )	Lower level inside Big Gym (low)	10/8/15	< 1		
HDW-1008-20B	Woodson SHS ( H.D. )	Lower level inside Big Gym (low)	10/8/15	< 1		
HDW-1008-21A	Woodson SHS ( H.D. )	Lower level inside Small Gym (high)	10/8/15	< 1		
HDW-1008-21B	Woodson SHS ( H.D. )	Lower level inside Small Gym (high)	10/8/15	< 1		
HDW-1008-22A	Woodson SHS ( H.D. )	Lower level inside Small Gym (low)	10/8/15	< 1		
HDW-1008-22B	Woodson SHS ( H.D. )	Lower level inside Small Gym (low)	10/8/15	< 1		
HDW-1008-23A	Woodson SHS ( H.D. )	Lower level inside Weight Room (high)	10/8/15	< 1		
HDW-1008-23B	Woodson SHS ( H.D. )	Lower level inside Weight Room (high)	10/8/15	< 1		
HDW-1008-24A	Woodson SHS ( H.D. )	Lower level inside Weight Room (low)	10/8/15	< 1		
HDW-1008-24B	Woodson SHS ( H.D. )	Lower level inside Weight Room (low)	10/8/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
	Youth Services Center					
	Youth Services Center					
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
<b>Totals/Percentages of All Tested Schools</b>						
<b>Total Number of Schools Tested</b>					<b>106</b>	
<b>Total Passed Samples</b>					<b>3719</b>	
<b>Total Failed Samples</b>					<b>15</b>	
<b>Total Samples Collected</b>					<b>3734</b>	
<b>Percentage of Passed Samples</b>					<b>99.60%</b>	

