GOVERNMENT OF THE DISTRICT OF COLUMBIA DEPARTMENT OF GENERAL SERVICES







Launch Pad Initiative HISTORICAL EASTERN MARKET PRESERVATION & BUILDING RESTORATION Addendum No. 2

Issued: February 13, 2018

This Addendum No. 2 is issued and hereby published on the DGS website February 13, 2018.

Item No. 1

QUESTIONS & ANSWERS

Add/Incorporate:

QUESTIONS & ANSWERS		
QUESTIONS	ANSWERS	
The wiring for the electrical is in exposed conduit and with removal of the wood paneling and replacement to match the existing plaster walls, some rework of the electrical would be needed. In lieu of using what appears to be % metallic conduit exposed could wire mold be used?	Yes, wire mold can be used.	

All other terms and conditions remain unchanged.

- End of Addendum No. 2 -

Contracting Officer