



ADAMS MS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	ADAMS MIDDLE SCHOOL	WS- 003970	8/23/2016	1	Cooler	In hallway adjacent to room 102	FT-82016-003970-A	< 1	FT-82016-003970-B	< 1
2	ADAMS MIDDLE SCHOOL	WS- 003973	8/23/2016	1	Health Suite	In health suite Mid	FT-82016-003973-A	< 1	FT-82016-003973-B	< 1
3	ADAMS MIDDLE SCHOOL	WS- 003974	8/23/2016	1	Health Suite	In health suite Right	FT-72016-003974-A	< 1	FT-72016-003974-B	< 1
4	ADAMS MIDDLE SCHOOL	WS- 003975	8/23/2016	1	Health Suite	In health suite Left	FT-82016-003975-A	< 1	FT-82016-003975-B	< 1
5	ADAMS MIDDLE SCHOOL	WS- 003976	8/23/2016	1	Cooler	In cafeteria	FT-82016-003976-A	< 1	FT-82016-003976-B	< 1
6	ADAMS MIDDLE SCHOOL	WS- 003977	8/23/2016	1	Food Prep Sink	In kitchen	FT-82016-003977-A	< 1	FT-82016-003977-B	< 1
7	ADAMS MIDDLE SCHOOL	WS- 003978	8/23/2016	1	Cooler	In hallway adjacent to room 103	FT-82016-003978-A	< 1	FT-82016-003978-B	< 1
8	ADAMS MIDDLE SCHOOL	WS- 003982	8/23/2016	2	Fountain	In gym on south wall	FT-82016-003982-A	< 1	FT-82016-003982-B	< 1
9	ADAMS MIDDLE SCHOOL	WS- 003983	8/23/2016	2	Fountain	In gym on north wall	FT-82016-003983-A	< 1	FT-82016-003983-B	< 1
10	ADAMS MIDDLE SCHOOL	WS- 003984	8/23/2016	2	Cooler	In hallway adjacent to room 201	FT-82016-003984-A	< 1	FT-82016-003984-B	< 1
11	ADAMS MIDDLE SCHOOL	WS- 003985	8/23/2016	2	Cooler	In hallway adjacent to room 202	FT-82016-003985-A	< 1	FT-82016-003985-B	< 1
12	ADAMS MIDDLE SCHOOL	WS- 003986	8/23/2016	3	Cooler	In hallway adjacent to room 302	FT-82016-003986-A	< 1	FT-82016-003986-B	< 1
13	ADAMS MIDDLE SCHOOL	WS- 003987	8/23/2016	3	Cooler	In hallway adjacent to room 308	FT-82016-003987-A	< 1	FT-82016-003987-B	< 1