



Adams Middle School Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003974	5/18/17	5/18/18	1	Health Suite	In health suite	Right	WF-52017-003974	12/4/17	FT-FY18--52017-003974-A	<1	FT-FY18--52017-003974-B	<1
WS- 003975	5/18/17	5/18/18	1	Health Suite	In health suite	Left	WF-52017-003975	12/4/17	FT-FY18--52017-003975-A	<1	FT-FY18--52017-003975-B	<1
WS- 003980	5/5/17	5/5/18	1	Break Room	In staff lounge		WF-52017-003980	12/4/17	FT-FY18--52017-003980-A	<1	FT-FY18--52017-003980-B	<1
WS- 003982	5/5/17	5/5/18	2	Fountain	In gym on south wall		WF-52017-003982	12/4/17	FT-FY18--52017-003982-A	<1	FT-FY18--52017-003982-B	<1
WS- 003987	5/5/17	5/5/18	3	Cooler	In hallway adjacent to room 308		WF-52017-003987	12/4/17	FT-FY18--52017-003987-A	<1	FT-FY18--52017-003987-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location		Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003977	1	Food Prep Sink	In kitchen		12/4/17	FT-FY18-102017-003977-A	<1	FT-FY18-102017-003977-B	<1