Aiton Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000414	3/15/2021	3/15/2022	1	Health Suite	In health suite	WF-03152021-000414	1/21/2022	FT-FY22-01042022-000414-A	1.5	FT-FY22-01042022-000414-B	<1
WS- 009512	3/15/2021	3/15/2022	1	Cooler	In hallway in lobby	WF-03152021-009512	1/21/2022	FT-FY22-01042022-009512-A	<1	FT-FY22-01042022-009512-B	<1
WS- 009514	3/15/2021	3/15/2022	1	Cooler	In hallway across from health suite	WF-03152021-009514	1/21/2022	FT-FY22-01042022-009514-A	<1	FT-FY22-01042022-009514-B	<1
WS- 009515	3/15/2021	3/15/2022	1	Cooler	In classroom K-1	WF-03152021-009515	1/21/2022	FT-FY22-01042022-009515-A	<1	FT-FY22-01042022-009515-B	<1
WS- 009516	8/30/2021	8/30/2022	1	Classroom Faucet	In classroom K-1	WF-08302021-009516	1/21/2022	FT-FY22-01042022-009516-A	<1	FT-FY22-01042022-009516-B	<1
WS- 009517	8/30/2021	8/30/2022	1	Classroom Faucet	In classroom K-2	WF-08302021-009517	1/21/2022	FT-FY22-01042022-009517-A	2.3	FT-FY22-01042022-009517-B	<1
WS- 009518	3/15/2021	3/15/2022	1	Cooler	In classroom K-2	WF-03152021-009518	1/21/2022	FT-FY22-01042022-009518-A	<1	FT-FY22-01042022-009518-B	<1
WS- 009519	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to room 203	WF-03152021-009519	1/21/2022	FT-FY22-01042022-009519-A	<1	FT-FY22-01042022-009519-B	<1
WS- 009520	3/15/2021	3/15/2022	2	Break Room	In staff lounge across from room 207	WF-03152021-009520	1/21/2022	FT-FY22-01042022-009520-A	<1	FT-FY22-01042022-009520-B	<1
WS- 009521	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to library	WF-03152021-009521	1/21/2022	FT-FY22-01042022-009521-A	<1	FT-FY22-01042022-009521-B	<1
WS- 009522	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to room 301	WF-03152021-009522	1/21/2022	FT-FY22-01042022-009522-A	<1	FT-FY22-01042022-009522-B	<1
WS- 009523	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to room 305	WF-03152021-009523	1/21/2022	FT-FY22-01042022-009523-A	<1	FT-FY22-01042022-009523-B	<1
WS- 009526	8/30/2021	8/30/2022	4	Classroom Faucet	In classroom 401 Right	WF-08302021-009526	1/21/2022	FT-FY22-01042022-009526-A	<1	FT-FY22-01042022-009526-B	<1
WS- 009528	3/15/2021	3/15/2022	4	Cooler	In hallway adjacent to room 401	WF-03152021-009528	1/21/2022	FT-FY22-01042022-009528-A	<1	FT-FY22-01042022-009528-B	<1
WS- 009529	3/15/2021	3/15/2022	4	Cooler	In hallway adjacent to room 406	WF-03152021-009529	1/21/2022	FT-FY22-01042022-009529-A	<1	FT-FY22-01042022-009529-B	<1
WS- 009530	8/30/2021	8/30/2022	3	Classroom Faucet	In classroom 302 Left	WF-08302021-009530	1/21/2022	FT-FY22-01042022-009530-A	<1	FT-FY22-01042022-009530-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009510	1/19/2021	1/19/2022	1	Food Prep Sink	In kitchen east wall Mid	WF-01192021-009510	1/21/2022	FT-FY22-01042022-009510-A	<1	FT-FY22-01042022-009510-B	<1

FY22 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009524	8/30/2021	8/30/2022	3	Classroom Faucet	In classroom 301	WF-08302021-009524	1/21/2022	FT-FY22-01042022-009524-A	5.9	FT-FY22-01042022-009524-B	<1