



Aiton Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000414	3/24/2020	3/24/2021	1	Health Suite	In health suite	WF-03242020-000414	3/10/2021	FT-FY21-032021-000414-A	<1	FT-FY21-032021-000414-B	<1
WS- 009512	3/24/2020	3/24/2021	1	Cooler	In hallway in lobby	WF-03242020-009512	3/10/2021	FT-FY21-032021-009512-A	<1	FT-FY21-032021-009512-B	<1
WS- 009514	3/24/2020	3/24/2021	1	Cooler	In hallway across from health suite	WF-03242020-009514	3/10/2021	FT-FY21-032021-009514-A	<1	FT-FY21-032021-009514-B	<1
WS- 009515	3/24/2020	3/24/2021	1	Cooler	In classroom K-1	WF-03242020-009515	3/10/2021	FT-FY21-032021-009515-A	<1	FT-FY21-032021-009515-B	<1
WS- 009516	9/9/2020	9/9/2021	1	Classroom Faucet	In classroom K-1	WF-09092020-009516	3/10/2021	FT-FY21-032021-009516-A	1.2	FT-FY21-032021-009516-B	<1
WS- 009517	9/9/2020	9/9/2021	1	Classroom Faucet	In classroom K-2	WF-09092020-009517	3/10/2021	FT-FY21-032021-009517-A	<1	FT-FY21-032021-009517-B	<1
WS- 009518	3/24/2020	3/24/2021	1	Cooler	In classroom K-2	WF-03242020-009518	3/10/2021	FT-FY21-032021-009518-A	<1	FT-FY21-032021-009518-B	<1
WS- 009519	3/24/2020	3/24/2021	2	Cooler	In hallway adjacent to room 203	WF-03242020-009519	3/10/2021	FT-FY21-032021-009519-A	<1	FT-FY21-032021-009519-B	<1
WS- 009520	3/24/2020	3/24/2021	2	Break Room	In staff lounge across from room 207	WF-03242020-009520	3/10/2021	FT-FY21-032021-009520-A	<1	FT-FY21-032021-009520-B	<1
WS- 009521	3/24/2020	3/24/2021	2	Cooler	In hallway adjacent to library	WF-03242020-009521	3/10/2021	FT-FY21-032021-009521-A	<1	FT-FY21-032021-009521-B	<1
WS- 009522	3/24/2020	3/24/2021	3	Cooler	In hallway adjacent to room 301	WF-03242020-009522	3/10/2021	FT-FY21-032021-009522-A	<1	FT-FY21-032021-009522-B	<1
WS- 009523	3/24/2020	3/24/2021	3	Cooler	In hallway adjacent to room 305	WF-03242020-009523	3/10/2021	FT-FY21-032021-009523-A	<1	FT-FY21-032021-009523-B	<1
WS- 009524	9/9/2020	9/9/2021	3	Classroom Faucet	In classroom 301	WF-09092020-009524	3/10/2021	FT-FY21-032021-009524-A	<1	FT-FY21-032021-009524-B	<1
WS- 009526	9/9/2020	9/9/2021	4	Classroom Faucet	In classroom 401 Right	WF-09092020-009526	3/10/2021	FT-FY21-032021-009526-A	<1	FT-FY21-032021-009526-B	<1
WS- 009529	3/24/2020	3/24/2021	4	Cooler	In hallway adjacent to room 406	WF-03242020-009529	3/10/2021	FT-FY21-032021-009529-A	<1	FT-FY21-032021-009529-B	1.8
WS- 009530	9/9/2020	9/9/2021	3	Classroom Faucet	In classroom 302 Left	WF-09092020-009530	3/10/2021	FT-FY21-032021-009530-A	<1	FT-FY21-032021-009530-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009509	1/19/2021	1/19/2022	1	Food Prep Sink	In kitchen east wall Left	WF-01192021-009509	3/10/2021	FT-FY21-032021-009509-A	<1	FT-FY21-032021-009509-B	<1
WS- 009510	1/19/2021	1/19/2022	1	Food Prep Sink	In kitchen east wall Mid	WF-01192021-009510	3/10/2021	FT-FY21-032021-009510-A	<1	FT-FY21-032021-009510-B	<1