



# Amidon Bowen Elementary School Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003366	4/24/2023	4/24/2024	1	Combo Fountain	In classroom 114	High Right	WF-04242023-003366	10/16/2023	FT-FY24-09182023-003366-A	<1	FT-FY24-09182023-003366-B	<1
WS- 003367	8/23/2023	8/23/2024	1	Classroom Faucet	In classroom 114	High Right	WF-08232023-003367	10/16/2023	FT-FY24-09182023-003367-A	<1	FT-FY24-09182023-003367-B	<1
WS- 003368	4/24/2023	4/24/2024	1	Combo Fountain	In classroom 114	Low Left	WF-04242023-003368	10/16/2023	FT-FY24-09182023-003368-A	<1	FT-FY24-09182023-003368-B	<1
WS- 003369	8/23/2023	8/23/2024	1	Combo Faucet	In classroom 114	Low Left	WF-08232023-003369	10/16/2023	FT-FY24-09182023-003369-A	<1	FT-FY24-09182023-003369-B	<1
WS- 003370	4/24/2023	4/24/2024	2	Cooler	In hallway adjacent to stairwell C		WF-04242023-003370	10/16/2023	FT-FY24-09182023-003370-A	<1	FT-FY24-09182023-003370-B	<1
WS- 003375	4/24/2023	4/24/2024	2	Bottle Filler	In hallway adjacent to stairwell C		WF-04242023-003375	10/16/2023	FT-FY24-09182023-003375-A	<1	FT-FY24-09182023-003375-B	<1
WS- 003376	4/24/2023	4/24/2024	1	Bottle Filler	In hallway adjacent to gym		WF-04242023-003376	10/16/2023	FT-FY24-09182023-003376-A	<1	FT-FY24-09182023-003376-B	<1
WS- 003377	4/24/2023	4/24/2024	1	Bottle Filler	In hallway adjacent to health suite A116		WF-04242023-003377	10/16/2023	FT-FY24-09182023-003377-A	<1	FT-FY24-09182023-003377-B	<1
WS- 003542	8/23/2023	8/23/2024	1	Combo Faucet	In classroom B126		WF-08232023-003542	10/16/2023	FT-FY24-09182023-003542-A	<1	FT-FY24-09182023-003542-B	<1
WS- 003543	4/24/2023	4/24/2024	1	Combo Fountain	In classroom B126		WF-04242023-003543	10/16/2023	FT-FY24-09182023-003543-A	<1	FT-FY24-09182023-003543-B	<1
WS- 003544	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to classroom B128	High Left	WF-04242023-003544	10/16/2023	FT-FY24-09182023-003544-A	<1	FT-FY24-09182023-003544-B	<1
WS- 003545	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to classroom B128	Low Right	WF-04242023-003545	10/16/2023	FT-FY24-09182023-003545-A	<1	FT-FY24-09182023-003545-B	<1
WS- 003546	8/23/2023	8/23/2024	1	Combo Faucet	In classroom B128		WF-08232023-003546	10/16/2023	FT-FY24-09182023-003546-A	<1	FT-FY24-09182023-003546-B	<1
WS- 003547	4/24/2023	4/24/2024	1	Combo Fountain	In classroom B128		WF-04242023-003547	10/16/2023	FT-FY24-09182023-003547-A	<1	FT-FY24-09182023-003547-B	<1
WS- 003549	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to gym		WF-04242023-003549	10/16/2023	FT-FY24-09182023-003549-A	<1	FT-FY24-09182023-003549-B	<1
WS- 003555	4/24/2023	4/24/2024	1	Break Room	In first floor lobby adjacent to principal's office B121		WF-04242023-003555	10/16/2023	FT-FY24-09182023-003555-A	<1	FT-FY24-09182023-003555-B	<1
WS- 003558	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to kitchen		WF-04242023-003558	10/16/2023	FT-FY24-09182023-003558-A	<1	FT-FY24-09182023-003558-B	<1
WS- 003559	8/23/2023	8/23/2024	1	Combo Faucet	In classroom A106	High Left	WF-08232023-003559	10/16/2023	FT-FY24-09182023-003559-A	<1	FT-FY24-09182023-003559-B	<1
WS- 003560	4/24/2023	4/24/2024	1	Combo Fountain	In classroom A106	High Left	WF-04242023-003560	10/16/2023	FT-FY24-09182023-003560-A	1.4	FT-FY24-09182023-003560-B	1.1
WS- 003561	8/23/2023	8/23/2024	1	Combo Faucet	In classroom A106	Low Right	WF-08232023-003561	10/16/2023	FT-FY24-09182023-003561-A	<1	FT-FY24-09182023-003561-B	<1
WS- 003562	4/24/2023	4/24/2024	1	Combo Fountain	In classroom A106	Low Right	WF-04242023-003562	10/16/2023	FT-FY24-09182023-003562-A	<1	FT-FY24-09182023-003562-B	<1
WS- 003563	8/23/2023	8/23/2024	1	Combo Faucet	In classroom A103	Low Left	WF-08232023-003563	10/16/2023	FT-FY24-09182023-003563-A	<1	FT-FY24-09182023-003563-B	<1
WS- 003564	4/24/2023	4/24/2024	1	Combo Fountain	In classroom A103	Low Left	WF-04242023-003564	10/16/2023	FT-FY24-09182023-003564-A	<1	FT-FY24-09182023-003564-B	<1
WS- 003565	8/23/2023	8/23/2024	1	Combo Faucet	In classroom A103	High Right	WF-08232023-003565	10/16/2023	FT-FY24-09182023-003565-A	<1	FT-FY24-09182023-003565-B	<1
WS- 003566	4/24/2023	4/24/2024	1	Combo Fountain	In classroom A103	High Right	WF-04242023-003566	10/16/2023	FT-FY24-09182023-003566-A	<1	FT-FY24-09182023-003566-B	<1
WS- 003567	8/23/2023	8/23/2024	1	Combo Faucet	In classroom A105	High Left	WF-08232023-003567	10/16/2023	FT-FY24-09182023-003567-A	<1	FT-FY24-09182023-003567-B	<1
WS- 003568	4/24/2023	4/24/2024	1	Combo Fountain	In classroom A105	High Left	WF-04242023-003568	10/16/2023	FT-FY24-09182023-003568-A	<1	FT-FY24-09182023-003568-B	<1
WS- 003569	8/23/2023	8/23/2024	1	Combo Faucet	In classroom A105	Low Right	WF-08232023-003569	10/16/2023	FT-FY24-09182023-003569-A	<1	FT-FY24-09182023-003569-B	<1
WS- 003570	4/24/2023	4/24/2024	1	Combo Fountain	In classroom A105	Low Right	WF-04242023-003570	10/16/2023	FT-FY24-09182023-003570-A	<1	FT-FY24-09182023-003570-B	<1
WS- 003571	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to health suite A116		WF-04242023-003571	10/16/2023	FT-FY24-09182023-003571-A	<1	FT-FY24-09182023-003571-B	<1
WS- 003572	8/23/2023	8/23/2024	1	Combo Faucet	In classroom A107	Low Left	WF-08232023-003572	10/16/2023	FT-FY24-09182023-003572-A	<1	FT-FY24-09182023-003572-B	<1
WS- 003573	4/24/2023	4/24/2024	1	Combo Fountain	In classroom A107	Low Left	WF-04242023-003573	10/16/2023	FT-FY24-09182023-003573-A	<1	FT-FY24-09182023-003573-B	<1
WS- 003574	8/23/2023	8/23/2024	1	Combo Faucet	In classroom A107	High Right	WF-08232023-003574	10/16/2023	FT-FY24-09182023-003574-A	<1	FT-FY24-09182023-003574-B	<1
WS- 003575	4/24/2023	4/24/2024	1	Combo Fountain	In classroom A107	High Right	WF-04242023-003575	10/16/2023	FT-FY24-09182023-003575-A	<1	FT-FY24-09182023-003575-B	<1
WS- 003576	4/24/2023	4/24/2024	1	Cooler	In health suite A116		WF-04242023-003576	10/16/2023	FT-FY24-09182023-003576-A	<1	FT-FY24-09182023-003576-B	<1

WS-003577	8/23/2023	8/23/2024	2	Combo Faucet	In classroom A212			WF-08232023-003577	10/16/2023	FT-FY24-09182023-003577-A	<1	FT-FY24-09182023-003577-B	<1
WS-003578	4/24/2023	4/24/2024	2	Combo Fountain	In classroom A212			WF-04242023-003578	10/16/2023	FT-FY24-09182023-003578-A	<1	FT-FY24-09182023-003578-B	<1
WS-003579	8/23/2023	8/23/2024	2	Combo Faucet	In classroom A213			WF-08232023-003579	10/16/2023	FT-FY24-09182023-003579-A	<1	FT-FY24-09182023-003579-B	<1
WS-003580	4/24/2023	4/24/2024	2	Combo Fountain	In classroom A213			WF-04242023-003580	10/16/2023	FT-FY24-09182023-003580-A	<1	FT-FY24-09182023-003580-B	<1
WS-003581	8/23/2023	8/23/2024	2	Combo Faucet	In classroom A209			WF-08232023-003581	10/16/2023	FT-FY24-09182023-003581-A	<1	FT-FY24-09182023-003581-B	<1
WS-003582	4/24/2023	4/24/2024	2	Combo Fountain	In classroom A209			WF-04242023-003582	10/16/2023	FT-FY24-09182023-003582-A	<1	FT-FY24-09182023-003582-B	<1
WS-003583	8/23/2023	8/23/2024	2	Combo Faucet	In classroom A208			WF-08232023-003583	10/16/2023	FT-FY24-09182023-003583-A	<1	FT-FY24-09182023-003583-B	<1
WS-003584	4/24/2023	4/24/2024	2	Combo Fountain	In classroom A208			WF-04242023-003584	10/16/2023	FT-FY24-09182023-003584-A	<1	FT-FY24-09182023-003584-B	<1
WS-003585	4/24/2023	4/24/2024	2	Cooler	In hallway between girls' and boys' restrooms	High	Left	WF-04242023-003585	10/16/2023	FT-FY24-09182023-003585-A	<1	FT-FY24-09182023-003585-B	<1
WS-003586	4/24/2023	4/24/2024	2	Cooler	In hallway between girls' and boys' restrooms	Low	Right	WF-04242023-003586	10/16/2023	FT-FY24-09182023-003586-A	<1	FT-FY24-09182023-003586-B	<1
WS-003587	8/23/2023	8/23/2024	2	Combo Faucet	In classroom A202			WF-08232023-003587	10/16/2023	FT-FY24-09182023-003587-A	<1	FT-FY24-09182023-003587-B	<1
WS-003588	4/24/2023	4/24/2024	2	Combo Fountain	In classroom A202			WF-04242023-003588	10/16/2023	FT-FY24-09182023-003588-A	<1	FT-FY24-09182023-003588-B	<1
WS-003589	8/23/2023	8/23/2024	2	Combo Faucet	In classroom B223			WF-08232023-003589	10/16/2023	FT-FY24-09182023-003589-A	<1	FT-FY24-09182023-003589-B	<1
WS-003590	4/24/2023	4/24/2024	2	Combo Fountain	In classroom B223			WF-04242023-003590	10/16/2023	FT-FY24-09182023-003590-A	<1	FT-FY24-09182023-003590-B	<1
WS-003591	8/23/2023	8/23/2024	2	Combo Faucet	In classroom B230			WF-08232023-003591	10/16/2023	FT-FY24-09182023-003591-A	<1	FT-FY24-09182023-003591-B	<1
WS-003592	4/24/2023	4/24/2024	2	Combo Fountain	In classroom B230			WF-04242023-003592	10/16/2023	FT-FY24-09182023-003592-A	<1	FT-FY24-09182023-003592-B	<1
WS-003593	8/23/2023	8/23/2024	2	Combo Faucet	In classroom B225			WF-08232023-003593	10/16/2023	FT-FY24-09182023-003593-A	<1	FT-FY24-09182023-003593-B	<1
WS-003594	4/24/2023	4/24/2024	2	Combo Fountain	In classroom B225			WF-04242023-003594	10/16/2023	FT-FY24-09182023-003594-A	<1	FT-FY24-09182023-003594-B	<1
WS-003595	8/23/2023	8/23/2024	2	Combo Faucet	In classroom B232			WF-08232023-003595	10/16/2023	FT-FY24-09182023-003595-A	<1	FT-FY24-09182023-003595-B	<1
WS-003596	4/24/2023	4/24/2024	2	Combo Fountain	In classroom B232			WF-04242023-003596	10/16/2023	FT-FY24-09182023-003596-A	<1	FT-FY24-09182023-003596-B	<1
WS-003597	8/23/2023	8/23/2024	2	Combo Faucet	In classroom B227			WF-08232023-003597	10/16/2023	FT-FY24-09182023-003597-A	<1	FT-FY24-09182023-003597-B	<1
WS-003598	4/24/2023	4/24/2024	2	Combo Fountain	In classroom B227			WF-04242023-003598	10/16/2023	FT-FY24-09182023-003598-A	<1	FT-FY24-09182023-003598-B	<1
WS-003599	8/23/2023	8/23/2024	2	Combo Faucet	In classroom B236			WF-08232023-003599	10/16/2023	FT-FY24-09182023-003599-A	<1	FT-FY24-09182023-003599-B	<1
WS-003600	4/24/2023	4/24/2024	2	Combo Fountain	In classroom B236			WF-04242023-003600	10/16/2023	FT-FY24-09182023-003600-A	<1	FT-FY24-09182023-003600-B	<1
WS-003601	8/23/2023	8/23/2024	2	Combo Faucet	In classroom B231			WF-08232023-003601	10/16/2023	FT-FY24-09182023-003601-A	<1	FT-FY24-09182023-003601-B	<1
WS-003602	4/24/2023	4/24/2024	2	Combo Fountain	In classroom B231			WF-04242023-003602	10/16/2023	FT-FY24-09182023-003602-A	<1	FT-FY24-09182023-003602-B	<1
WS-003603	4/24/2023	4/24/2024	1	Health Suite	In health suite A116 in bathroom			WF-04242023-003603	10/16/2023	FT-FY24-09182023-003603-A	<1	FT-FY24-09182023-003603-B	<1
WS-004530	8/23/2023	8/23/2024	1	Combo Faucet	In classroom B135			WF-08232023-004530	10/16/2023	FT-FY24-09182023-004530-A	<1	FT-FY24-09182023-004530-B	<1
WS-004531	4/24/2023	4/24/2024	1	Combo Fountain	In classroom B135			WF-04242023-004531	10/16/2023	FT-FY24-09182023-004531-A	<1	FT-FY24-09182023-004531-B	<1
WS-004862	9/28/2023	9/28/2024	1	Combo Fountain	In Room 1	Low	Left	WF-09282023-004862	10/16/2023	FT-FY24-09252023-004862-A	<1	FT-FY24-09252023-004862-B	<1
WS-004864	9/28/2023	9/28/2024	1	Combo Fountain	In Room 1	High	Right	WF-09282023-004864	10/16/2023	FT-FY24-09252023-004864-A	<1	FT-FY24-09252023-004864-B	<1
WS-004866	9/28/2023	9/28/2024	1	Combo Fountain	In Room 2		Left	WF-09282023-004866	10/16/2023	FT-FY24-09252023-004866-A	<1	FT-FY24-09252023-004866-B	<1
WS-004868	9/28/2023	9/28/2024	1	Combo Fountain	In Room 2		Right	WF-09282023-004868	10/16/2023	FT-FY24-09252023-004868-A	<1	FT-FY24-09252023-004868-B	<1
WS-004870	9/28/2023	9/28/2024	2	Combo Fountain	In Room 3	High	Left	WF-09282023-004870	10/16/2023	FT-FY24-09252023-004870-A	<1	FT-FY24-09252023-004870-B	<1
WS-004872	9/28/2023	9/28/2024	2	Combo Fountain	In Room 3	Low	Right	WF-09282023-004872	10/16/2023	FT-FY24-09252023-004872-A	<1	FT-FY24-09252023-004872-B	<1
WS-004874	9/28/2023	9/28/2024	2	Combo Fountain	In Room 4	High	Left	WF-09282023-004874	10/16/2023	FT-FY24-09252023-004874-A	<1	FT-FY24-09252023-004874-B	<1
WS-004876	9/28/2023	9/28/2024	2	Combo Fountain	In Room 4	Low	Right	WF-09282023-004876	10/16/2023	FT-FY24-09252023-004876-A	<1	FT-FY24-09252023-004876-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003556	1/9/2023	1/9/2024	1	Food Prep Sink	In kitchen on south wall (dishwashing hose) Left	WF-01092023-003556	10/16/2023	FT-FY24-09182023-003556-A	<1	FT-FY24-09182023-003556-B	<1
WS- 003557	1/9/2023	1/9/2024	1	Food Prep Sink	In kitchen on south wall Right	WF-01092023-003557	10/16/2023	FT-FY24-09182023-003557-A	<1	FT-FY24-09182023-003557-B	<1
WS- 004860	9/28/2023	9/28/2024	1	Food Prep Sink	In Food prep Room	WF-09282023-004860	10/16/2023	FT-FY24-09252023-004860-A	<1	FT-FY24-09252023-004860-B	<1