



# Amidon Elementary School Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003366	5/10/2021	5/10/2022	1	Combo Fountain	In classroom 114	High	Right	WF-05102021-003366	1/8/2022	FT-FY22-12012021-003366-A	<1	FT-FY22-12012021-003366-B	<1
WS-003367	9/7/2021	9/7/2022	1	Classroom Faucet	In classroom 114	High	Right	WF-09072021-003367	1/8/2022	FT-FY22-12012021-003367-A	<1	FT-FY22-12012021-003367-B	<1
WS-003368	5/10/2021	5/10/2022	1	Combo Fountain	In classroom 114	Low	Left	WF-05102021-003368	1/8/2022	FT-FY22-12012021-003368-A	<1	FT-FY22-12012021-003368-B	<1
WS-003369	9/7/2021	9/7/2022	1	Combo Faucet	In classroom 114	Low	Left	WF-09072021-003369	1/8/2022	FT-FY22-12012021-003369-A	<1	FT-FY22-12012021-003369-B	<1
WS-003370	5/10/2021	5/10/2022	2	Cooler	In hallway adjacent to stairwell C			WF-05102021-003370	1/8/2022	FT-FY22-12012021-003370-A	<1	FT-FY22-12012021-003370-B	<1
WS-003542	9/7/2021	9/7/2022	1	Combo Faucet	In classroom B126			WF-09072021-003542	1/8/2022	FT-FY22-12012021-003542-A	<1	FT-FY22-12012021-003542-B	<1
WS-003543	5/10/2021	5/10/2022	1	Combo Fountain	In classroom B126			WF-05102021-003543	1/8/2022	FT-FY22-12012021-003543-A	1.2	FT-FY22-12012021-003543-B	<1
WS-003544	5/10/2021	5/10/2022	1	Cooler	In hallway adjacent to classroom B128	High	Left	WF-05102021-003544	1/8/2022	FT-FY22-12012021-003544-A	<1	FT-FY22-12012021-003544-B	<1
WS-003545	5/10/2021	5/10/2022	1	Cooler	In hallway adjacent to classroom B128	Low	Right	WF-05102021-003545	1/8/2022	FT-FY22-12012021-003545-A	<1	FT-FY22-12012021-003545-B	<1
WS-003546	9/7/2021	9/7/2022	1	Combo Faucet	In classroom B128			WF-09072021-003546	1/8/2022	FT-FY22-12012021-003546-A	<1	FT-FY22-12012021-003546-B	<1
WS-003547	5/10/2021	5/10/2022	1	Combo Fountain	In classroom B128			WF-05102021-003547	1/8/2022	FT-FY22-12012021-003547-A	<1	FT-FY22-12012021-003547-B	<1
WS-003548	5/10/2021	5/10/2022	1	Break Room	In workroom B137			WF-05102021-003548	1/8/2022	FT-FY22-12012021-003548-A	<1	FT-FY22-12012021-003548-B	<1
WS-003549	5/10/2021	5/10/2022	1	Cooler	In hallway adjacent to gym			WF-05102021-003549	1/8/2022	FT-FY22-12012021-003549-A	<1	FT-FY22-12012021-003549-B	<1
WS-003551	5/10/2021	5/10/2022	1	Cooler	In classroom D161A			WF-05102021-003551	1/8/2022	FT-FY22-12012021-003551-A	1.7	FT-FY22-12012021-003551-B	<1
WS-003555	5/10/2021	5/10/2022	1	Break Room	In first floor lobby adjacent to principal's office B121			WF-05102021-003555	1/8/2022	FT-FY22-12012021-003555-A	<1	FT-FY22-12012021-003555-B	<1
WS-003558	5/10/2021	5/10/2022	1	Cooler	In hallway adjacent to kitchen			WF-05102021-003558	1/8/2022	FT-FY22-12012021-003558-A	<1	FT-FY22-12012021-003558-B	<1
WS-003559	9/7/2021	9/7/2022	1	Combo Faucet	In classroom A106	High	Left	WF-09072021-003559	1/8/2022	FT-FY22-12012021-003559-A	<1	FT-FY22-12012021-003559-B	<1
WS-003560	5/10/2021	5/10/2022	1	Combo Fountain	In classroom A106	High	Left	WF-05102021-003560	1/8/2022	FT-FY22-12012021-003560-A	<1	FT-FY22-12012021-003560-B	<1
WS-003561	9/7/2021	9/7/2022	1	Combo Faucet	In classroom A106	Low	Right	WF-09072021-003561	1/8/2022	FT-FY22-12012021-003561-A	<1	FT-FY22-12012021-003561-B	<1
WS-003562	5/10/2021	5/10/2022	1	Combo Fountain	In classroom A106	Low	Right	WF-05102021-003562	1/8/2022	FT-FY22-12012021-003562-A	<1	FT-FY22-12012021-003562-B	<1
WS-003563	9/7/2021	9/7/2022	1	Combo Faucet	In classroom A103	Low	Left	WF-09072021-003563	1/8/2022	FT-FY22-12012021-003563-A	<1	FT-FY22-12012021-003563-B	<1
WS-003564	5/10/2021	5/10/2022	1	Combo Fountain	In classroom A103	Low	Left	WF-05102021-003564	1/8/2022	FT-FY22-12012021-003564-A	<1	FT-FY22-12012021-003564-B	<1
WS-003565	9/7/2021	9/7/2022	1	Combo Faucet	In classroom A103	High	Right	WF-09072021-003565	1/8/2022	FT-FY22-12012021-003565-A	<1	FT-FY22-12012021-003565-B	<1
WS-003566	5/10/2021	5/10/2022	1	Combo Fountain	In classroom A103	High	Right	WF-05102021-003566	1/8/2022	FT-FY22-12012021-003566-A	<1	FT-FY22-12012021-003566-B	<1
WS-003567	9/7/2021	9/7/2022	1	Combo Faucet	In classroom A105	High	Left	WF-09072021-003567	1/8/2022	FT-FY22-12012021-003567-A	<1	FT-FY22-12012021-003567-B	<1
WS-003568	5/10/2021	5/10/2022	1	Combo Fountain	In classroom A105	High	Left	WF-05102021-003568	1/8/2022	FT-FY22-12012021-003568-A	<1	FT-FY22-12012021-003568-B	<1
WS-003569	9/7/2021	9/7/2022	1	Combo Faucet	In classroom A105	Low	Right	WF-09072021-003569	1/8/2022	FT-FY22-12012021-003569-A	<1	FT-FY22-12012021-003569-B	<1
WS-003570	5/10/2021	5/10/2022	1	Combo Fountain	In classroom A105	Low	Right	WF-05102021-003570	1/8/2022	FT-FY22-12012021-003570-A	<1	FT-FY22-12012021-003570-B	<1
WS-003571	5/10/2021	5/10/2022	1	Cooler	In hallway adjacent to health suite A116			WF-05102021-003571	1/8/2022	FT-FY22-12012021-003571-A	<1	FT-FY22-12012021-003571-B	<1
WS-003572	9/7/2021	9/7/2022	1	Combo Faucet	In classroom A107	Low	Left	WF-09072021-003572	1/8/2022	FT-FY22-12012021-003572-A	<1	FT-FY22-12012021-003572-B	<1
WS-003573	5/10/2021	5/10/2022	1	Combo Fountain	In classroom A107	Low	Left	WF-05102021-003573	1/8/2022	FT-FY22-12012021-003573-A	<1	FT-FY22-12012021-003573-B	<1
WS-003574	9/7/2021	9/7/2022	1	Combo Faucet	In classroom A107	High	Right	WF-09072021-003574	1/8/2022	FT-FY22-12012021-003574-A	<1	FT-FY22-12012021-003574-B	<1
WS-003575	5/10/2021	5/10/2022	1	Combo Fountain	In classroom A107	High	Right	WF-05102021-003575	1/8/2022	FT-FY22-12012021-003575-A	<1	FT-FY22-12012021-003575-B	<1
WS-003576	5/10/2021	5/10/2022	1	Cooler	In health suite A116			WF-05102021-003576	1/8/2022	FT-FY22-12012021-003576-A	<1	FT-FY22-12012021-003576-B	<1
WS-003577	9/7/2021	9/7/2022	2	Combo Faucet	In classroom A212			WF-09072021-003577	1/8/2022	FT-FY22-12012021-003577-A	<1	FT-FY22-12012021-003577-B	<1
WS-003578	5/10/2021	5/10/2022	2	Combo Fountain	In classroom A212			WF-05102021-003578	1/8/2022	FT-FY22-12012021-003578-A	<1	FT-FY22-12012021-003578-B	<1

WS-003579	9/7/2021	9/7/2022	2	Combo Faucet	In classroom A213	WF-09072021-003579	1/8/2022	FT-FY22-12012021-003579-A	1.5	FT-FY22-12012021-003579-B	<1	
WS-003580	5/10/2021	5/10/2022	2	Combo Fountain	In classroom A213	WF-05102021-003580	1/8/2022	FT-FY22-12012021-003580-A	<1	FT-FY22-12012021-003580-B	<1	
WS-003581	9/7/2021	9/7/2022	2	Combo Faucet	In classroom A209	WF-09072021-003581	1/8/2022	FT-FY22-12012021-003581-A	<1	FT-FY22-12012021-003581-B	<1	
WS-003582	5/10/2021	5/10/2022	2	Combo Fountain	In classroom A209	WF-05102021-003582	1/8/2022	FT-FY22-12012021-003582-A	<1	FT-FY22-12012021-003582-B	<1	
WS-003583	9/7/2021	9/7/2022	2	Combo Faucet	In classroom A208	WF-09072021-003583	1/8/2022	FT-FY22-12012021-003583-A	<1	FT-FY22-12012021-003583-B	<1	
WS-003584	5/10/2021	5/10/2022	2	Combo Fountain	In classroom A208	WF-05102021-003584	1/8/2022	FT-FY22-12012021-003584-A	3.0	FT-FY22-12012021-003584-B	<1	
WS-003585	5/10/2021	5/10/2022	2	Cooler	In hallway between girls' and boys' restrooms	High Left	WF-05102021-003585	1/8/2022	FT-FY22-12012021-003585-A	<1	FT-FY22-12012021-003585-B	<1
WS-003586	5/10/2021	5/10/2022	2	Cooler	In hallway between girls' and boys' restrooms	Low Right	WF-05102021-003586	1/8/2022	FT-FY22-12012021-003586-A	<1	FT-FY22-12012021-003586-B	<1
WS-003587	9/7/2021	9/7/2022	2	Combo Faucet	In classroom A202	WF-09072021-003587	1/8/2022	FT-FY22-12012021-003587-A	<1	FT-FY22-12012021-003587-B	<1	
WS-003588	5/10/2021	5/10/2022	2	Combo Fountain	In classroom A202	WF-05102021-003588	1/8/2022	FT-FY22-12012021-003588-A	<1	FT-FY22-12012021-003588-B	<1	
WS-003589	9/7/2021	9/7/2022	2	Combo Faucet	In classroom B223	WF-09072021-003589	1/8/2022	FT-FY22-12012021-003589-A	<1	FT-FY22-12012021-003589-B	<1	
WS-003590	5/10/2021	5/10/2022	2	Combo Fountain	In classroom B223	WF-05102021-003590	1/8/2022	FT-FY22-12012021-003590-A	<1	FT-FY22-12012021-003590-B	<1	
WS-003591	9/7/2021	9/7/2022	2	Combo Faucet	In classroom B230	WF-09072021-003591	1/8/2022	FT-FY22-12012021-003591-A	1.8	FT-FY22-12012021-003591-B	<1	
WS-003592	5/10/2021	5/10/2022	2	Combo Fountain	In classroom B230	WF-05102021-003592	1/8/2022	FT-FY22-12012021-003592-A	<1	FT-FY22-12012021-003592-B	<1	
WS-003593	9/7/2021	9/7/2022	2	Combo Faucet	In classroom B225	WF-09072021-003593	1/8/2022	FT-FY22-12012021-003593-A	<1	FT-FY22-12012021-003593-B	<1	
WS-003594	5/10/2021	5/10/2022	2	Combo Fountain	In classroom B225	WF-05102021-003594	1/8/2022	FT-FY22-12012021-003594-A	<1	FT-FY22-12012021-003594-B	<1	
WS-003595	9/7/2021	9/7/2022	2	Combo Faucet	In classroom B232	WF-09072021-003595	1/8/2022	FT-FY22-12012021-003595-A	<1	FT-FY22-12012021-003595-B	<1	
WS-003596	5/10/2021	5/10/2022	2	Combo Fountain	In classroom B232	WF-05102021-003596	1/8/2022	FT-FY22-12012021-003596-A	<1	FT-FY22-12012021-003596-B	<1	
WS-003597	9/7/2021	9/7/2022	2	Combo Faucet	In classroom B227	WF-09072021-003597	1/8/2022	FT-FY22-12012021-003597-A	<1	FT-FY22-12012021-003597-B	<1	
WS-003598	5/10/2021	5/10/2022	2	Combo Fountain	In classroom B227	WF-05102021-003598	1/8/2022	FT-FY22-12012021-003598-A	<1	FT-FY22-12012021-003598-B	<1	
WS-003599	9/7/2021	9/7/2022	2	Combo Faucet	In classroom B236	WF-09072021-003599	1/8/2022	FT-FY22-12012021-003599-A	1.6	FT-FY22-12012021-003599-B	<1	
WS-003600	5/10/2021	5/10/2022	2	Combo Fountain	In classroom B236	WF-05102021-003600	1/8/2022	FT-FY22-12012021-003600-A	<1	FT-FY22-12012021-003600-B	<1	
WS-003601	9/7/2021	9/7/2022	2	Combo Faucet	In classroom B231	WF-09072021-003601	1/8/2022	FT-FY22-12012021-003601-A	<1	FT-FY22-12012021-003601-B	<1	
WS-003602	5/10/2021	5/10/2022	2	Combo Fountain	In classroom B231	WF-05102021-003602	1/8/2022	FT-FY22-12012021-003602-A	<1	FT-FY22-12012021-003602-B	<1	
WS-003603	5/10/2021	5/10/2022	1	Health Suite	In health suite A116 in bathroom	WF-05102021-003603	1/8/2022	FT-FY22-12012021-003603-A	<1	FT-FY22-12012021-003603-B	<1	
WS-003605	9/7/2021	9/7/2022	2	Combo Faucet	In ESL teacher room adjacent to classroom 269	WF-09072021-003605	1/8/2022	FT-FY22-12012021-003605-A	<1	FT-FY22-12012021-003605-B	<1	

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003556	2/17/2021	2/17/2022	1	Food Prep Sink	In kitchen on south wall (dishwashing hose) Left	WF-02172021-003556	1/8/2022	FT-FY22-12012021-003556-A	<1	FT-FY22-12012021-003556-B	<1
WS-003557	2/17/2021	2/17/2022	1	Food Prep Sink	In kitchen on south wall Right	WF-02172021-003557	1/8/2022	FT-FY22-12012021-003557-A	<1	FT-FY22-12012021-003557-B	<1

### FY22 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003606	5/10/2021	5/10/2022	2	Combo Fountain	In ESL teacher room adjacent to classroom 269	WF-05102021-003606	1/8/2022	FT-FY22-12012021-003606-A	15.3	FT-FY22-12012021-003606-B	<1