



Amidon Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003366	6/9/2020	6/9/2021	1	Combo Fountain	In classroom 114 High Right	WF-06092020-003366	3/1/2021	FT-FY21-022021-003366-A	<1	FT-FY21-022021-003366-B	<1
WS-003367	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom 114 High Right	WF-09142020-003367	3/1/2021	FT-FY21-022021-003367-A	<1	FT-FY21-022021-003367-B	<1
WS-003368	6/9/2020	6/9/2021	1	Combo Fountain	In classroom 114 Low Left	WF-06092020-003368	3/1/2021	FT-FY21-022021-003368-A	<1	FT-FY21-022021-003368-B	<1
WS-003369	9/14/2020	9/14/2021	1	Combo Faucet	In classroom 114 Low Left	WF-09142020-003369	3/1/2021	FT-FY21-022021-003369-A	<1	FT-FY21-022021-003369-B	<1
WS-003542	9/14/2020	9/14/2021	1	Combo Faucet	In classroom B126	WF-09142020-003542	3/1/2021	FT-FY21-022021-003542-A	<1	FT-FY21-022021-003542-B	<1
WS-003543	6/9/2020	6/9/2021	1	Combo Fountain	In classroom B126	WF-06092020-003543	3/1/2021	FT-FY21-022021-003543-A	<1	FT-FY21-022021-003543-B	<1
WS-003544	6/9/2020	6/9/2021	1	Cooler	In hallway adjacent to classroom B128 High Left	WF-06092020-003544	3/1/2021	FT-FY21-022021-003544-A	<1	FT-FY21-022021-003544-B	<1
WS-003545	6/9/2020	6/9/2021	1	Cooler	In hallway adjacent to classroom B128 Low Right	WF-06092020-003545	3/1/2021	FT-FY21-022021-003545-A	<1	FT-FY21-022021-003545-B	<1
WS-003546	9/14/2020	9/14/2021	1	Combo Faucet	In classroom B128	WF-09142020-003546	3/1/2021	FT-FY21-022021-003546-A	<1	FT-FY21-022021-003546-B	<1
WS-003547	6/9/2020	6/9/2021	1	Combo Fountain	In classroom B128	WF-06092020-003547	3/1/2021	FT-FY21-022021-003547-A	<1	FT-FY21-022021-003547-B	<1
WS-003548	6/9/2020	6/9/2021	1	Break Room	In workroom B137	WF-06092020-003548	3/1/2021	FT-FY21-022021-003548-A	<1	FT-FY21-022021-003548-B	<1
WS-003550	6/9/2020	6/9/2021	1	Cooler	In gym	WF-06092020-003550	3/1/2021	FT-FY21-022021-003550-A	<1	FT-FY21-022021-003550-B	<1
WS-003551	6/9/2020	6/9/2021	1	Cooler	In classroom D161A	WF-06092020-003551	3/1/2021	FT-FY21-022021-003551-A	<1	FT-FY21-022021-003551-B	<1
WS-003555	6/9/2020	6/9/2021	1	Break Room	In first floor lobby adjacent to principal's office B121	WF-06092020-003555	3/1/2021	FT-FY21-022021-003555-A	1.7	FT-FY21-022021-003555-B	<1
WS-003558	6/9/2020	6/9/2021	1	Cooler	In hallway adjacent to kitchen	WF-06092020-003558	3/1/2021	FT-FY21-022021-003558-A	<1	FT-FY21-022021-003558-B	<1
WS-003559	9/14/2020	9/14/2021	1	Combo Faucet	In classroom A106 High Left	WF-09142020-003559	3/1/2021	FT-FY21-022021-003559-A	<1	FT-FY21-022021-003559-B	<1
WS-003560	6/9/2020	6/9/2021	1	Combo Fountain	In classroom A106 High Left	WF-06092020-003560	3/1/2021	FT-FY21-022021-003560-A	1.4	FT-FY21-022021-003560-B	<1
WS-003561	9/14/2020	9/14/2021	1	Combo Faucet	In classroom A106 Low Right	WF-09142020-003561	3/1/2021	FT-FY21-022021-003561-A	<1	FT-FY21-022021-003561-B	<1
WS-003562	6/9/2020	6/9/2021	1	Combo Fountain	In classroom A106 Low Right	WF-06092020-003562	3/1/2021	FT-FY21-022021-003562-A	<1	FT-FY21-022021-003562-B	<1
WS-003563	9/14/2020	9/14/2021	1	Combo Faucet	In classroom A103 Low Left	WF-09142020-003563	3/1/2021	FT-FY21-022021-003563-A	<1	FT-FY21-022021-003563-B	<1
WS-003564	6/9/2020	6/9/2021	1	Combo Fountain	In classroom A103 Low Left	WF-06092020-003564	3/1/2021	FT-FY21-022021-003564-A	<1	FT-FY21-022021-003564-B	<1
WS-003565	9/14/2020	9/14/2021	1	Combo Faucet	In classroom A103 High Right	WF-09142020-003565	3/1/2021	FT-FY21-022021-003565-A	<1	FT-FY21-022021-003565-B	<1
WS-003566	6/9/2020	6/9/2021	1	Combo Fountain	In classroom A103 High Right	WF-06092020-003566	3/1/2021	FT-FY21-022021-003566-A	<1	FT-FY21-022021-003566-B	<1
WS-003567	9/14/2020	9/14/2021	1	Combo Faucet	In classroom A105 High Left	WF-09142020-003567	3/1/2021	FT-FY21-022021-003567-A	1.1	FT-FY21-022021-003567-B	<1
WS-003568	6/9/2020	6/9/2021	1	Combo Fountain	In classroom A105 High Left	WF-06092020-003568	3/1/2021	FT-FY21-022021-003568-A	<1	FT-FY21-022021-003568-B	<1
WS-003569	9/14/2020	9/14/2021	1	Combo Faucet	In classroom A105 Low Right	WF-09142020-003569	3/1/2021	FT-FY21-022021-003569-A	1.0	FT-FY21-022021-003569-B	<1
WS-003570	6/9/2020	6/9/2021	1	Combo Fountain	In classroom A105 Low Right	WF-06092020-003570	3/1/2021	FT-FY21-022021-003570-A	<1	FT-FY21-022021-003570-B	<1
WS-003572	9/14/2020	9/14/2021	1	Combo Faucet	In classroom A107 Low Left	WF-09142020-003572	3/1/2021	FT-FY21-022021-003572-A	2.0	FT-FY21-022021-003572-B	<1
WS-003573	6/9/2020	6/9/2021	1	Combo Fountain	In classroom A107 Low Left	WF-06092020-003573	3/1/2021	FT-FY21-022021-003573-A	<1	FT-FY21-022021-003573-B	<1
WS-003574	9/14/2020	9/14/2021	1	Combo Faucet	In classroom A107 High Right	WF-09142020-003574	3/1/2021	FT-FY21-022021-003574-A	<1	FT-FY21-022021-003574-B	<1
WS-003575	6/9/2020	6/9/2021	1	Combo Fountain	In classroom A107 High Right	WF-06092020-003575	3/1/2021	FT-FY21-022021-003575-A	<1	FT-FY21-022021-003575-B	<1
WS-003576	6/9/2020	6/9/2021	1	Cooler	In health suite A116	WF-06092020-003576	3/1/2021	FT-FY21-022021-003576-A	<1	FT-FY21-022021-003576-B	<1

WS- 003577	9/14/2020	9/14/2021	2	Combo Faucet	In classroom A212		WF-09142020-003577	3/1/2021	FT-FY21-022021-003577-A	<1	FT-FY21-022021-003577-B	<1
WS- 003578	6/9/2020	6/9/2021	2	Combo Fountain	In classroom A212		WF-06092020-003578	3/1/2021	FT-FY21-022021-003578-A	<1	FT-FY21-022021-003578-B	<1
WS- 003579	9/14/2020	9/14/2021	2	Combo Faucet	In classroom A213		WF-09142020-003579	3/1/2021	FT-FY21-022021-003579-A	<1	FT-FY21-022021-003579-B	<1
WS- 003580	6/9/2020	6/9/2021	2	Combo Fountain	In classroom A213		WF-06092020-003580	3/1/2021	FT-FY21-022021-003580-A	<1	FT-FY21-022021-003580-B	<1
WS- 003581	9/14/2020	9/14/2021	2	Combo Faucet	In classroom A209		WF-09142020-003581	3/1/2021	FT-FY21-022021-003581-A	<1	FT-FY21-022021-003581-B	<1
WS- 003582	6/9/2020	6/9/2021	2	Combo Fountain	In classroom A209		WF-06092020-003582	3/1/2021	FT-FY21-022021-003582-A	<1	FT-FY21-022021-003582-B	<1
WS- 003583	9/14/2020	9/14/2021	2	Combo Faucet	In classroom A208		WF-09142020-003583	3/1/2021	FT-FY21-022021-003583-A	<1	FT-FY21-022021-003583-B	<1
WS- 003584	6/9/2020	6/9/2021	2	Combo Fountain	In classroom A208		WF-06092020-003584	3/1/2021	FT-FY21-022021-003584-A	<1	FT-FY21-022021-003584-B	<1
WS- 003585	6/9/2020	6/9/2021	2	Cooler	In hallway between girls' and boys' restrooms	High Left	WF-06092020-003585	3/1/2021	FT-FY21-022021-003585-A	<1	FT-FY21-022021-003585-B	<1
WS- 003586	6/9/2020	6/9/2021	2	Cooler	In hallway between girls' and boys' restrooms	Low Right	WF-06092020-003586	3/1/2021	FT-FY21-022021-003586-A	<1	FT-FY21-022021-003586-B	<1
WS- 003587	9/14/2020	9/14/2021	2	Combo Faucet	In classroom A202		WF-09142020-003587	3/1/2021	FT-FY21-022021-003587-A	<1	FT-FY21-022021-003587-B	<1
WS- 003588	6/9/2020	6/9/2021	2	Combo Fountain	In classroom A202		WF-06092020-003588	3/1/2021	FT-FY21-022021-003588-A	<1	FT-FY21-022021-003588-B	<1
WS- 003589	9/14/2020	9/14/2021	2	Combo Faucet	In classroom B223		WF-09142020-003589	3/1/2021	FT-FY21-022021-003589-A	<1	FT-FY21-022021-003589-B	<1
WS- 003590	6/9/2020	6/9/2021	2	Combo Fountain	In classroom B223		WF-06092020-003590	3/1/2021	FT-FY21-022021-003590-A	<1	FT-FY21-022021-003590-B	<1
WS- 003591	9/14/2020	9/14/2021	2	Combo Faucet	In classroom B230		WF-09142020-003591	3/1/2021	FT-FY21-022021-003591-A	<1	FT-FY21-022021-003591-B	<1
WS- 003592	6/9/2020	6/9/2021	2	Combo Fountain	In classroom B230		WF-06092020-003592	3/1/2021	FT-FY21-022021-003592-A	<1	FT-FY21-022021-003592-B	<1
WS- 003593	9/14/2020	9/14/2021	2	Combo Faucet	In classroom B225		WF-09142020-003593	3/1/2021	FT-FY21-022021-003593-A	<1	FT-FY21-022021-003593-B	<1
WS- 003594	6/9/2020	6/9/2021	2	Combo Fountain	In classroom B225		WF-06092020-003594	3/1/2021	FT-FY21-022021-003594-A	<1	FT-FY21-022021-003594-B	<1
WS- 003595	9/14/2020	9/14/2021	2	Combo Faucet	In classroom B232		WF-09142020-003595	3/1/2021	FT-FY21-022021-003595-A	<1	FT-FY21-022021-003595-B	<1
WS- 003596	6/9/2020	6/9/2021	2	Combo Fountain	In classroom B232		WF-06092020-003596	3/1/2021	FT-FY21-022021-003596-A	<1	FT-FY21-022021-003596-B	<1
WS- 003597	9/14/2020	9/14/2021	2	Combo Faucet	In classroom B227		WF-09142020-003597	3/1/2021	FT-FY21-022021-003597-A	<1	FT-FY21-022021-003597-B	<1
WS- 003598	6/9/2020	6/9/2021	2	Combo Fountain	In classroom B227		WF-06092020-003598	3/1/2021	FT-FY21-022021-003598-A	<1	FT-FY21-022021-003598-B	<1
WS- 003599	9/14/2020	9/14/2021	2	Combo Faucet	In classroom B236		WF-09142020-003599	3/1/2021	FT-FY21-022021-003599-A	<1	FT-FY21-022021-003599-B	<1
WS- 003600	6/9/2020	6/9/2021	2	Combo Fountain	In classroom B236		WF-06092020-003600	3/1/2021	FT-FY21-022021-003600-A	<1	FT-FY21-022021-003600-B	<1
WS- 003601	9/14/2020	9/14/2021	2	Combo Faucet	In classroom B231		WF-09142020-003601	3/1/2021	FT-FY21-022021-003601-A	<1	FT-FY21-022021-003601-B	<1
WS- 003602	6/9/2020	6/9/2021	2	Combo Fountain	In classroom B231		WF-06092020-003602	3/1/2021	FT-FY21-022021-003602-A	<1	FT-FY21-022021-003602-B	<1
WS- 003603	6/9/2020	6/9/2021	1	Health Suite	In health suite A116 in bathroom		WF-06092020-003603	3/1/2021	FT-FY21-022021-003603-A	<1	FT-FY21-022021-003603-B	<1
WS- 003605	9/14/2020	9/14/2021	2	Combo Faucet	In ESL teacher room adjacent to classroom 269		WF-09142020-003605	3/1/2021	FT-FY21-022021-003605-A	<1	FT-FY21-022021-003605-B	<1
WS- 003606	6/9/2020	6/9/2021	2	Combo Fountain	In ESL teacher room adjacent to classroom 269		WF-06092020-003606	3/1/2021	FT-FY21-022021-003606-A	<1	FT-FY21-022021-003606-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003556	2/19/2020	2/19/2021	1	Food Prep Sink	In kitchen on south wall (dishwashing hose)	Left	WF-02192020-003556	3/1/2021	FT-FY21-022021-003556-A	<1	FT-FY21-022021-003556-B	<1
WS- 003557	2/17/2021	2/17/2022	1	Food Prep Sink	In kitchen on south wall	Right	WF-02172021-003557	3/1/2021	FT-FY21-022021-003557-A	<1	FT-FY21-022021-003557-B	<1