



Amidon ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003366	4/7/2025	4/7/2026	1	Combo Fountain	In classroom 114 High Right	WF-04072025-003366	10/15/2025	FT-FY26-09302025-003366-A	<2	FT-FY26-09302025-003366-B	<2
WS- 003367	8/11/2025	8/11/2026	1	Classroom Faucet	In classroom 114 High Right	WF-08112025-003367	10/15/2025	FT-FY26-09302025-003367-A	<2	FT-FY26-09302025-003367-B	<2
WS- 003368	4/7/2025	4/7/2026	1	Combo Fountain	In classroom 114 Low Left	WF-04072025-003368	10/15/2025	FT-FY26-09302025-003368-A	<2	FT-FY26-09302025-003368-B	<2
WS- 003369	8/11/2025	8/11/2026	1	Combo Faucet	In classroom 114 Low Left	WF-08112025-003369	10/15/2025	FT-FY26-09302025-003369-A	<2	FT-FY26-09302025-003369-B	<2
WS- 003370	4/7/2025	4/7/2026	2	Cooler	In hallway adjacent to stairwell C	WF-04072025-003370	10/15/2025	FT-FY26-09302025-003370-A	<2	FT-FY26-09302025-003370-B	<2
WS- 003375	4/7/2025	4/7/2026	2	Bottle Filler	In hallway adjacent to stairwell C	WF-04072025-003375	10/15/2025	FT-FY26-09302025-003375-A	<2	FT-FY26-09302025-003375-B	<2
WS- 003376	4/7/2025	4/7/2026	1	Bottle Filler	In hallway adjacent to gym	WF-04072025-003376	10/15/2025	FT-FY26-09302025-003376-A	<2	FT-FY26-09302025-003376-B	<2
WS- 003377	4/7/2025	4/7/2026	1	Bottle Filler	In hallway adjacent to health suite A116	WF-04072025-003377	10/15/2025	FT-FY26-09302025-003377-A	<2	FT-FY26-09302025-003377-B	<2
WS- 003542	8/11/2025	8/11/2026	1	Combo Faucet	In classroom B126	WF-08112025-003542	10/15/2025	FT-FY26-09302025-003542-A	<2	FT-FY26-09302025-003542-B	<2
WS- 003543	4/7/2025	4/7/2026	1	Combo Fountain	In classroom B126	WF-04072025-003543	10/15/2025	FT-FY26-09302025-003543-A	<2	FT-FY26-09302025-003543-B	<2
WS- 003547	4/7/2025	4/7/2026	1	Combo Fountain	In classroom B128	WF-04072025-003547	10/15/2025	FT-FY26-09302025-003547-A	<2	FT-FY26-09302025-003547-B	<2
WS- 003549	4/7/2025	4/7/2026	1	Cooler	In hallway adjacent to gym	WF-04072025-003549	10/15/2025	FT-FY26-09302025-003549-A	<2	FT-FY26-09302025-003549-B	<2
WS- 003550	4/7/2025	4/7/2026	1	Cooler	In gym	WF-04072025-003550	10/15/2025	FT-FY26-09302025-003550-A	<2	FT-FY26-09302025-003550-B	<2
WS- 003555	4/7/2025	4/7/2026	1	Break Room	In first floor lobby adjacent to principal's office B121	WF-04072025-003555	10/15/2025	FT-FY26-09302025-003555-A	<2	FT-FY26-09302025-003555-B	<2
WS- 003558	4/7/2025	4/7/2026	1	Cooler	In hallway adjacent to kitchen	WF-04072025-003558	10/15/2025	FT-FY26-09302025-003558-A	<2	FT-FY26-09302025-003558-B	<2
WS- 003559	8/11/2025	8/11/2026	1	Combo Faucet	In classroom A106 High Left	WF-08112025-003559	10/15/2025	FT-FY26-09302025-003559-A	<2	FT-FY26-09302025-003559-B	<2
WS- 003560	4/7/2025	4/7/2026	1	Combo Fountain	In classroom A106 High Left	WF-04072025-003560	10/15/2025	FT-FY26-09302025-003560-A	<2	FT-FY26-09302025-003560-B	<2
WS- 003561	8/11/2025	8/11/2026	1	Combo Faucet	In classroom A106 Low Right	WF-08112025-003561	10/15/2025	FT-FY26-09302025-003561-A	<2	FT-FY26-09302025-003561-B	<2
WS- 003562	4/7/2025	4/7/2026	1	Combo Fountain	In classroom A106 Low Right	WF-04072025-003562	10/15/2025	FT-FY26-09302025-003562-A	<2	FT-FY26-09302025-003562-B	<2
WS- 003563	8/11/2025	8/11/2026	1	Combo Faucet	In classroom A103 Low Left	WF-08112025-003563	10/15/2025	FT-FY26-09302025-003563-A	<2	FT-FY26-09302025-003563-B	<2
WS- 003564	4/7/2025	4/7/2026	1	Combo Fountain	In classroom A103 Low Left	WF-04072025-003564	10/15/2025	FT-FY26-09302025-003564-A	<2	FT-FY26-09302025-003564-B	<2
WS- 003565	8/11/2025	8/11/2026	1	Combo Faucet	In classroom A103 High Right	WF-08112025-003565	10/15/2025	FT-FY26-09302025-003565-A	<2	FT-FY26-09302025-003565-B	<2
WS- 003566	4/7/2025	4/7/2026	1	Combo Fountain	In classroom A103 High Right	WF-04072025-003566	10/15/2025	FT-FY26-09302025-003566-A	<2	FT-FY26-09302025-003566-B	<2
WS- 003567	8/11/2025	8/11/2026	1	Combo Faucet	In classroom A105 High Left	WF-08112025-003567	10/15/2025	FT-FY26-09302025-003567-A	<2	FT-FY26-09302025-003567-B	<2
WS- 003568	4/7/2025	4/7/2026	1	Combo Fountain	In classroom A105 High Left	WF-04072025-003568	10/15/2025	FT-FY26-09302025-003568-A	<2	FT-FY26-09302025-003568-B	<2
WS- 003569	8/11/2025	8/11/2026	1	Combo Faucet	In classroom A105 Low Right	WF-08112025-003569	10/15/2025	FT-FY26-09302025-003569-A	<2	FT-FY26-09302025-003569-B	<2
WS- 003570	4/7/2025	4/7/2026	1	Combo Fountain	In classroom A105 Low Right	WF-04072025-003570	10/15/2025	FT-FY26-09302025-003570-A	<2	FT-FY26-09302025-003570-B	<2
WS- 003571	4/7/2025	4/7/2026	1	Cooler	In hallway adjacent to health suite A116	WF-04072025-003571	10/15/2025	FT-FY26-09302025-003571-A	<2	FT-FY26-09302025-003571-B	<2
WS- 003572	8/11/2025	8/11/2026	1	Combo Faucet	In classroom A107 Low Left	WF-08112025-003572	10/15/2025	FT-FY26-09302025-003572-A	<2	FT-FY26-09302025-003572-B	<2
WS- 003573	4/7/2025	4/7/2026	1	Combo Fountain	In classroom A107 Low Left	WF-04072025-003573	10/15/2025	FT-FY26-09302025-003573-A	<2	FT-FY26-09302025-003573-B	<2
WS- 003574	8/11/2025	8/11/2026	1	Combo Faucet	In classroom A107 High Right	WF-08112025-003574	10/15/2025	FT-FY26-09302025-003574-A	<2	FT-FY26-09302025-003574-B	<2
WS- 003575	4/7/2025	4/7/2026	1	Combo Fountain	In classroom A107 High Right	WF-04072025-003575	10/15/2025	FT-FY26-09302025-003575-A	<2	FT-FY26-09302025-003575-B	<2
WS- 003576	4/7/2025	4/7/2026	1	Cooler	In health suite A116	WF-04072025-003576	10/15/2025	FT-FY26-09302025-003576-A	<2	FT-FY26-09302025-003576-B	<2
WS- 003577	8/11/2025	8/11/2026	2	Combo Faucet	In classroom A212	WF-08112025-003577	10/15/2025	FT-FY26-09302025-003577-A	<2	FT-FY26-09302025-003577-B	<2

WS- 003578	4/7/2025	4/7/2026	2	Combo Fountain	In classroom A212		WF-04072025-003578	10/15/2025	FT-FY26-09302025-003578-A	<2	FT-FY26-09302025-003578-B	<2
WS- 003579	8/11/2025	8/11/2026	2	Combo Faucet	In classroom A213		WF-08112025-003579	10/15/2025	FT-FY26-09302025-003579-A	<2	FT-FY26-09302025-003579-B	<2
WS- 003580	4/7/2025	4/7/2026	2	Combo Fountain	In classroom A213		WF-04072025-003580	10/15/2025	FT-FY26-09302025-003580-A	<2	FT-FY26-09302025-003580-B	<2
WS- 003581	8/11/2025	8/11/2026	2	Combo Faucet	In classroom A209		WF-08112025-003581	10/15/2025	FT-FY26-09302025-003581-A	<2	FT-FY26-09302025-003581-B	<2
WS- 003582	4/7/2025	4/7/2026	2	Combo Fountain	In classroom A209		WF-04072025-003582	10/15/2025	FT-FY26-09302025-003582-A	<2	FT-FY26-09302025-003582-B	<2
WS- 003583	8/11/2025	8/11/2026	2	Combo Faucet	In classroom A208		WF-08112025-003583	10/15/2025	FT-FY26-09302025-003583-A	<2	FT-FY26-09302025-003583-B	<2
WS- 003584	4/7/2025	4/7/2026	2	Combo Fountain	In classroom A208		WF-04072025-003584	10/15/2025	FT-FY26-09302025-003584-A	<2	FT-FY26-09302025-003584-B	<2
WS- 003587	8/11/2025	8/11/2026	2	Combo Faucet	In classroom A202		WF-08112025-003587	10/15/2025	FT-FY26-09302025-003587-A	<2	FT-FY26-09302025-003587-B	<2
WS- 003588	4/7/2025	4/7/2026	2	Combo Fountain	In classroom A202		WF-04072025-003588	10/15/2025	FT-FY26-09302025-003588-A	<2	FT-FY26-09302025-003588-B	<2
WS- 003589	8/11/2025	8/11/2026	2	Combo Faucet	In classroom B223		WF-08112025-003589	10/15/2025	FT-FY26-09302025-003589-A	<2	FT-FY26-09302025-003589-B	<2
WS- 003590	4/7/2025	4/7/2026	2	Combo Fountain	In classroom B223		WF-04072025-003590	10/15/2025	FT-FY26-09302025-003590-A	<2	FT-FY26-09302025-003590-B	<2
WS- 003591	8/11/2025	8/11/2026	2	Combo Faucet	In classroom B230		WF-08112025-003591	10/15/2025	FT-FY26-09302025-003591-A	<2	FT-FY26-09302025-003591-B	<2
WS- 003592	4/7/2025	4/7/2026	2	Combo Fountain	In classroom B230		WF-04072025-003592	10/15/2025	FT-FY26-09302025-003592-A	<2	FT-FY26-09302025-003592-B	<2
WS- 003593	8/11/2025	8/11/2026	2	Combo Faucet	In classroom B225		WF-08112025-003593	10/15/2025	FT-FY26-09302025-003593-A	<2	FT-FY26-09302025-003593-B	<2
WS- 003594	4/7/2025	4/7/2026	2	Combo Fountain	In classroom B225		WF-04072025-003594	10/15/2025	FT-FY26-09302025-003594-A	<2	FT-FY26-09302025-003594-B	<2
WS- 003595	8/11/2025	8/11/2026	2	Combo Faucet	In classroom B232		WF-08112025-003595	10/15/2025	FT-FY26-09302025-003595-A	<2	FT-FY26-09302025-003595-B	<2
WS- 003596	4/7/2025	4/7/2026	2	Combo Fountain	In classroom B232		WF-04072025-003596	10/15/2025	FT-FY26-09302025-003596-A	<2	FT-FY26-09302025-003596-B	<2
WS- 003597	8/11/2025	8/11/2026	2	Combo Faucet	In classroom B227		WF-08112025-003597	10/15/2025	FT-FY26-09302025-003597-A	<2	FT-FY26-09302025-003597-B	<2
WS- 003598	4/7/2025	4/7/2026	2	Combo Fountain	In classroom B227		WF-04072025-003598	10/15/2025	FT-FY26-09302025-003598-A	<2	FT-FY26-09302025-003598-B	<2
WS- 003599	8/11/2025	8/11/2026	2	Combo Faucet	In classroom B236		WF-08112025-003599	10/15/2025	FT-FY26-09302025-003599-A	<2	FT-FY26-09302025-003599-B	<2
WS- 003600	4/7/2025	4/7/2026	2	Combo Fountain	In classroom B236		WF-04072025-003600	10/15/2025	FT-FY26-09302025-003600-A	<2	FT-FY26-09302025-003600-B	<2
WS- 003601	8/11/2025	8/11/2026	2	Combo Faucet	In classroom B231		WF-08112025-003601	10/15/2025	FT-FY26-09302025-003601-A	<2	FT-FY26-09302025-003601-B	<2
WS- 003602	4/7/2025	4/7/2026	2	Combo Fountain	In classroom B231		WF-04072025-003602	10/15/2025	FT-FY26-09302025-003602-A	<2	FT-FY26-09302025-003602-B	<2
WS- 003603	4/7/2025	4/7/2026	1	Health Suite	In health suite A116 in bathroom		WF-04072025-003603	10/15/2025	FT-FY26-09302025-003603-A	<2	FT-FY26-09302025-003603-B	<2
WS- 003605	8/11/2025	8/11/2026	2	Combo Faucet	In ESL teacher room adjacent to classroom 269		WF-08112025-003605	10/15/2025	FT-FY26-09302025-003605-A	<2	FT-FY26-09302025-003605-B	<2
WS- 003606	4/7/2025	4/7/2026	2	Combo Fountain	In ESL teacher room adjacent to classroom 269		WF-04072025-003606	10/15/2025	FT-FY26-09302025-003606-A	<2	FT-FY26-09302025-003606-B	<2
WS- 004530	8/11/2025	8/11/2026	1	Combo Faucet	In classroom B135		WF-08112025-004530	10/15/2025	FT-FY26-09302025-004530-A	<2	FT-FY26-09302025-004530-B	<2
WS- 004531	4/7/2025	4/7/2026	1	Combo Fountain	In classroom B135		WF-04072025-004531	10/15/2025	FT-FY26-09302025-004531-A	<2	FT-FY26-09302025-004531-B	<2
WS- 004862	4/7/2025	4/7/2026	1	Combo Fountain	In Room 1	Low Left	WF-04072025-004862	10/15/2025	FT-FY26-09302025-004862-A	<2	FT-FY26-09302025-004862-B	<2
WS- 004864	4/7/2025	4/7/2026	1	Combo Fountain	In Room 1	High Right	WF-04072025-004864	10/15/2025	FT-FY26-09302025-004864-A	<2	FT-FY26-09302025-004864-B	<2
WS- 004866	4/7/2025	4/7/2026	1	Combo Fountain	In Room 2	Left	WF-04072025-004866	10/15/2025	FT-FY26-09302025-004866-A	<2	FT-FY26-09302025-004866-B	<2
WS- 004868	4/7/2025	4/7/2026	1	Combo Fountain	In Room 2	Right	WF-04072025-004868	10/15/2025	FT-FY26-09302025-004868-A	<2	FT-FY26-09302025-004868-B	<2
WS- 004870	4/7/2025	4/7/2026	2	Combo Fountain	In Room 3	High Left	WF-04072025-004870	10/15/2025	FT-FY26-09302025-004870-A	<2	FT-FY26-09302025-004870-B	<2
WS- 004872	4/7/2025	4/7/2026	2	Combo Fountain	In Room 3	Low Right	WF-04072025-004872	10/15/2025	FT-FY26-09302025-004872-A	<2	FT-FY26-09302025-004872-B	<2
WS- 004874	4/7/2025	4/7/2026	2	Combo Fountain	In Room 4	High Left	WF-04072025-004874	10/15/2025	FT-FY26-09302025-004874-A	<2	FT-FY26-09302025-004874-B	<2
WS- 004876	4/7/2025	4/7/2026	2	Combo Fountain	In Room 4	Low Right	WF-04072025-004876	10/15/2025	FT-FY26-09302025-004876-A	<2	FT-FY26-09302025-004876-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003556	11/13/2024	11/13/2025	1	Food Prep Sink	In kitchen on south wall (dishwashing hose)	Left	WF-11132024-003556	10/15/2025	FT-FY26-09302025-003556-A	<2	FT-FY26-09302025-003556-B	<2
WS- 003557	11/13/2024	11/13/2025	1	Food Prep Sink	In kitchen on south wall	Right	WF-11132024-003557	10/15/2025	FT-FY26-09302025-003557-A	<2	FT-FY26-09302025-003557-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.